



Technical Specification 41-24

Issue <1> 2017

Guidelines for the Design, Installation, Testing and Maintenance of Main Earthing Systems in Substations

© <year of publication> **Energy Networks Association**

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written consent of Energy Networks Association. Specific enquiries concerning this document should be addressed to:

**Operations Directorate
Energy Networks Association
6th Floor, Dean Bradley House
52 Horseferry Rd
London
SW1P 2AF**

This document has been prepared for use by members of the Energy Networks Association to take account of the conditions which apply to them. Advice should be taken from an appropriately qualified engineer on the suitability of this document for any other purpose.

<Insert publication history here, e.g. "First published, December, 2011">

Amendments since publication

Issue	Date	Amendment
Issue <1>	<April, 2016>	Draft updated in line with comments from previous meeting. References to S34 highlighted for discussion at April Meeting. Some comments included in body for guidance. Other changes accepted and tracked changes removed [RW].
	June 2016	Minor changes for review at June meeting
	August 2016	Edits following June meeting. All changes accepted. Yellow highlight for S34 references remaining. TO DO: Case studies at end of document. Flow chart.
	Dec 2016 / March 2017	Risk assessment section revised and flow chart updated. General tidy prior to issue.

1	Contents	
2	Foreword	9
3	1 Scope	10
4	2 Normative references	10
5	3 Definitions	11
6	4 Fundamental Requirements	15
7	4.1 Function of an earthing system.....	15
8	4.2 Typical features of an earthing system.....	15
9	4.3 The effects of substation potential rise on persons.....	16
10	4.3.1 Touch potential	17
11	4.3.2 Step potential	17
12	4.3.3 Transfer potential	17
13	4.3.4 General	17
14	4.3.5 Limits for LV networks	18
15	4.3.6 Limits for Other systems	18
16	4.3.7 Limits for Telecommunications Equipment (HOT/COLD sites).....	18
17	4.4 Safety criteria	18
18	4.4.1 General ‘permissible’ design limits	18
19	4.4.2 Effect of electricity on animals	22
20	4.4.3 Injury or shock to persons and animals outside the installation	22
21	4.5 Electrical Requirements	22
22	4.5.1 Method of neutral earthing.....	22
23	4.5.2 Fault Current	23
24	4.5.3 Thermal effects - general.....	23
25	5 Design	24
26	5.1 Design Considerations	24
27	5.1.1 Limiting values for EPR	24
28	5.1.2 Touch and Step voltages	24
29	5.1.3 Factors to include in calculation of EPR and Safety Voltages	24
30	5.1.4 Transfer Potential.....	24
31	5.2 Preliminary Arrangement and Layout	25
32	5.3 Design Guidelines	25
33	5.3.1 Outdoor Substations	25
34	5.3.2 Indoor Substations	26
35	5.3.3 Shared Sites.....	27
36	5.3.4 Distribution (or ‘Secondary’) Substations	27
37	5.3.5 Metallic Fences	27
38	5.3.6 Provision of Maintenance/Test facilities	27
39	5.4 Design data	28
40	5.4.1 Soil Resistivity	28
41	5.4.2 Fault currents and durations - general	29
42	5.4.3 Fault current growth	30
43	5.4.4 Fault currents for EPR and safety voltage calculations	30

44	5.4.5	Fault currents and clearance times for conductor size (thermal effects)	
45		31
46	5.4.6	Fault currents and times for electrode size calculations (thermal	
47		effects)	32
48	5.5	Conductor and Electrode Ratings	34
49	5.5.1	Earthing Conductors and Electrodes.....	34
50	5.5.2	Electrode Surface Current Density Ratings	40
51	5.6	Design Assessment	42
52	5.6.1	Design flowchart	42
53	5.6.2	Assessment Procedure.....	44
54	5.6.3	Methods to improve design (Mitigation measures)	45
55		5.6.3.1 EPR reduction.....	45
56		5.6.3.2 Touch Voltage reduction.....	46
57	5.7	Risk Assessment.....	46
58	5.7.1	Methodology.....	46
59	5.7.2	Typical applications.....	47
60	6	Construction of Earthing Systems	48
61	6.1	General Design Philosophy	48
62	6.1.1	Materials.....	48
63	6.1.2	Avoiding Theft	48
64	6.2	Jointing Conductors and Equipment Connections	49
65	6.2.1	General	49
66	6.2.2	Transition washers.....	49
67	6.2.3	Copper to Copper Connections	50
68	6.2.4	Copper to Earth Rods	50
69	6.2.5	Electrode Test Points.....	50
70	6.2.6	Copper to Equipment (Steel, or Galvanised Steel) Connections.....	50
71	6.2.7	Aluminium to Equipment Connections	50
72	6.2.8	Aluminium to Aluminium Connections.....	51
73	6.2.9	Aluminium to Copper Connections.....	51
74	6.2.10	Earthing Connections to Aluminium Structures.....	52
75	6.2.11	Steel Structures	52
76	6.3	Above Ground Earthing Installations	53
77	6.3.1	Fixing Above Ground Conductor to Supports	53
78	6.3.2	Prevention of Corrosion of Above Ground Conductors	53
79	6.3.3	Metal Trench Covers	53
80	6.3.4	Loops for Portable Earth Connections	53
81	6.4	Below Ground Earthing Installations	54
82	6.4.1	Installation of Buried Electrode within a Substation	54
83	6.4.2	Positioning of Buried Electrode	54
84	6.4.3	Other Earth Electrodes	55
85		6.4.3.1 Earth Rods	55
86		6.4.3.2 Earth Plates	55
87	6.5	Use of Structural Earths including Steel Piles and Rebar	56

88	6.5.1	Sheet Steel Piles.....	56
89	6.5.2	Horizontal Steel Reinforced Foundations.....	56
90	6.5.3	Vertical Steel Reinforced Concrete Columns.....	57
91	6.6	Metallic Fences	57
92	6.6.1	Independently Earthed Fences.....	57
93	6.6.2	Segregation between independently earthed fence and earthing	
94		system.....	57
95	6.6.3	Fences Bonded to the Substation Earthing System	59
96	6.6.4	Third Party Metallic Fences	60
97	6.6.5	Insulated Fence Sections.	60
98	6.6.6	Chain Link Fencing (Galvanised or Plastic Coated)	61
99	6.6.7	Coated Fence Panels	61
100	6.6.8	Electric Security Fences	61
101	6.6.9	Anti-climbing Precautions	61
102	6.7	Specific Items	61
103	6.7.1	Water Services to Substations	61
104	6.7.2	Non-current carrying metalwork	62
105	6.7.3	Items normally bonded to the main earth grid:.....	62
106	6.7.4	Items NOT normally bonded to the Earth Grid.....	62
107	6.7.5	Non-standard bonding arrangements.....	63
108	6.8	Overhead Line Terminations.....	63
109	6.8.1	Tower Terminations Adjacent to Substation	63
110	6.8.2	Steel Tower Termination with Cable Sealing Ends.....	63
111	6.8.3	Terminal Poles with Stays Adjacent to Substation Fence	63
112	6.8.4	Down drop Anchorage Arrangement with Arcing Horns.....	64
113	6.8.5	Loss of Aerial Earth Wires	64
114	6.9	HV Cable Metallic Sheath / Armour Earthing	64
115	6.9.1	Insulated (Polymeric) Sheath Cables	64
116	6.9.2	Cables Entering Substations	65
117	6.9.3	Cables Within Substations.....	65
118	6.9.4	Outdoor Cable Sealing-Ends.....	65
119	6.9.5	Use of Disconnected, Non-Insulated Sheath/Armour Cables as an	
120		Electrode	65
121	6.10	Light-current Equipment Associated with External Cabling	66
122	6.11	Metal Clad and Gas Insulated (GIS) Substations.....	66
123	6.11.1	Metal Clad Substations.....	66
124	6.11.2	Gas Insulated Switchgear (GIS).....	66
125	6.12	Fault Throwing Switches, Earth Switches and Disconnectors	67
126	6.12.1	Background.....	67
127	6.12.2	Fault Throwing Switches (Phase - Earth).....	68
128	6.12.3	Earth Switches	68
129	6.12.4	Isolators.....	68
130	6.13	Operating Handles, Mechanisms and Control Kiosks.....	68
131	6.13.1	Background.....	68

132	6.13.2	Earth Mats (Stance Earths)	68
133	6.13.3	Connection of Handles to the Earth Grid and Stance Earths	69
134	6.14	Surge Arrestors and CVTs	69
135	7	Measurements	71
136	7.1	General	71
137	7.2	Safety	71
138	7.3	Instrumentation and Equipment	71
139	7.4	Soil Resistivity Measurements	72
140	7.4.1	Objective	72
141	7.4.2	Wenner Method	72
142	7.4.3	Interpretation of Results	72
143	7.4.4	Sources of Error	72
144	7.4.5	Driven Rod Method	73
145	7.5	Earth Resistance/Impedance Measurements	73
146	7.5.1	Objective	73
147	7.5.2	Method	74
148	7.5.3	Interpretation of Results	74
149	7.5.4	Sources of Error	75
150	7.6	Comparative Method of Measuring Earth Resistance	76
151	7.6.1	Objective	76
152	7.6.2	Method	76
153	7.6.3	Interpretation of Results	77
154	7.6.4	Sources of Error	77
155	7.7	Earth Connection Resistance Measurements (Equipment Bonding Tests)	78
156	7.7.1	Objective	78
157	7.7.2	Method	78
158	7.7.3	Interpretation of Results	78
159	7.8	Earth Conductor Joint Resistance Measurements	79
160	7.8.1	Objective	79
161	7.8.2	Method	79
162	7.8.3	Interpretation of Results	79
163	7.9	Earth Potential Measurements	79
164	7.9.1	Objective	79
165	7.9.2	Method	80
166	7.9.3	Interpretation of Results	80
167	7.10	Earth Electrode Separation Test	80
168	7.10.1	Objective	80
169	7.10.2	Method	80
170	7.10.3	Interpretation of Results	80
171	7.11	Buried Earth Electrode Location	81
172	7.11.1	Objective	81
173	7.11.2	Method	81
174	8	MAINTENANCE	82
175	8.1	Introduction	82

176	8.1.1	Inspection.....	82
177	8.1.2	Maintenance and Repairs.....	82
178	8.2	Types of Inspection.....	83
179	8.2.1	Introduction.....	83
180	8.2.2	Frequent Visual Inspection.....	83
181	8.2.3	Infrequent Detailed Visual Inspection.....	83
182	8.2.4	Detailed Visual Inspection, Testing and Analysis.....	84
183	8.2.4.1	Testing.....	84
184	8.2.4.2	Selected Excavation and Examination of Buried Earth	
185		Electrode.....	85
186	8.2.4.3	Analysis and Recording of Test Results.....	85
187	8.3	Maintenance and Repair of Earthing Systems.....	86
188	8.4	Procedure for the Remaking Defective Joints or Repairing Conductor Breaks	
189		87
190	8.4.1	Introduction.....	87
191	8.4.2	Joint Repair Methods.....	87
192	8.4.3	Flexible Braids.....	87
193	9	Ground Mounted Distribution Substation Earthing.....	88
194	9.1	Introduction.....	88
195	9.2	Relocation of Pole Mounted Equipment to Ground Level.....	88
196	9.3	General design requirements.....	88
197	9.3.1	Design Data Requirements.....	89
198	9.3.2	Conductor and electrode sizing.....	89
199	9.3.3	Target resistance.....	89
200	9.3.4	EPR design limit.....	90
201	9.3.5	Calculation of EPR.....	90
202	9.3.5.1	Factors to consider:.....	90
203	9.3.5.2	Transfer Potential from source.....	91
204	9.3.6	Step/Touch Potentials at the Substation.....	91
205	9.3.7	Simplified approach.....	91
206	9.4	Network and other contributions.....	92
207	9.4.1	Additional Electrode.....	92
208	9.4.2	Parallel contributions from interconnected HV and LV networks.....	92
209	9.4.3	Ascertaining Network Contribution.....	93
210	9.4.4	Global Earthing Systems.....	93
211	9.5	Transfer Potential onto LV network.....	94
212	9.5.1	General.....	94
213	9.5.2	Touch voltage on LV system as a result of HV faults.....	94
214	9.5.3	Stress Voltage.....	94
215	9.6	Combined HV and LV earthing.....	95
216	9.7	Segregated HV and LV earthing.....	95
217	9.7.1	Separation Distance.....	95
218	9.7.2	Transfer voltage to third parties.....	96
219	9.7.3	Further Considerations.....	96

220	9.7.4	Multiple LV electrodes on segregated systems.....	97
221	9.8	Situations where HV/LV systems cannot be segregated	97
222	9.9	Practical Considerations	97
223	9.10	LV installations near High EPR sites	98
224	9.11	Supplies to/from High EPR (HPR) sites	98
225	9.11.1	Special Arrangements	99
226	10	Pole Mounted Substation and Equipment Earthing	100
227	10.1	General Comments & Assumptions.....	100
228	10.2	Pole Mounted Transformers	100
229	10.3	Electrode Configuration for Pole Mounted Equipment	101
230	10.4	HV Earth Electrode Value	102
231	10.5	Electrode Arrangement Selection Method.....	102
232	10.6	Earthed Operating Mechanisms Accessible From Ground Level	103
233	10.7	Air Break Switch Disconnecter (ABSD) with an isolated operating mechanism	
234		107
235	10.8	Surge Arresters	109
236	10.9	Cable Terminations	109
237	10.10	Operations at Earthed Equipment Locations.....	110
238	10.11	Installation	110
239	10.12	Inspection & Maintenance of Earth Installations	111
240	10.12.1	Items to Inspect.....	111
241	10.12.2	Items to Examine	111
242	10.12.3	Items to Test	111
243	11	Case studies / examples	113
244	11.1	Risk assessment – house near substation	113
245	11.2	LV Supply into HOT (HPR) site	115
246			
247			
248			

249 **Foreword**

250 This Technical Specification (TS) is published by the Energy Networks Association (ENA) and
251 comes into effect from **June, 2017**. It has been prepared under the authority of the ENA
252 Engineering Policy and Standards Manager and has been approved for publication by the ENA
253 Electricity Networks and Futures Group (ENFG). The approved abbreviated title of this
254 engineering document is “ENA TS 41-24”.

255 This Specification is to be used in conjunction with **Engineering Recommendation S34** (2017).
256 In this document account has been taken of:

- 257 (i) UK Adoption of BS EN 50522:2010 (Earthing of Power Installations Exceeding
258 1kV a.c.), in particular with reference to acceptable touch/step voltage limits
259 derived from IEC/TS 60479-1:2005 (Effects of current on human beings and
260 livestock);
- 261 (ii) changes to earthing practice as outlined in ESQC (Electrical Safety, Quality, and
262 Continuity) Regulations, 2002, in particular with regard to smaller ‘distribution’ or
263 ‘secondary’ substations. These are described in Sections 9 and 10 of this
264 specification;
- 265 (iii) the requirements for Protective Multiple Earthing systems as outlined in
266 Engineering Recommendation G12. (The relevant items concerning substation
267 earthing in EREC G12/4 have now been transferred to this document);
- 268 (iv) the increasing use of plastic sheathed cables;
- 269 (v) the differing requirements of earthing systems at various voltages and for differing
270 types of substation installation.

271

272 **1 Scope**

273 This Specification applies to fixed earthing systems for all electricity supply systems and
274 equipment earthing within EHV, HV and HV/LV substations.

275 It also applies to:

- 276 (i) terminal towers adjacent to substations and cable sealing end compounds;
- 277 (ii) pole mounted transformer or air-break switch disconnecter installations;
- 278 (iii) pole mounted reclosers with ground level control.

279 It does not apply to earthing systems for quarries and railway supply substations.

280 **2 Normative references**

281 The following referenced documents, in whole or part, are indispensable for the application of
282 this document. For dated references, only the edition cited applies. For undated references,
283 the latest edition of the referenced document (including any amendments) applies.

284 BS 7430:2011+2015 (Code of Practice for Protective Earthing of Electrical Installations)

285 ESQC (Electrical Safety, Quality, and Continuity) Regulations, 2002 (As amended)

286 BS EN 50522:2010 (Earthing of Power Installations Exceeding 1kV a.c.)

287 IEC/TS 60479-1:2005 (Effects of current on human beings and livestock). (Part 1 – General
288 Aspects)

289 IEC/TR 60479- 3 – (Effects of currents passing through the body of livestock)

290 ITU-T: Directives concerning the protection of telecommunication lines against harmful effects
291 from electric power and electrified railway lines: Volume VI: Danger, damage and disturbance
292 (2008)

293 CIGRE Working Group 23.10 Paper 151 (044) (Dec. 1993): Earthing of GIS – An Application
294 Guide

295 Other references as included in this document: ER 134, S34, BS EN 62305, IEEE 80, IEEE
296 81, BS EN 62561-2

297

298

299 **3 Definitions**

APPROVED EQUIPMENT	Equipment Approved in operational policy document for use in the appropriate circumstances.
AUXILIARY ELECTRODE	See SUPPLEMENTARY ELECTRODE
BACKUP PROTECTION	Protection set to operate following failure or slow operation of primary protection – see NORMAL PROTECTION below. For design purposes the backup protection clearance time may be taken as a fixed (worst case) clearance time appropriate to the network operator's custom and practice.
BONDING CONDUCTOR	A protective conductor providing equipotential bonding.
CROSS COUNTRY FAULT	Two or more phase-to-earth faults at separate locations and on different phases. Effectively this creates a phase-phase fault with current flowing through earth electrode and/or bonding conductors. The result can be an increased 'EARTH FAULT CURRENT' for design purposes at some locations. CROSS COUNTRY FAULTS are usually considered only if a first phase-earth fault does not automatically clear within a short period, or if significant phase voltage displacement (neutral voltage displacement) could occur. If an accurate figure is not available, a value of 85% of the double phase-to-earth fault current may be assumed.
EARTH	The conductive mass of earth whose electric potential at any point is conventionally taken as zero.
EARTH ELECTRODE	A conductor or group of conductors in intimate contact with, and providing an electrical connection to, earth.
EARTH ELECTRODE POTENTIAL	The difference in potential between the 'EARTH ELECTRODE' and a remote 'EARTH'.
EARTH ELECTRODE RESISTANCE	The resistance of an 'EARTH ELECTRODE' with respect to 'EARTH'.
EARTH ELECTRODE RESISTANCE AREA	That area of ground over which the resistance of an 'EARTH ELECTRODE' effectively exists. It is the same area of ground over which the 'EARTH ELECTRODE POTENTIAL' exists.
EARTH FAULT	A fault causing current to flow in one or more earth-return paths. Typically a single phase to earth fault, but this term may also be used to describe two phase and three phase faults involving earth.
EARTH FAULT CURRENT	The worst case steady state (symmetrical) RMS current to earth, i.e. that returning to the system neutral(s) resulting from a single phase to earth fault. This is normally calculated (initially) for the 'zero ohm' fault condition. Depending on the circumstances, the value can be modified by including 'earth resistance'. Not to be confused with 'GROUND RETURN'

current which relates to the proportion of current returning via soil.

In some situations, particularly 'CROSS COUNTRY FAULTS', a different single phase to earth fault at two separate locations can result in 'EARTH FAULT CURRENT' (as seen at the fault-point) that does not return to the system neutrals yet should still be considered at the design stage.

EARTH POTENTIAL RISE (EPR) OR GROUND POTENTIAL	The difference in potential which may exist between a point on the ground and a remote 'EARTH'. Formerly known as RoEP (Rise of Earth Potential). The term 'GPR' (Ground Potential Rise) is an alternative form, not used in this standard.
EARTHING CONDUCTOR OR EARTHING CONNECTION	A protective conductor connecting a main earth terminal of an installation to an 'EARTH ELECTRODE' or to other means of earthing.
EARTH MAT	Definition requested by WPD. Group to decide form of words, e.g.: A buried or surface laid mesh or other electrode, usually installed at the operator position close to switchgear or other plant, intended to control or limit hand-feet TOUCH POTENTIAL.
EARTHING SYSTEM	The complete interconnected assembly of 'EARTHING CONDUCTORS' and 'EARTH ELECTRODES' (including cables with uninsulated sheaths).
EHV	Extra High Voltage, typically used in UK to describe a voltage of 33kV or higher.
ELECTRODE CURRENT	The current entering the ground through the substation's electrode system under earth fault conditions. This term is generally used in the context of electrode sizing calculations and is slightly different to Ground Return Current since the ground return current may flow through alternative paths such as auxiliary electrodes etc. For design purposes the electrode current may be taken as the worst case current flowing into a substation's electrode system under foreseeable fault conditions including, where relevant, the loss of metallic return paths and/or cross country faults.
GLOBAL EARTHING SYSTEM	An earthing system of sufficiently dense interconnection such that all items are bonded together and rise in voltage together under fault conditions. No 'true earth' reference exists and therefore safety voltages are limited.
GROUND RETURN CURRENT	<p>The proportion of EARTH FAULT CURRENT returning via soil (as opposed to metallic paths such as cable sheaths or overhead earth wires)</p> <p>If there is a metallic return path for EARTH FAULT CURRENT (e.g. a cable screen or overhead earth wire), this will typically convey a large proportion of the earth fault current. The remainder will return through soil to the system neutral(s).</p>

Reduction factors for neutral current flows (multiple earthed systems) and sheath/earth wire return currents may be applied to calculate the GROUND RETURN CURRENT. The GROUND RETURN CURRENT is used in EPR calculations as it flows through the resistance formed by a substation's overall earth electrode system (and that of the wider network) and thus contributes to voltage rise of that system. Annex I of BS EN 50522 describes some methods for calculating this component. Further guidance is given in ENA **EREC S34**.

GROUND VOLTAGE PROFILE	The radial ground surface potential around an 'EARTH ELECTRODE' referenced with respect to remote 'EARTH'.
HOT / COLD SITE	<p>A HOT site is defined as one which exceeds ITU limits for EPR, typically these thresholds are 650 V (for reliable fault clearance time ≤ 0.2 seconds), or 430 V otherwise. The requirements derive from telecommunication standards relating to voltage withstand on equipment.</p> <p>Note: These thresholds have formerly been applied as design limits for EPR in some areas. The terms HOT and COLD were often applied as a convenience (on the basis that many COLD sites do achieve safe step/touch limits) but do not relate directly to safe design limits for touch and step voltages in substations. Refer to 'HIGH EPR' below.</p>
HIGH EPR / HPR	High Potential Rise resulting from an earth fault. An EPR greater than twice the permissible touch voltage limit (e.g. 466 V for 1 second faults on soil or outdoor concrete).
HV (High Voltage)	A voltage greater than 1kV and less than 33kV. Typically used to describe 6.6kV, 11kV and 20kV systems in UK.
MES (Main Earthing System)	The interconnected arrangement of earth electrode and bonds to main items of plant in a substation.
NORMAL PROTECTION OPERATION	Clearance of a fault under normal (usual) circumstances. The normal clearance time will include relay operating time and mechanical circuit breaker delays for all foreseeable faults, and may be calculated for design purposes. Alternatively a network operator may work to the 'worst case' protection clearance time applicable to the network in a given area. This time assumes that faults will be cleared by normal upstream protection and does not allow for e.g. stuck circuit breakers or other protection failures/delays. Certain parts of an earthing design should consider slower 'BACKUP PROTECTION' operation (see above) which allows for a failure of normal protection.
NETWORK OPERATOR	Owner or operator of assets. Includes DNO (Distribution Network Operator), IDNO (Independent or 'Inset' DNO) and Transmission Network Operator (TNO) as defined in the Distribution Code (DCode) or System Operator Transmission Code (STC) as appropriate.

SUPPLEMENTARY ELECTRODE	Electrode that improves the performance of an earthing system, and may increase resilience, but is not critical to the safety of the 'as designed' system.
STEP POTENTIAL	See Section 4.3.2 for definition.
STRESS VOLTAGE	Voltage difference between two segregated earthing systems, which may appear across insulators/bushings etc. or cable insulation.
TOUCH POTENTIAL	See Section 4.3.1 for definition.
TRANSFER POTENTIAL	See Section 4.3.3 for definition.
WITHSTAND VOLTAGE	The maximum STRESS VOLTAGE that can be safely permitted between items of plant or across insulation without risk of insulation breakdown or failure.

301 **4 Fundamental Requirements**

302 **4.1 Function of an earthing system**

303 Every substation shall be provided with an earthing installation designed so that in both normal
304 and abnormal conditions there is no danger to persons arising from earth potential in any place
305 to which they have legitimate access. The installation shall be able to pass the maximum
306 current from any fault point back to the system neutral whilst maintaining step, touch, and
307 transfer potentials within permissible limits (defined in Section 4.3) based on normal* protection
308 relay and circuit breaker operating times. In exceptional circumstances where the above
309 parameters may not be economically or practically kept below permissible limits a probabilistic
310 risk assessment may be carried out. Where this shows the risk to be below accepted ALARP
311 levels the level of earth potential rise mitigation may be reduced (refer to Section 5.7).

312 The earthing system shall be designed to avoid damage to equipment due to excessive
313 potential rise, potential differences within the earthing system (stress voltages), and due to
314 excessive currents flowing in auxiliary paths not intended for carrying fault current.

315 The design shall be such that the passage of fault current does not result in any thermal or
316 mechanical damage [for backup protection clearance times] or damage to insulation of
317 connected apparatus. It shall be such that protective gear, including surge protection, is able
318 to operate correctly.

319 Any exposed normally un-energised metalwork within a substation, which may be made live
320 by consequence of a system insulation failure can present a safety hazard to personnel. It is
321 a function of the station earthing system to eliminate such hazards by solidly bonding together
322 all such metalwork and to bond this to the substation earth electrode system in contact with
323 the general mass of earth. Dangerous potential differences between points legitimately
324 accessible to personnel shall be eliminated by appropriate design.

325 The earthing system shall maintain its integrity for the expected installation lifetime with due
326 allowance for corrosion and mechanical constraints.

327 The earthing system performance shall contribute to ensuring electromagnetic compatibility
328 (EMC) among electrical and electronic apparatus of the high voltage system in accordance
329 with IEC/TS 61000-5-2.

330 **4.2 Typical features of an earthing system**

331 The earthing installation requirements are met principally by providing in each substation an
332 arrangement of electrodes and earthing conductors which act as an earthing busbar. This is
333 called the 'main earth grid' or 'main earth system' (MES) and the following are connected to it:

334 (i) all equipment housing or supporting high voltage conductors within the substation
335 such as transformer and circuit breaker tanks, arcing rings and horns and metal
336 bases of insulators;

337 (ii) neutral connection of windings of transformers required for high voltage system
338 earthing. For high voltage systems the connections may be via earthing resistors
339 or other current limiting devices, as described in Section 4.4. (The neutral earthing
340 of low-voltage systems is separately considered in Section 9);

* See 'Definitions' in Section 3

- 341 (iii) earth electrodes, additional to the main earth grid which may itself function as an
342 earth electrode;
- 343 (iv) earth connections from overhead line terminal supports and the sheaths / screens
344 of underground cables;
- 345 (v) earth mats, provided as a safety measure, to reduce the potential difference
346 between points on the area of ground adjacent to manually operated plant and the
347 metalwork including handles of that plant (but see also 10.6);
- 348 (vi) 'Grading Electrodes' (intended to reduce touch voltages on equipment), which as a
349 minimum consist of a horizontal ring electrode around all items of earthed plant and
350 the equipment and bonded to it. This often must be supplemented by additional
351 grading electrodes inside the ring;
- 352 (vii) 'High Frequency Electrodes', conductors and electrodes specifically configured to
353 reduce the impedance to lightning, switching and other surges at applicable
354 locations, e.g. surge arresters, CVTs and GIS bus interfaces;
- 355 (viii) all other exposed and normally un-energised metalwork wholly inside the
356 substation perimeter fence, e.g. panels (excluding floating fence panels), kiosks,
357 lighting masts, oil tanks, etc. Conductive parts not liable to introduce a potential
358 need not be bonded (e.g. metal window frames in brick walls). Items such as
359 fences, cables and water pipes which are not wholly inside the substation are
360 separately considered in Sections 6.6 and 6.7.
- 361 (ix) Fences may be bonded to the main earth system in some situations – refer to
362 Section 6.6.

363 Substation surface materials, for example stone chippings which have a high value of
364 resistivity, are chosen to provide a measure of insulation against potential differences occurring
365 in the ground and between ground and adjacent plant. Although effective bonding significantly
366 reduces this problem the surface insulation provides added security under system fault
367 conditions. Permissible 'touch/step' voltages are higher where an insulated surface layer is
368 provided – refer to 'Safety Criteria' below.

369 **4.3 The effects of substation potential rise on persons**


370 During the passage of earth-fault current a substation earth electrode is subjected to a voltage
371 rise (Earth Potential Rise, or 'EPR', sometimes denoted as U_E). Potential gradients develop in
372 the surrounding ground area. These gradients are highest adjacent to the substation earth
373 electrode and the ground potential reduces to zero (or 'true earth potential') at some distance
374 from the substation earth electrode.

375 A person will be at risk if he/she can simultaneously contact parts at different potential; thus in
376 a well designed system the voltage differences between metallic items will be kept to safe
377 levels regardless of the voltage rise (EPR) on the system.

378 Ground potential gradients around the electrode system, if great enough, can present a hazard
379 to persons and thus effective measures to limit them must be incorporated in the design.

380 The three main design parameters relate to 'Touch', 'Step' and 'Transfer' voltages as defined
381 below. These terms are shown as U_{VT} , U_{VS} and 'A' in Figure 1.

382



383

384

Figure 1 – Showing Touch, Step, and Transfer Voltages resulting from an earth fault

385

386 4.3.1 Touch potential

387 This term describes the voltage appearing between a person's hands and feet. It arises from
388 the fact that the ground surface potential at a person's feet can be somewhat lower in value
389 than that present on the buried earth electrode (and any connected metalwork). If an earthed
390 metallic structure is accessible, a person standing on the ground 1 metre away and touching
391 the structure will be subject to the 'touch potential'. For a given substation the maximum value
392 of 'touch potential' can be up to two or three times greater than the maximum value of 'step
393 potential'. In addition, the permissible limits for step potential are usually much higher than for
394 touch potential. As a consequence, if a substation is safe against 'touch potentials', it will
395 normally be safe against 'step potentials'.

396 In some situations, the 'hand-hand' touch potential needs to be considered, for example if
397 'unbonded' parts are within 2 metres. The permissible limits for this scenario can be calculated
398 as described in IEC/TS 60479-1, using the body impedance not exceeded by 5% of the
399 population. In general, such situations should be designed out, e.g. by increasing separation
400 or introducing barriers if the systems must be electrically separate, or by bonding items
401 together. The siting of fences needs consideration in this regard.

402 4.3.2 Step potential

403 As noted above, a potential gradient in the ground is greatest immediately adjacent to the
404 substation earth electrode area. Accordingly the maximum 'step potential' at a time of
405 substation potential rise will be experienced by a person who has one foot on the ground of
406 maximum potential rise and the other foot one step towards true earth. For purposes of
407 assessment the step distance is taken as one metre. This is shown as U_{VS} in Figure 1.

408 4.3.3 Transfer potential

409 4.3.4 General

410 A metallic object having length - a fence, a pipe, a cable sheath or a cable core, for example,
411 may be located so as to bring in ('import') or carry out ('export') a potential to or from the site.

412 By such means a remote, or 'true earth' (zero) potential can be transferred into an area of high
413 potential rise (HPR) or vice-versa. For example a long wire fence tied to a (bonded) substation
414 fence could export the site EPR to the end of the wire fence, where it may pose an electric
415 shock hazard to somebody standing on soil at 'true earth' potential. Similarly, a metallic water
416 pipe (or telephone cable, or pilot cable, etc.) could 'import' a zero volt reference into a

417 substation, where local voltage differences could be dangerous. Bonding the cable or pipe to
418 the substation system might reduce local risk but could create a problem elsewhere; isolation
419 units or insulated inserts (for pipework) are typical solutions that may need to be considered.

420 The limits for permissible transfer voltage relate to shock risk (Touch and Step Voltage), and
421 equipment damage / insulation breakdown (Stress Voltage).

422 **4.3.5 Limits for LV networks**

423 Safety criteria (as defined in Section 4.4.1) apply to the voltage that may be transferred to LV
424 networks. Further information is given in Section 9.5.

425 **4.3.6 Limits for Other systems**

426 Voltages carried to pipelines, fences, and other metallic structures during HV fault conditions
427 must not exceed permissible touch and step voltage limits as defined below (Section 4.4.1).
428 In some circumstances (for example pipelines connected to gas or oil pumping or storage
429 facilities), lower limits may apply as defined in relevant standards.

430 **4.3.7 Limits for Telecommunications Equipment (HOT/COLD sites)**

431 Care must be taken to ensure that telecommunications and other systems are not adversely
432 impacted by substation or structure EPR; in general these systems must be routed so that the
433 insulation withstand is not exceeded by passing through an area of high potential rise. Where
434 the EPR on substations (or structures) exceeds certain levels, the operators of these systems
435 must be notified. Refer to ENA ER S36 for more information.

436 ITU Directives† presently prescribe limits (for induced or impressed voltages derived from HV
437 supply networks) of 430 V rms or, in the case of high security lines, 650 V rms. (High security
438 lines are those with fast acting protection which, in the majority of cases, limits the fault duration
439 to less than 200 milliseconds.) Voltages above and below these limits are termed 'HOT' and
440 'COLD' respectively, although it should be noted that these terms do not relate directly to
441 safety voltages.

442 For telecoms connections to 'HOT' sites, consultation with telecommunications provider may
443 be necessary to arrive at a solution, e.g. isolation transformers or optic fibre links to ensure the
444 telecoms system is segregated from the substation earth.

445 **4.4 Safety criteria**

446 **4.4.1 General 'permissible' design limits**

447 An effective earthing system is essential to ensure the safety of persons in, and close to
448 substations, and to minimise the risk of danger on connected systems beyond the substation
449 boundaries. The most significant hazard to humans is that sufficient current will flow through
450 the heart to cause ventricular fibrillation.

451 The basic criteria adopted in this specification for the safety of personnel are those laid down
452 in BS EN 50522, which in turn derive from IEC/TS 60479-1. In addition, ITU-T directives are
453 considered where relevant, and where their limits might be lower than BS EN 50522.

454 The relevant limits for touch and step voltages are given in Tables 1 and 2 below.

455 These use the body impedance values not exceeded by 5% of the population, and the 'C2'
456 current curve as described in National Annexe NA of BS EN 50522:2010.

† (ITU-T: Directives concerning the protection of telecommunication lines against harmful effects from electric power and electrified railway lines: Volume VI: Danger, damage and disturbance (2008))

457 In selecting the appropriate limits, the designer must consider the type of surface covering,
458 and if footwear will be worn. Within substations, it should be assumed that footwear will be
459 worn. IEC/TS 60479-1 states that these design limits are sufficiently conservative to apply to
460 all humans including children; however it is recommended that further reference be made to
461 that standard, and relevant (lower) limits adopted as necessary if a substation is in close
462 proximity to, or might otherwise impinge on high risk groups.

463

464

Table 1 – Permissible touch voltages for typical fault clearance times:

Permissible touch voltages V ^(A)		Fault clearance time, seconds																			
		0.1	.15	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1	1.1	1.2	1.3	1.4	1.5	2	3	5	≥10 ^(B)
Bare feet (with contact resistance)		521	462	407	313	231	166	128	106	92	84	80	76	73	71	69	67	63	60	58	57
Shoes on soil or outdoor concrete		2070	1808	1570	1179	837	578	420	332	281	250	233	219	209	200	193	188	173	162	156	153
Shoes on 75mm chippings		2341	2043	1773	1331	944	650	471	371	314	279	259	244	232	223	215	209	192	180	173	170
Shoes on 150mm chippings or dry ^(D) concrete		2728	2379	2064	1548	1095	753	544	428	361	321	298	280	266	255	246	239	220	205	198	194
Shoes on 100mm Asphalt		13500	11800	10200	7600	5300	3600	2500	2000	1600	1400	1370	1300	1200	1100	1100	1080	990	922	885	866

NOTE: These values are based on fibrillation limits. Immobilisation or falls/muscular contractions could occur at lower voltages. Steady state or standing voltages may require additional consideration.

A) Additional resistances apply based on footwear resistance as well as contact patch, as defined in BS EN 50522, i.e. each shoe is 4kΩ and the contact patch offers 3ρ, where ρ is the resistivity of the substrate in Ω·m. Thus for touch voltage, the series resistance offered by both feet is 2150 Ω for shoes on soil/wet concrete (effective ρ=100 Ω·m). For 75 mm chippings, each contact patch adds 1000 Ω to each foot, giving 2500 Ω (effective ρ=333 Ω·m). For 150mm chippings (and a conservative estimate for dry concrete), the total resistance is 3000 Ω (effective ρ = 670 Ω·m). Concrete resistivity typically will vary between 2,000-10,000 Ω·m (dry) and 30-100 Ω·m (saturated). For asphalt, an effective ρ =10,000 Ω·m gives 34kΩ per shoe.

B) The ≥10s column is an asymptotic value which may be applied to longer fault duration. This is a fibrillation limit only; it may be prudent to apply lower limits to longer duration faults or steady state voltages sufficient to limit body current to 'let-go' threshold values.

C) This assumes no contact resistance but does apply the 'dry' body impedance values with large contact areas. For other scenarios (e.g. salt-water wet) refer to IEC/TS 60479-1.

D) Dry assumes indoors. Outdoor concrete, or that buried in normally 'wet' areas (>0.6m) below ground level should be treated in the same way as soil.

465

466

Table 2 – Permissible step voltages for typical fault clearance times:

Permissible step voltages V ^(B)	Fault clearance time, seconds																			
	0.1	.15	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1	1.1	1.2	1.3	1.4	1.5	2	3	5	≥10 ^(C)
Bare feet (with contact resistance)	22753	19763	17077	12715	8905	6044	4290	3320	2770	2434	2249	2098	1992	1897	1823	1771	1616	1503	1442	1412
Shoes on soil or outdoor concrete	A)	A)	A)	A)	A)	A)	A)	A)	21608	19067	17571	16460	15575	14839	14267	13826	12629	11727	11250	11012
Shoes on 75mm chippings	A)	A)	A)	A)	A)	A)	A)	A)	24906	21976	20253	18971	17951	17103	16445	15936	14557	13517	12967	12692
Shoes on 150mm chippings or dry concrete	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	24083	22559	21347	20338	19555	18951	17311	16074	15420	15092
Shoes on 100mm Asphalt	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)	A)

NOTES:

1) As for touch voltage, these limits are calculated according to fibrillation thresholds. Immobilisation or falls / involuntary movements could occur at lower voltages.
 2) In general, compliance with touch voltage limits will achieve safe step voltages.

A) Limits could not be foreseeably exceeded, i.e. 25kV or greater.
 B) Additional footwear / contact resistances appear in series (rather than parallel for the hand-foot case), and are therefore 4x those in equivalent touch potential case.
 C) The >= 10s column is an asymptotic value which may be applied to longer fault duration. This is a fibrillation limit only; it may be prudent to apply lower limits to longer duration faults or steady state voltages sufficient to limit body current to 'let-go' threshold values.
 D) This assumes no contact resistance but does apply the 'dry' body impedance values. For wet or salt-water wet, scenarios refer to IEC/TS 60479-1.

467

468 The figures above give acceptable touch and step potentials as a function of fault current
469 duration. Note that touch and step voltages are normally a fraction of the total EPR, and
470 therefore if the EPR (for all foreseeable fault conditions) is below the limits above then it follows
471 that the site will be compliant. (The full design assessment procedure is given in Section 5.)

472 Permissible limits are a function of normal protection clearance times. Figure B2 of BS EN
473 50522 shows curves showing intermediate values, if required.

474 Touch and Step Voltages are sometimes collectively referred to as 'Safety Voltages' since they
475 relate directly to the safety of persons or animals.

476 Substations shall be designed so that 'Safety Voltages' are below the limits defined in Table 1
477 and Table 2 above. It will be appreciated that there are particular locations in a substation
478 where a person can be subjected to the maximum 'step' or 'touch' potential. Steep potential
479 gradients in particular can exist around individual rod electrodes or at the corner of a meshed
480 grid.

481 The presence of a surface layer of very high resistivity material provides insulation from these
482 ground potentials and greatly reduces the associated risks. Thus substations surfaced with
483 stone chippings/concrete or asphalt are inherently safer than those with grass surfacing, and
484 permissible limits are higher. These relate to the 'Additional Resistance' rows in the tables
485 above.

486 **4.4.2 Effect of electricity on animals**

487 The main focus of this document is human safety. However, horses and cattle are known to
488 be particularly susceptible to potential gradients in soil. There are no safety limits prescribed
489 for animals but technical report (IEC/TR 60479-3) provides some limited experimental data.
490 Interpretation of this data suggests that voltage gradients (e.g. around remote electrodes or
491 structures placed in fields) not exceeding 25 V/m will generally not result in animal fatality.

492 **4.4.3 Injury or shock to persons and animals outside the installation**

493 Shock risk outside an installation can be introduced by metallic transfer (fence, pipe, cable) or
494 via the soil. Where a hazardous transferred potential can occur due to metallically conductive
495 means, that eventuality should be removed by the introduction of insulation or other protective
496 measures (examples include insulated sections introduced into external metal fences). Where
497 metal fences are bonded to the substation earthing system, the touch and step potentials
498 external to them must be controlled by the design, such that they are within the acceptable
499 limits. In other words, most risks should be managed by design such that touch and step
500 voltages are below safe 'deterministic' limits defined in Table 2 above. Where HV and LV
501 earthing systems are combined, the EPR is transferred from the installation into domestic,
502 commercial or industrial properties and must be at a level that complies with the requirements
503 of section 9.5.

504 In many situations, risk to individuals may be beyond the control of the network operator, for
505 example if a building is erected close to an existing substation. In such circumstances, a risk
506 assessment should be carried out to establish the level of risk, and the justifiable spend to
507 mitigate against that risk. Acceptable voltage thresholds will be influenced by activity (e.g.
508 wet/dry), location (e.g. beach-side) and the presence of animals. The risk assessment process
509 is described further in Section 5.7.

510 **4.5 Electrical Requirements**

511 **4.5.1 Method of neutral earthing**

512 The method of neutral (or 'star point') earthing strongly influences the fault current level. The
513 earthing system shall be designed appropriate to any normal or 'alternative' neutral earthing

514 arrangements, in a similar way that it will be necessary to consider alternative running
515 arrangements that may affect fault levels or protection clearance times.

516 Note, if the system uses a tuned reactor (arc suppression coil (ASC) / Petersen coil) connected
517 between the transformer neutral and earth, the magnitude of the current in the earthing system
518 may be small due to the tuning of the ASC reactance against the capacitance to earth of the
519 unfaulted phases. However, other conditions can occur that require a higher current to be
520 considered. For instance, if the tuned reactor can be shorted out (bypassed), e.g. for
521 maintenance or protection purposes whilst the transformer is still on load, then it is necessary
522 to design for this (refer to sections 5.4.2 and 5.4.5). Furthermore, even if there is no alternative
523 method of system earthing it is still necessary to consider the possibility of a neutral bushing
524 fault on the tuned reactor effectively shorting out the tuned reactor. Such considerations also
525 apply to all impedance earthed systems if there is a foreseeable risk of the impedance 'failing'
526 and remaining out for any significant time.

527 The likelihood of phase-to-earth insulation failure is increased on ASC systems, particularly if
528 earth faults are not automatically disconnected. This is because a first earth fault will cause
529 phase displacement such that the two healthy phases will become at increased voltage relative
530 to earth (approaching line-line voltage). Consideration should be given to a 'cross-country'
531 fault where two phase-to-earth faults occur simultaneously on different phases. The current
532 can approach phase-to-phase levels if the earth resistance at each fault site is minimal or if
533 there is metallic interconnection between the sites.

534 **4.5.2 Fault Current**

535 The passage of fault current into an electrode system causes voltage rise (EPR, and
536 touch/step/transfer voltages) and heating. Both are related to the magnitude of fault current
537 flow. Section 5.4 describes the fault currents (and durations) applicable to earthing design.

538 **4.5.3 Thermal effects - general**

539 The earthing system shall be sized according to the maximum foreseeable current flow and
540 duration to prevent damage due to excessive temperature rise. For main items of plant in
541 substations (switchgear, transformers, VTs, CTs, surge arrestors, etc.), consideration needs
542 to be given to the possibility of simultaneous phase-earth faults on different items of plant,
543 which could result in phase-phase current flows through the MES. Refer also to Section 5.4.5.

544 Any current flowing into an electrode will give rise to heating at the electrode and surrounding
545 soil. If the current magnitude or duration is excessive, local soil can dry out leading to an
546 increase in the resistance of the electrode system. Section 5.5.2 defines a 'surface current
547 density' limit (in terms of Amps per m² or cm² of electrode area). In some situations, even if
548 target resistance and design EPR values are achieved, it may be necessary to increase the
549 electrode contact surface area to ensure compliance with this requirement (Section 5.4.6).

550

551 **5 Design**

552 **5.1 Design Considerations**

553 This section describes general arrangements applicable to all substations. Further discussion
554 relating to those items specific to distribution substations is included in Section 9, and pole-
555 mounted systems are further described in Section 10.

556 **5.1.1 Limiting values for EPR**

557 The design shall comply with the safety criteria (touch, step and transfer voltages) and with the
558 earthing conductor and earth electrode conductor current ratings, and will need to allow
559 sufficient current flow for reliable protection operation.

560 There is no design requirement which directly limits the overall EPR of a substation to a
561 particular value, however, the design will need to consider insulation withstand between
562 different systems, and voltage contours in surrounding soil. The need to comply with these
563 requirements, and safety limits, will naturally tend to restrict the acceptable EPR. In practice,
564 an upper EPR limit may be applied by different network operators based on equipment
565 specifications and/or proximity to third party systems.

566 **5.1.2 Touch and Step voltages**

567 Touch and Step voltages (collectively referred to as 'Safety Voltages') are the most important
568 design criteria. A substation that fails to achieve permissible touch voltage limits will not be
569 safe. Formulae for calculating touch and step voltages are presented in EREC S34.

570 **5.1.3 Factors to include in calculation of EPR and Safety Voltages**

571 For each operating voltage at a substation, two conditions of earth fault should be considered
572 to determine the maximum value of earth electrode current. In one, the earth fault is external
573 to the substation; here the current of concern is that returning to the neutral(s) of the
574 transformer(s) at the substation under consideration. The other is for an earth fault in the
575 substation; here the current of concern is now that value returning to the neutral(s) of the
576 transformer(s) external to the substation under consideration. These currents are components
577 of the system earth fault currents. If these return currents have available to them other
578 conducting paths directly connected to the earthing system of the substation, for example
579 overhead line earth-wires and cable sheaths, then the currents in these paths shall be
580 deducted from the appropriate return current to derive the value of current passing through the
581 earth electrode system of the substation. Evaluation of this 'ground-return' current component
582 is described in EREC S34. See also Section 5.4.2.

583 **5.1.4 Transfer Potential**

584 A further factor that needs to be considered is 'transfer voltage' that may arise from a fault at
585 the source substation(s), if there is a metallic connection (cable sheath or earth wire) between
586 the substation earthing systems. Methods for calculating the transferred potential are
587 described in ENA EREC S34.

588 A person at a remote location could theoretically receive the full (100%) EPR as a touch
589 potential since he/she will be in contact with 'true earth'. This may be disregarded if the EPR
590 at the source substation is known to meet the safety criteria, i.e. is within acceptable touch
591 voltage limits. However, particular care is needed if there is a possibility of hand-hand contact
592 between a transfer potential source, and other earthed metalwork. The possibility should be
593 excluded by appropriate barriers (e.g. insulated glands, enclosures) or bonding. If this cannot
594 be ensured, then lower voltage limits apply to the hand-hand shock case (refer to IEC/TS
595 60479-1).

596 **5.2 Preliminary Arrangement and Layout**

597 In order to determine fully the requirements for and adequacy of an earthing system it is
598 necessary to produce a preliminary design arrangement of that earthing system. From a site
599 layout drawing showing the location of the plant to be earthed, a preliminary design
600 arrangement of the earthing system for the substation should be prepared, incorporating the
601 relevant 'functions' of Section 4.1 and the relevant 'features' of Section 4.2. The particular
602 layout arrangement will be unique to each substation but all will have some dependence on,
603 inter alia, a combination of the factors described in Section 5.4.5, relating to fault level, fault
604 duration, electrode current and soil type.

605 **5.3 Design Guidelines**

606 This Section gives an outline of those features of earthing system arrangements which have
607 proved to be most satisfactory in practice.

608 **5.3.1 Outdoor Substations**

609 Except for pole mounted equipment, it is recommended that the earthing arrangement be
610 based on a bare 'perimeter electrode' (peripheral buried horizontal earthing electrode),
611 generally encompassing the plant items to be earthed such that the perimeter earth electrode
612 is at least 1m out from the plant items to provide touch voltage control at arm's reach. Internal
613 connections shall connect from the perimeter electrode to the items of plant. These internal
614 connections function as earthing conductor if not in contact with soil, or electrode otherwise.
615 Where reasonably practicable, the amount run above the surface shall be minimized to deter
616 theft. In addition, discrete earth electrodes, e.g. rods or plates, may be connected to this
617 perimeter electrode. These may variously be employed to reduce the surface current and/or
618 the electrode resistance of the overall earth electrode system. The overall electrode system is
619 termed the Main Earthing System (MES).

620 The electrode system may be augmented with inter-connected, buried, bare cross-connections
621 to form a grid. Such cross-connections increase the quantity of earth electrode conductor and
622 mesh density of the grid, reduce touch voltages on plant within the grid, and provide local main
623 conductors to keep equipment connections short; in addition they increase security/resilience
624 of connections by introducing multiple paths for fault current, which is an important
625 consideration.

626 In all substations it is recommended that duplicate connections are made from the Main
627 Earthing System (MES) to main items of plant, in order to increase resilience (refer to Section
628 5.4.5 for conductor sizing).

629 Where regular contact of an operator with an earthed structure is anticipated, e.g. at a switch
630 handle, the earthing system shall be enhanced by providing an earth mat (or, if a mat poses
631 difficulties, appropriate grading electrode) at or just below the surface of the ground and
632 bonded to the metalwork, so arranged that the metalwork can only be touched while standing
633 above the mat (or enhanced area).

634 Pole-mounted equipment presents a particularly difficult ground potential gradient problem and
635 the special precautions noted in Section 10 shall be observed. It may be necessary to apply
636 these precautions in some ground-mounted substations.

637 Fault current flowing through an earth electrode system to ground uses the outer extremities
638 of the electrode system to a greater extent than the inner parts of the system. Thus, adding
639 more earth electrode, whether as vertical rods or as horizontal tape, to the inner area of a small
640 loop or well integrated grid electrode system, will have little impact in reducing earth resistance
641 or the current density in the outer electrode conductors of the system (however this can help
642 to control step/touch potentials around specific items of plant).

643 Such reductions (in overall earth resistance) as may be desirable are best achieved by
644 extending the electrode system to cover a greater area of ground (e.g. by buried 'radial'
645 electrodes), or by driving rods around the periphery of the system or by a combination of both.

646 The vertical rod electrode is most effective for use in small area substations or when low soil
647 resistivity strata, into which the rod can penetrate, lies beneath a layer of high soil resistivity.
648 Rods are least effective where there is a high resistivity layer beneath one of lower resistivity,
649 e.g. where underlying bedrock is near to the surface. In these locations extended horizontal
650 electrodes in the low resistivity surface layer are more effective.

651 For large area substations employing a grid electrode system, the addition of vertical rods,
652 even when optimally installed around the periphery of the system, may make only a marginal
653 improvement.

654 **5.3.2 Indoor Substations**

655 The plant of indoor substations will normally be erected on a concrete raft, often containing a
656 steel reinforcing mesh (re-bar). To control touch and step potentials around plant, it is common
657 for re-bar to be bonded to the main earthing system, or for a dedicated 'grading mesh' (usually
658 consisting of prefabricated steel or copper mesh) to be buried in concrete screed in the
659 substation area. These measures are to control potential gradients and are not intended to
660 act as an 'electrode' (they may be employed for example above basement areas); dedicated
661 electrodes will also be required to provide a connection to the mass of earth and achieve the
662 functional requirements. For new substation buildings a buried peripheral horizontal electrode
663 may be conveniently installed around the building foundation and supplemented with vertical
664 rod electrodes as required. Coordination with the civil engineering design can result in a cost-
665 effective installation.

666 Where reinforcing mesh in concrete is to function as supplementary earth electrode, it must be
667 designed to carry the current without cracking the concrete, be constructed with mesh panels
668 welded together and be welded to the peripheral buried earth electrode at suitable intervals
669 (e.g. 5 m).

670 The provision of a buried main earth bonding conductor within the confines of an existing
671 building is often impractical and thus a surface mounted main earthing conductor loop, is
672 normally installed with surface run (and duplicate) spur connections to the various items of
673 plant. The earth electrode system employed with this arrangement may differ depending on
674 the magnitude of earth fault current that the electrode system is required to carry. Marshalling
675 earth bars are sometimes used in addition to, or instead of, a surface laid loop, and (if properly
676 labelled) can facilitate measurement/maintenance. The convenience of such an arrangement
677 often brings with it a high reliance on bolted connections and so the 'resilience' aspect needs
678 to be balanced with convenience.

679 Substations in buildings may require a buried loop/ring electrode outside the building if any
680 extraneous metalwork (e.g. metal cladding, steel joists, handrails, communications antennae
681 etc.) is bonded to the substation earthing system and could otherwise present a touch potential
682 issue to those outside the building. The same considerations apply where a substation is
683 installed in an existing building (for example in the basement of a tower block), even if the
684 building is not recognisable as a 'substation building'; in fact risks associated with members of
685 the public will often be higher in such installations and warrant additional consideration.

686 Electrode systems (rod nests, etc.) should not be sited close to main access/egress routes
687 without consideration of step and touch voltage in these areas.

688 Grading electrode (where required) should be positioned 1 m from metal-clad buildings, and
689 bonded to the building's internal HV or EHV earthing system at two or more separate points.

690 If the building is to be provided with a lightning protection system that will be bonded to the
691 main earthing system, the LPS electrodes may contribute to potential grading. Calculations
692 and/or computer modelling will normally be necessary to demonstrate whether such measures
693 can be used in place of dedicated grading electrodes.

694 Sparsely positioned rods (e.g. associated with a lightning protection system to BS EN / IEC
695 62305-1) may serve this function if compliance can be demonstrated at the design stage.

696 A lightning protection electrode system if purposely designed with regard to power system fault
697 currents and with closely spaced rods (or interconnecting electrode ring), could serve the dual
698 purpose of lightning protection and potential grading. Care is needed to ensure that such a
699 system cannot be disconnected from the building, e.g. by removal of test links.

700 Conversely, any earthing system designed for power system fault current may be used for
701 lightning protection system if compliant with BS EN / IEC 62305-1, particularly with regard to
702 high frequency components and down-conductor routing (free of tight bends etc.)

703 **5.3.3 Shared Sites**

704 Where the customer operates HV (and/or EHV) switchgear, there will be a natural boundary
705 between Network Operator's ownership, and customer ownership. Ideally the Network
706 Operator should not rely on the customer's earthing system to ensure electrical safety around
707 the Network Operator's assets, unless maintenance agreements can be made. In practice, the
708 systems may need to be connected together, but each system should (where reasonably
709 practicable) be designed to be safe (touch voltages) in the absence of any (electrode)
710 contribution from the other system.

711 Neither party should rely on the other's earthing system unless regular maintenance/testing of
712 both systems can be assured.

713 **5.3.4 Distribution (or 'Secondary') Substations**

714 Distribution (HV:LV) substation earthing is particularly important given that LV system
715 neutral/earth conductors may be connected to, or close to HV earthing systems and
716 consequently could export 'transfer potential' to customer installations. Specific examples for
717 ground mounted substations are given in Section 9, and pole mounted equipment is covered
718 in Section 10.

719 **5.3.5 Metallic Fences**

720 Substation fences are typically either a) Bonded to the MES, or b) Separately earthed. In
721 general, a bonded design will be required if 2m separation (or barriers/effective insulation)
722 cannot be established to prevent simultaneous contact (hand-hand) between the systems. A
723 separately earthed system is preferable otherwise to minimise the EPR (and resulting touch
724 voltage) that may be accessible externally.

725 In the case of bonded fences, consideration must be given to touch voltages that appear on
726 the fence under fault conditions; an external peripheral electrode may be required 1m around
727 the outside of the fence to achieve acceptable levels. Care must also be taken to ensure that
728 voltage rise is not 'exported' via third party fences etc. that may be in contact with the fence.

729 Refer to Section 6.6 for more details.

730 **5.3.6 Provision of Maintenance/Test facilities**

731 Facilities for Monitoring Earth System Efficiency (described in Section 6.2.5) should be
732 included at the design stage. Refer to Section 7.5 for information on earth resistance
733 measurements.

734 Test points (e.g. for clamp meter testing) should be shown on earthing drawings.

735 **5.4 Design data**

736 The final design of the earthing system can only be undertaken when sufficient knowledge is
737 available of the proposed physical and electrical arrangements of the substation.

738 As a minimum, the designer must have knowledge of:

- 739 1) value of fault current **and supply arrangements (overhead and/or underground cable)**
- 740 2) fault duration (or protection settings)
- 741 3) soil resistivity
- 742 4) substation dimensions

743 Any special features about the site, such as subsoil of a corrosive nature and the suitability of
744 the site for driven earth rods or other forms of electrode, must be ascertained. Other relevant
745 features, such as existing earth electrodes, nearby earthed structures, buried pipes or piled
746 foundations are also required to be noted and taken into consideration.

747 In urban areas in particular the substation may be served by an underground cable network
748 which (particularly if incorporating non-insulated sheaths/armours) will make a 'contribution'
749 which may be taken into consideration. Refer to Section 9.4.3 for details on the contribution
750 from typical 11kV networks.

751 **5.4.1 Soil Resistivity**

752 The value of the specific resistivity of the soil may be ascertained by reference to published
753 data or by direct measurement. Table 3 (below) sets out typical values relating to types of soil
754 but these should be used for very preliminary assessments only.

755 [Nationally available soil survey data can also be used for this purpose, e.g.

756 <http://mapapps.bgs.ac.uk/geologyofbritain/home.html>].

757

Table 3 - Typical soil resistivity values

758

Resistivity in $\Omega \cdot m$

SOIL	RESISTIVITY ($\Omega \cdot m$)
Loams, garden soils, etc	5 – 50
Clays	10 – 100
Chalk	30 – 100
Clay, sand and gravel mixture	40 – 250
Marsh, peat	150 – 300
Sand	250 – 500
Slates and slaty shales	300 – 3,000
Rock	1,000 – 10,000

759

760 Multi-layer soil models and computer modelling may offer more effective / optimal designs than
761 typical or 'homogeneous' soil models. Except for some smaller substations, (where the
762 additional expense may not be warranted), direct measurement will normally be necessary
763 prior to detailed design. The recommended method, using the Wenner Array, is described in
764 Section 7.4.

765 It should be noted that the top layers of soil may be subject to significant seasonal variation
766 due to fluctuating moisture content. Designs should utilise deeper more 'stable' strata wherever
767 possible; the depth of this 'stable' layer is variable depending on soil type and weather/climate.

768 **5.4.2 Fault currents and durations - general**

769 The earthing system must remain intact, and safety voltages must be acceptable for all
770 foreseeable fault conditions. BS EN 50522 describes the need to consider single phase to
771 earth, two phase, and three phase to earth fault current flows, as well as 'cross country' faults
772 in some situations.

773 The relevant currents for earthing design are summarised in Table 4 below, and described in
774 detail in the following sections.

775

776

777 Table 4 – Relevant currents for earthing design purposes

Type of System Earth Supplying Fault	Relevant for EPR and Safety Voltages	Relevant for thermal effects	
		Earth Electrode	Earthing Conductor
Solid Earthing	If known, and if earth-return paths are known to be reliable and rated for duty: Ground return current should be used.	Maximum foreseeable electrode current . This should be taken as the ground return current or value between ground return current and earth fault current , taking into account the loss of any metallic return paths (cable sheath or overhead earth wire) where relevant. See sections 5.4.6 and 5.5.2	Earth fault currents for all voltage levels at the substation. Three phase (or phase-to-phase) faults should be considered if phase-to-phase fault current can flow through earthing conductors (e.g. separately earthed items of plant, particularly single phase equipment). See section 5.4.5.
Impedance Earthing	Otherwise: Earth fault current should be used. See Section 5.4.3		
Arc Suppression Coil (ASC or Petersen Coil)	ASCs are generally used in addition to solid or impedance earthing. It is therefore usually appropriate to design to the alternative solid or impedance arrangement (as above) which is termed the 'bypass' arrangement. In addition, cross-country faults should be considered if they are likely to be more onerous in terms of magnitude and/or duration. Steady state currents (i.e. the maximum current that can flow in the earthing system without protection operation) may impose additional requirements on the designer.		
	Refer to Section 5.4.3	See section 5.4.6.	See Section 5.4.5
Notes: Fault currents associated with all voltages levels in substations must be considered. The appropriate protection clearance times for each voltage level must be applied – refer to Section 5.4.2			

778

779 Refer to Table 1 in BS EN 50522 for further details.

780

781 **5.4.3 Fault current growth**

782 Consideration should be given to future network alterations and alternative running
783 arrangements. A margin should be added to allow for future changes without detailed
784 assessment (e.g. typical 20% increase, unless more accurate information is available).

785 If fault levels are expected to approach the switchgear rating in the foreseeable future, the
786 **switchgear rating should be used as the design figure**. In any case the rating of the
787 earthing system should be reviewed if plant is to be upgraded such that higher fault levels may
788 be possible.

789 **5.4.4 Fault currents for EPR and safety voltage calculations**

790 The fault current applicable to EPR calculation (and therefore safety voltage calculations) is
791 the maximum (symmetrical RMS) current to earth (**earth-fault current**) that the installation will
792 see under fault conditions.

793 **Normal operating time** of protection relays and breakers should be used for safety voltage
794 calculations, rather than worst-case (back-up) protection clearance times.

795 Cable sheath or earth wire return paths should be included if they are reliable and rated for
796 duty, in which case the resultant (smaller) **Ground Return Current** may be used for design
797 purposes, since it is this current (or a fraction of it) that flows into the local electrode system
798 and gives rise to EPR. Designs should consider touch voltage that may result under various
799 failure scenarios and for all voltage levels at a substation.

800 If specific protection settings are not available, the design should use 'upper bound' (slowest)
801 clearance times associated with normal protection operation, as specified by the network
802 operator.

803 These considerations apply whether the source substation (i.e. that supplying the fault) is
804 impedance or solidly earthed. EPR should be calculated for all voltage levels at any substation,
805 for faults at the substation and on circuits fed from it. LV faults can usually be shown to be
806 insignificant in this regard.

807 For substations with Arc Suppression Coils (ASCs), the design should be based on the most
808 onerous (in terms of magnitude and/or duration) earth-fault or cross-country fault. In addition,
809 the design should consider long duration EPR conditions which may give rise to near 'steady
810 state' voltages on equipment or fences etc.

811 Note: In many cases the 'solid' earth fault level is an appropriate design figure for safety voltage assessment on
812 ASC systems, since this is likely to represent a realistic upper-bound. The need to consider alternative fault
813 scenarios / currents is subject to operational experience / risk assessment.

814

815 **5.4.5 Fault currents and clearance times for conductor size (thermal effects)**

816 Conductor sizing calculations should be based on **backup** protection clearance time, i.e. the
817 design shall allow for failure of primary protection without damage to the earthing system. In
818 the absence of network specific data, the following operating times should be assumed:

819 Up to and including 132 kV: 3 seconds (excluding LV)

820 275 kV and higher voltages: 1 second

821 For earthing conductors and electrodes in substations it is recommended that the design fault-
822 current should be the maximum symmetrical three-phase fault current value, or other worst
823 case foreseeable value if greater.

824 NOTE: The decision of whether to include the 'missing return path' scenario is largely dependent on operational
825 experience and risk assessment. For example, the likelihood of complete failure of the metallic return path will be
826 higher for a single overhead earth wire than it would be for a triplex (3 x bunched single cores) cable network
827 arranged in a ring.

828 The maximum fault current applies wherever this may be borne by one spur connection, in
829 which case that spur shall be sized accordingly. In grid (mesh) earthing designs there will
830 often be parallel paths to share the current; if the current is to flow in two or more paths (e.g.
831 around a ring) then each individual path shall be sized to no less than 60% of the fault current.

832 Installations connected to, or part of the one where the highest fault current occurs, may only
833 be required to carry a portion of that current and the earth conductors may be sized
834 accordingly. For example, in lower voltage areas peripheral to a higher voltage one, their earth
835 conductors must be sized to meet the lower voltage fault current and calculations may show
836 that they are also adequate for their proportion of the HV or EHV fault current.

837 Conductor ratings are given in Section 5.5.1.

838 **5.4.6 Fault currents and times for electrode size calculations (thermal effects)**

839 The discrete earth electrode shall at all times retain its functional properties, i.e. both its current
840 carrying capability and its value of resistance to earth. For these reasons the temperature rise
841 of the electrode conductor and the density of current dissipation from electrode to soil, during
842 the passage of fault current through it, shall be limited.

843 Electrodes are thus subject to thermal requirements of the electrode material due to passage
844 of fault current, and current limits imposed by the electrode-to-soil interface as described
845 below:

846 a) 'Conductor Thermal requirements' are satisfied by appropriate choice of material and
847 cross sectional area for each electrode and its connection to the main earthing system
848 (Section 5.5.1).

849 b) 'Surface Current Density' requirements are satisfied by ensuring sufficient electrode
850 surface area. In some cases it will be necessary to install additional electrode(s) to
851 satisfy this requirement, particularly if the electrode resistance requirements can be
852 met with a relatively small electrode system.

853 Further detail – surface current density

854 The soil surrounding earth electrodes is of a much higher sensitivity than the electrode
855 conductor material and thus the passage of current through the soil will develop, relatively, a
856 much higher temperature rise. The effect of high temperature in the soil causes drying of the
857 surrounding soil, thus further increasing its resistivity, or even the production of steam which
858 can force a separation between the electrode conductor and its interfacing soil.

859 For this reason the current rating of an earth electrode is specified in terms of its surface current
860 density (A/mm^2), and is dependent on soil resistivity. As a consequence the current rating of
861 buried electrodes in practical installations is very much less than equivalent sized above-
862 ground earthing conductors (Section 5.5.2 gives typical ratings).

863 Where a multi-mesh buried main earth grid is installed, the density of fault current in the earth
864 electrode should rapidly reduce as the distance from the point of fault increases. Provided,
865 therefore, that a sufficient quantity of grid conductor is buried and is well distributed, the surface
866 current density will generally be satisfactory and high surface temperature restricted to a small
867 area close to the fault point and thus have negligible effect on the value of total earth electrode
868 resistance or on the efficacy of the earthing system as a whole.

869 Design fault currents and clearance times for electrode ratings

870 The surface area of the main electrode through which the fault current flows to ground shall,
871 as a minimum, be sufficient to disperse the maximum foreseeable **electrode current** (i.e. the
872 total current flowing into the electrode system).

873 The **ground return current** (or **earth fault current**) should be used in calculations if the
874 electrode current(s) are not known. Higher values may be appropriate for ASC systems, as
875 described below.

876 NOTE 1: The maximum current flow into individual electrode groups (where there is more than one) should be
877 assumed to be 60% of the ultimate overall figure used above.

878 NOTE 2: Reduction factors for neutral current flows (multiple earthed systems) and sheath/earth wire return
879 currents may be applied in the normal way to calculate ground return current or electrode current.

880 NOTE 3: Faults at all voltage levels in each substation shall be considered.

881

882 The possibility of sheath failure or aerial earth wire failure can give rise to higher than normal
883 ground return current (and consequent electrode current) and should be considered where
884 necessary, as described in the previous section.

885 For ASC systems*, the **electrode current** calculation must consider **cross-country** faults
886 since these are more likely on ASC systems. The electrode current in such circumstances can
887 sometimes exceed the normal calculated **ground return current**. **Solid earth-fault** level or
888 **phase-to-phase** fault levels should be used if there is any doubt, even if the 'bypass' is via
889 resistor or reactor. The value to be used is subject to risk assessment and operational
890 experience.

891 * NOTE: This is particularly relevant where earth faults are not automatically disconnected within 3 seconds.

892 The relevant clearance times are for **backup** protection operation as described in the previous
893 section, since it is imperative that the earthing system remains intact if faults are slow to clear.

894 Long term (steady state) current flows can cause drying of soil, and must be considered in
895 addition to normal faults (see below).

896 Relatively rare faults (e.g. bushing failures or internal faults) which may cause an ASC or
897 impedance to be shorted out should be considered if necessary, based on operational
898 experience.

899 Long term current flows

900 If significant ground-return current can flow for prolonged duration (i.e. without protection
901 operation), the effect of this current should be considered separately; it can lead to drying at
902 the electrode-soil interface and impose a steady state (or 'standing voltage') on plant which
903 can require additional measures to ensure safety. This is relevant for ASC systems where
904 earth faults are not automatically disconnected, or where moderate current can return via earth
905 to the system neutral in normal circumstances due to un-balanced network capacitance or
906 leakage. The magnitude of this current should be taken as the ASC coil rating or earth-fault
907 protection relay current settings.

908 NOTE: A maximum surface current density of 40 A/m² is appropriate for long term current flows. This is unlikely to
909 cause drying at the electrode-soil interface.

910

911 Surface area and current density requirements

912 In many cases the electrode surface area requirement is satisfied by normal design practice
913 based on achieving a satisfactorily low earth resistance value; care is needed for systems
914 where a small electrode system is otherwise thought to be sufficient.

915 The appropriate fault current, as described above, should be divided by the surface area of the
916 electrode system (as described in EREC S34 section XXX) to demonstrate that the current
917 density at the electrode-soil interface is within limits given in Section 5.5.2.

918 It is permitted to use the surface area of all connected electrodes (main and auxiliary) in this
919 calculation. However, it is good design practice, wherever possible, to ensure that sufficient
920 main electrode meets this requirement.

921 NOTE: In situations such as substations in urban areas where the overall Ground Return Current is significantly
922 increased by interconnection to a larger network or other auxiliary electrode system, dividing this **overall ground**
923 **return current** (returning via a wide area electrode system, shown as I_E in EREC S34 Figure 3.2) into the **local**
924 electrode surface area will provide a safety margin. It is permissible, for design economy, to calculate the local
925 electrode current (i.e. by evaluation of the ground return current 'split' between the local electrode system and other
926 paths, shown as I_{ES} in S34 Fig 3.2), and dividing this resultant electrode current into the local electrode area. This
927 approach should be used with caution, or combined with the risk assessment approach outlined in Section 5.7 as

928 failure of auxiliary electrode connections etc. could result in overheating/failure of the local electrode system under
929 fault conditions.

930

931 Limiting values of surface current rating, calculated for some typical electrodes are given in
932 Table 8 below (section 5.5.2).

933 **5.5 Conductor and Electrode Ratings**

934 The earthing system must remain intact following a protection failure as described in section
935 5.4.5.

936 **5.5.1 Earthing Conductors and Electrodes**

937 Earthing conductors should normally be selected from standard copper or aluminium sections;
938 this does not exclude the use of other materials if longevity and resilience (especially to
939 corrosion) can be demonstrated. For alkaline or acidic soils (i.e. those where the pH is greater
940 than 10 or less than 4), or in other situations where corrosion is likely, it may be necessary to
941 oversize electrodes, or to apply other measures to give a reasonable lifetime. Refer to BS 7430
942 for further details.

943 Based on maximum fault clearance times, the conductor temperature should not exceed 405°C
944 for copper and 325°C for aluminium based on an initial temperature of 30°C. A lower limit of
945 250°C (absolute) is relevant for bolted connections, since extreme thermal cycling can lead to
946 loosening over time.

947 Table 5 and Table 6 below give declared current ratings for a range of standard conductor
948 sizes for both 1 second and 3 second fault duration times. **The short time rating of other
949 conductors can be calculated from formulae given in EREC S34.**

950

951

Table 5 - CONDUCTOR RATINGS (COPPER)

952

(a) 405°C maximum temperature (Copper)

These copper sizes are based on a temperature rise of 375°C occurring in 3 seconds and 1 second above an ambient temperature of 30°C (i.e. achieving a maximum temperature of 405°C) with the currents in columns (a) and (b) respectively applied to the conductors. For each substation it will be necessary to specify whether column (a) or (b) should apply.					
Fault Current (kA) Not Exceeding		Copper Strip (mm)		Stranded Copper Conductor	
(a)	(b)				
(3 secs)	(1 sec)	Single (spur) Connections	Duplicate or Loop Connections	Single (spur) Connections	Duplicate or Loop Connections
4		25 x 4	25 x 4	70mm ²	70mm ²
8		25 x 4	25 x 4	70mm ²	70mm ²
12		25 x 4	25 x 4	95mm ²	70mm ²
13.2		31.5 x 4	25 x 4	120mm ²	70mm ²
18.5		40 x 4	25 x 4	150mm ²	95mm ²
22		50 x 4	31.5 x 4		120mm ²
26.8		40 x 6.3	40 x 4		150mm ²
40		-	50 x 4		
	40	50 x 4	31.5 x 4		
	60	50 x 6.3	50 x 4		
	63				
NOTE: Equivalent sizes for stranded conductor include, but are not limited to the following, quoted as number of strands/strand diameter: 70mm ² =19/2.14mm or 7/3.55mm(e.g. HDC); 95mm ² = 37/1.78mm; 120mm ² =37/2.03mm; 150mm ² =37/2.25mm. Consideration of corrosion risk may lead to the decision to specify minimum strand diameters (e.g. 1.7mm or larger as per BS EN 50164-2). A minimum strand diameter of 3mm is preferred by some DNOs for longevity of the electrode system particularly if corrosive soils exist.					

953

954

955

956

(b) 250°C maximum temperature (Copper) – bolted connections

These copper sizes are based on a temperature rise not exceeding 250°C , from an ambient temperature of 30°C with the currents in columns (a) and (b) respectively applied to the conductors. For each substation it will be necessary to specify whether column (a) or (b) should apply. These figures are generally applicable to bolted connections between tapes or lugs etc. which offer a relatively small thermal mass.					
Fault Current (kA) Not Exceeding		Copper Strip (mm)		Stranded Copper Conductor	
(a)	(b)				
(3 secs)	(1 sec)	Single (spur) Connections	Duplicate or Loop Connections	Single (spur) Connections	Duplicate or Loop Connections
4		25 x 4		70mm ²	70mm ²
8		25 x 4		95mm ²	70mm ²
12		25 x 6		120mm ²	95mm ²
13.2		25 x 6		150mm ²	95mm ²
18.5		38 x 5		185mm ²	120mm ²
22		40 x 6			150mm ²
26.8		50 x 6			185mm ²
40		-	40 x 6		
	40	40 x 6	50 x 3		
	60	-	50 x 6		
	63	-	50 x 6		
NOTE: Equivalent sizes for stranded conductor include, but are not limited to the following, quoted as number of strands/strand diameter: 70mm ² =19/2.14mm or 7/3.55mm(e.g. HDC); 95mm ² = 37/1.78mm; 120mm ² =37/2.03mm; 150mm ² =37/2.25mm. Consideration of corrosion risk may lead to the decision to specify minimum strand diameters (e.g. 1.7mm or larger as per BS EN 50164-2). A minimum strand diameter of 3mm is preferred by some DNOs for longevity of the electrode system particularly if corrosive soils exist.					

957

958

959

960

Table 6 - CONDUCTOR RATINGS (ALUMINIUM)

961

(a) 325°C maximum temperature (Aluminium)

<p>These aluminium sizes are based on a temperature rise of 295°C occurring in 3 seconds and 1 second above an ambient temperature of 30°C with the currents in columns 1(a) and 1(b) respectively applied to the conductors. For each substation it will be necessary to specify whether column 1(a) and 1(b) should apply.</p>					
Fault Current (kA) Not Exceeding		Aluminium Strip (mm)		Stranded Aluminium Conductor (mm)	
(a)	(b)				
(3 secs)	(1 sec)	Single (spur) Connections	* Duplicate or Loop Connections	Single (spur) Connections	Duplicate or Loop Connections
4		20 x 4	20 x 2.5	70mm ²	70mm ²
7.5		25 x 4	20 x 4	120mm ²	70mm ²
12		40 x 4	25 x 4		120mm ²
13.2		50 x 4	25 x 4		120mm ²
18.5		40 x 6	40 x 4		150mm ²
22		50 x 6	50 x 4		
26.8		60 x 6	40 x 6		
40		60 x 6	50 x 6		
	40	50 x 6	50 x 4		
	60	80 x 6	50 x 6		
<p>NOTE: Equivalent sizes for stranded conductor include, but are not limited to the following, quoted as number of strands/strand diameter: 70mm²=19/2.14mm or 7/3.55mm; 95mm²= 37/1.78mm; 120mm²=37/2.03mm; 150mm²=37/2.25mm.</p>					

962

963

964

965

966

967

(b) 250°C maximum temperature (Aluminium) – bolted connections

<p>These aluminium sizes are based on a temperature rise not exceeding 250°C in 3 seconds and 1 second from an ambient (initial) temperature of 30°C with the currents in columns 1(a) and 1(b) respectively applied to the conductors. For each substation it will be necessary to specify whether column 1(a) and 1(b) should apply. These figures are generally applicable to bolted connections between tapes or lugs etc. which offer a relatively small thermal mass.</p>					
Fault Current (kA) Not Exceeding		Aluminium Strip (mm)		Stranded Aluminium Conductor (mm)	
(a)	(b)				
(3 secs)	(1 sec)	Single (spur) Connections	* Duplicate or Loop Connections	Single (spur) Connections	Duplicate or Loop Connections
4		20 x 4	20 x 2.5	70mm ²	70mm ²
7.5		25 x 5	25 x 3	120mm ²	70mm ²
12		50 x 4	25 x 5	185mm ²	120mm ²
13.2		50 x 4	25 x 5		120mm ²
18.5		50 x 6	50 x 4		185mm ²
22		60 x 6	50 x 4		
26.8		-	40 x 6		
40		-	60 x 6		
	40	60 x 6	40 x 6		
	60	-	60 x 6		
<p>NOTE: Equivalent sizes for stranded conductor include, but are not limited to the following, quoted as number of strands/strand diameter: 70mm²=19/2.14mm or 7/3.55mm; 95mm²= 37/1.78mm; 120mm²=37/2.03mm; 150mm²=37/2.25mm. Duplicate or loop connections have been rated to carry 60 per cent of the full fault current.</p>					

968

969

970

Table 7 - Cross sectional areas for steel structures carrying fault current

These sizes are based on the maximum temperature achieved after the passage of fault current for 3 seconds and 1 second from an ambient (initial) temperature of 30°C. For each substation it will be necessary to specify whether column 1(a) or 1(b) should apply.			
Fault Current (kA) Not Exceeding		250°C (applicable to bolted structures)	400°C (applicable to welded/continuous structures which are galvanised)
(a)	(b)		
(3 secs)	(1 sec)	mm ²	mm ²
4		109	91
7.5		204	171
12		327	273
13.2		359	301
18.5		503	421
22		599	501
26.8		729	610
40		1087	910
	40	628	525
	60	942	789

971

972

973

974 **5.5.2 Electrode Surface Current Density Ratings**

975 Table 8 below shows the current rating of typical electrodes. The limiting factor tends to be
976 heating at the electrode-soil interface, consequently the ratings are dependent on soil
977 resistivity.

978

979 **Table 8 - MAXIMUM CURRENT RATING OF TYPICAL ROD, TAPE AND PLATE ELECTRODES**

Soil Resistivity $\Omega \cdot m$	3 - Second Current Rating				1 - Second Current Rating			
	Rod 16mm Dia. A (per metre length)	Plate 915 x 915mm A	Plate 1220 x 1220mm A	25 x 4 mm tape	Rod 16mm Dia. A (per metre length)	Plate 915 x 915mm A	Plate 1220 x 1220mm A	25 x 4 mm tape
10	69.7	2322	3135	80.3	120.7	4022	6979	138.9
30	40.2	1340	2217	46.4	69.7	2322	4128	80.3
40	34.9	1161	1568	40.1	60.4	2011	3575	69.3
50	31.2	1038	1402	35.9	54	1799	3197	61.7
60	28.4	948	1280	32.7	49.3	1642	2919	56.8
70	26.3	878	1185	30.3	45.6	1520	2702	52.6
80	24.6	821	1108	28.3	42.7	1422	2528	49.2
100	22	734	991	25.4	38.2	1272	2261	44
150	18	600	810	20.7	31.2	1038	1846	35.9
200	15.6	519	701	17.9	27	899	1599	31.2
250	13.9	464	627	16	24.1	804	1430	27.8
300	12.7	424	572	14.6	22	734	1305	25.4

980

981 In most practical installations the actual values of surface current density will be considerably
982 less than the above limiting values, due to the quantity of bare buried conductor (electrode)
983 employed in the installation to provide effective bonding and in some installations where extra
984 electrodes have been added, to comply with the touch potential limits. Further detail is given
985 in EREC S34 – Equation to go in S34 and to be referenced from here; note that this current
986 density limit is independent on electrode material, and therefore the limits can be applied to
987 rebar/piling/other ‘fortuitous’ or auxiliary electrodes, providing that temperature rise in these
988 structures under fault conditions will not cause issues such as cracking/distortion etc.

989 Where an electrode is encased in a material such as concrete, or material/agent other than
990 surrounding soil, the surface area calculation should be carried out at the electrode-material
991 interface, using the surface area of the metallic electrode itself and the properties of the 'agent'.
992 In some cases it will also be necessary to carry out a similar calculation at the interface of the
993 'agent' with surrounding soil, noting that the larger surface area offered by the agent will apply.

994 A well designed earthing system should provide sufficient surface area to satisfy this
995 requirement without reliance on rebar or other fortuitous / auxiliary electrodes.

996 **5.6 Design Assessment**


997 The assessment procedure outlined in 5.6.1 begins with an approximation which, if furnishing
998 satisfactory results, avoids the need for a more detailed assessment. If the results of this
999 approximate assessment indicate that the safety criteria could be exceeded or the rise of earth
1000 potential is considered to be excessive, then the more refined assessment should be
1001 employed.

1002 When an entirely theoretical approach is used for assessing the design of an earthing system,
1003 doubts on the reliability of the result may arise due to uncertainties as to the correct value of
1004 soil resistivity to be used or of the effects that other buried structures may have. In these
1005 circumstances recourse may have to be had to direct measurement to obtain a more reliable
1006 result.

1007 Recommended methods of measurement are given in Section 7.5. On the basis that the earth
1008 electrode system will not yet be installed, measurement may be made on representative test
1009 electrodes and the results extrapolated to the intended final design. Measurement may be
1010 delayed until a sufficiently representative part of the intended system is installed to obtain a
1011 better prediction of any improvements necessary. In any event a final check measurement of
1012 the completed installation is recommended prior to energisation.

1013 **5.6.1 Design flowchart**

1014 The general approach is summarised in the flowchart below:



1016 **5.6.2 Assessment Procedure**

1017 An approximate assessment considers both the internal and external earth fault conditions as
1018 explained above but disregards any contribution that external electrodes, e.g. overhead line
1019 earth-wires or cable sheaths, may have. An approximate assessment may be all that is
1020 required in many cases providing compliance with the safety criteria is demonstrated.

1021 By reference to the flowchart above (Section 5.6.1):

- 1022 1) Establish the soil resistivity (by measurement or enquiry)
- 1023 2) Estimate the resistance of the site electrode system (using computer modelling or
1024 calculations as detailed in **EREC S34**).
- 1025 3) Obtain the worst-case fault current flowing through the electrode system, disregarding
1026 the effect of 'fortuitous' electrode systems or cable sheath/earthwire return paths.
- 1027 4) Estimate the EPR, which is the product of resistance (point 2 above) and current
1028 (point 3).
- 1029 5) If the value derived in (4) above does not exceed 2x the permissible 'touch' potential
1030 then no further assessment needs to be done. The finalised design of the earthing
1031 system may be prepared taking into account the earthing and electrode conductor
1032 ratings.

1033 If the value derived under (4) above exceeds the appropriate safety voltages by a factor of 2
1034 or more, then a more refined assessment shall be made as detailed below.

- 1035 6) Determine the soil resistivity by measurement.
- 1036 7) Estimate the value of the substation earth electrode system resistance, including the
1037 contributions made by any overhead earthwires and/or earthed cable sheaths
1038 radiating from the site using the preliminary design assessment layout and the data
1039 provided in **EREC S34**.
- 1040 8) Obtain the appropriate total values of system earth fault current for both an internal
1041 and external earth fault and deduce the greater value of the two following quantities
1042 of earth fault current passing through the earth electrode system. Refer to EREC S34
1043 for guidance on this evaluation.
- 1044 9) For an internal fault, establish the total fault current less that returning to any local
1045 transformer neutrals and that returning as induced current in any earthwire or cable
1046 sheath/armour.
- 1047 10) For an external fault, that returning to local transformers less that returning as
1048 induced current in any earthwire or cable sheath/armour.
- 1049 11) Estimate the rise of earth potential (EPR) based on the product of items (7) and (9) or
1050 (10) above, whichever is the greater.
- 1051 12) If the EPR value derived under (11) above exceeds 2x the appropriate touch or step
1052 voltages, an assessment covering touch, step, and transfer potentials shall be made.
1053 The design should consider LV, telecoms, and remote systems where relevant (ref:
1054 **EREC S34 Section XXX**)

1055 13) If the earthing system is safe against 'touch' potential it will almost always be safe
1056 against 'step' potential*, although special consideration may be needed in certain
1057 situations such as wet areas, livestock, etc.

1058 Reference should be made to **EREC S34** for equations giving ground surface potential
1059 contours; the touch potential is the difference between EPR and ground surface potential up
1060 to 1m from plant / bonded items. Computer modelling may be necessary for complex systems.

1061 Depending on the results of the evaluation, further improvements in the design of the earth
1062 electrode system may be necessary until the appropriate safety criteria for touch, step and
1063 transfer potentials are met and any necessary isolation or additional insulation is provided to
1064 avoid contact with transferred potentials which exceed the appropriate safety limit.

1065 **5.6.3 Methods to improve design (Mitigation measures)**

1066 Following assessment, if the safety criteria are not met, the designer shall consider ways to
1067 either a) reduce overall EPR, or b) reduce the step/touch voltages.

1068 5.6.3.1 EPR reduction

1069 As described in 4.4.1, there is no specified limit to the rise of earth potential of the substation
1070 and the ultimate design limit is dependent on a number of factors. However, improvements
1071 may sometimes be justified to lower this value by reducing the value of the earth electrode
1072 resistance. If, for example, the surface potential outside the substation exceeds that which is
1073 acceptable to third parties in that area (e.g. telecoms or pipeline operators), then lowering the
1074 earth electrode resistance (and consequent EPR) may be considered.

1075 Reduction of earth resistance by extending electrode area may increase transfer potential onto
1076 third party metallic services and this must be considered in the design. Note that it may be
1077 cheaper and more practical instead to protect the other authorities' plant by isolation or
1078 additional insulation.

1079 EPR (arising from local faults) can generally be reduced by one or more of: a) earth resistance
1080 reduction, b) fault level reduction, or c) reducing the ground return component.

1081 a) Is probably more practical to achieve by installation of additional electrode.

1082 b) Can be achieved by impedance earthing (section 4.5.1), or changes to running
1083 arrangements, or possibly more accurate calculation of earth fault level including earth
1084 resistance values (which may be of benefit in marginal situations).

1085 c) Can be achieved by lower impedance metallic return paths (e.g. enhanced cable
1086 sheaths or earth-wires, or undergrounding a section of overhead line to make a
1087 complete cable circuit).

1088 An excessive EPR arising from transfer voltage, e.g. carried along the cable sheath from the
1089 source substation, can be reduced by lowering earth resistance as a) above, or by introducing
1090 a sheath break into the cable (e.g. by using an insulated gland or un-earthed overhead line
1091 section); special care is required in such circumstances to ensure that an individual cannot
1092 contact two earthing systems simultaneously. There may be other considerations which make
1093 a sheath break unacceptable or ineffective in some circumstances. Alternatively, measures

* As stated in BS EN 50522: As a general rule meeting the touch voltage requirements satisfies the step voltage requirements, because the tolerable step voltage limits are much higher than touch voltage limits due to the different current path through the body.

1094 could be employed to lower the EPR at the source substation. In any case, the design must
1095 be re-assessed to consider these revised arrangements.

1096 5.6.3.2 Touch Voltage reduction

1097 If reduction of EPR is not practicable or economic, touch voltage can be reduced by adopting
1098 measures to equalise potential between an operator's hands and feet; generally these
1099 measures involve additional bonded grading electrode or mesh under the operator's position,
1100 or insulated platforms.

1101 Equations are provided in **EREC S34** which give simple touch voltage calculations.

1102 The touch and step voltages must be re-calculated or re-modelled following any changes to
1103 the electrode layout. The touch voltages appearing on external parts of a substation
1104 (fences/doors/substations) must also be considered as these could cause issues for members
1105 of public.

1106 In some circumstances, asphalt (tarmac) or similar ground coverings may be used to justify an
1107 increase in the permissible limits so that the touch voltages are acceptable (see Section 4.4.1).
1108 Protection enhancement (faster fault clearance) may be also explored in similar
1109 circumstances, since permissible limits for touch/step voltage are higher if faster fault
1110 clearance times can be achieved. These two measures should not be considered an
1111 alternative to a properly designed earthing system and should be used only as a last resort, or
1112 in conjunction with the risk assessment approach outlined below.

1113 **5.7 Risk Assessment**

1114 In some situations it may not be reasonable to achieve compliance with permissible safety
1115 voltages at all locations in and around a substation. Nevertheless, in some locations (e.g.
1116 unmanned sites with restricted access), it may be deemed to be an acceptably low risk. It is
1117 recognised in new standards that some risk must be accepted in order to provide electrical
1118 infrastructure to society.

1119 As set out in BS EN 50522, risk assessment is one of the acceptable tools for analysis of
1120 situations where the cost of removing an identified risk appears to be disproportionately high.
1121 A risk-based approach needs to consider the statistical probability of injury occurring, and to
1122 weigh this against the cost needed to mitigate against that risk.

1123 Risk Assessment should only be used in circumstances where strict compliance with
1124 permissible safety voltage limits cannot be achieved, and where there are valid and well
1125 documented reasons for this. It should be used only as a last resort, as described in the
1126 flowchart in Section 5.6.1. In practice it is most appropriate outside an installation as it should
1127 almost always be possible to achieve safe (deterministic) step and touch voltages within site
1128 boundaries.

1129 A worked example is provided in Section 11.

1130 **5.7.1 Methodology**

1131 The use of risk assessment needs to be justified, e.g. when achieving safe (deterministic)
1132 touch and step potentials is not practicable and economical.

1133 The individual risk of fatality per year (IR) for a hypothetical person* is calculated from the mean
1134 number of significant EPR events (f_n) per annum, the probability of exposure (P_E) and the
1135 probability of fibrillation (P_{FB}). A simplified formula applicable to power system applications is:

* A hypothetical person describes an individual who is in some fixed relation to the hazard, e.g. the person most exposed to it, or a person living at some fixed point or with some assumed pattern of life [R2P2]. To ensure that

1136
$$IR \cong f_n * P_E * P_{FB}$$

1137

1138 This simplified formula is in line with that presented in Annex NB of IEC 50522.

1139 P_E and P_{FB} are dimensionless quantities; P_E relates to the proportion of time that an individual
1140 is in contact with the system. P_{FB} can be derived from body current calculations and fault
1141 clearance times, with reference to Figure 20 of IEC 60479-1 [xx]. The assessment should in
1142 the first instance use the higher P_{FB} for the band (e.g. 5% for the 0-5% band AC-4.1 between
1143 lines C1 and C2). An interpolated rather than upper-bound P_{FB} may be justifiable in some
1144 circumstances.

1145 It is recommended that the large area dry contact impedance model 'not exceeded for 5% of
1146 the population' is used (Table 1 of IEC 60479-1:2005) unless specific circumstances apply.

1147 The calculated individual risk is then compared to a broadly acceptable risk of death per person
1148 per year as defined in the HSE Document "Reducing Risk Protecting People" (R2P2) [ref xx].
1149 If the risk is greater than 1 in 1 million (deaths per person per year), but less than 1 in 1000,
1150 this falls into the ALARP region (as low as reasonably practicable) and the cost of reducing
1151 risk should then be evaluated taking into account the expected lifetime of the installation and
1152 the HSE's present value for the prevention of a fatality (VPF) to determine the justifiable spend
1153 for mitigation.

1154 Where the justifiable spend is significantly less than the cost of mitigation, risk assessment
1155 may justify the decision to take no mitigating action. Mitigation may include (and is not limited
1156 to) new or relocated barriers/fences, insulating paint, earthing redesign, substation relocation,
1157 restricted access / signage, protection enhancements, reliability improvements, EPR
1158 reduction, insulated ground coverings or fault level modification.

1159 **5.7.2 Typical applications**

1160 Typical applications for risk assessment may be those outside an installation, on the basis that
1161 it is almost always possible to control step and touch potentials within the confines of a
1162 substation by using appropriate buried electrode and/or ground coverings. Risk assessment is,
1163 in any case, not appropriate for situations where the presence of an individual increases the
1164 likelihood of an earth fault, e.g. switching operations or work in substations or HV installations.

1165 **Case Study 1** in Section 11 describes a typical example of a house that has been built close to
1166 a substation with high EPR. Under substation fault conditions, touch voltages exceeding
1167 permissible design limits can appear in and around the house, due to voltage differences
1168 between the elevated soil potential and the remote LV system entering the house. The risk
1169 assessment approach allows the need for mitigation measures to be evaluated.

1170

all significant risks for a particular hazard are adequately covered, there will usually have to be a number of hypothetical persons considered.

1171 **6 Construction of Earthing Systems**

1172 **6.1 General Design Philosophy**

1173 Above ground connections may use copper or aluminium conductors. Metal structures may
1174 be used to provide connections between equipment and the earth grid where appropriate.

1175 Below ground earth grids will normally be installed using copper conductor.

1176 When designing and installing both above and below ground earthing installations the risk of
1177 theft and corrosion must be considered and mitigation measures put in place where necessary.

1178 **6.1.1 Materials**

- 1179 • The use of copper earthing conductor is preferable due to its electrical and material
1180 properties.
- 1181 • Copper tape and (hard drawn) stranded copper conductor (min strand diameter 2mm)
1182 may be used as buried electrode.
- 1183 • Bare aluminium or copper rope (fine braided) conductors must not be used underground
1184 in any circumstances due to risk of accelerated corrosion.
- 1185 • Aluminium (which is less prone to theft) may be used at least 150mm above ground.
- 1186 • Galvanised steel may be used as supplementary electrode where it is already installed
1187 for other reasons. Consideration should be given to the risk of corrosion over the lifetime
1188 of the installation. [Galvanised steel has an electropotential different to that of copper
1189 and can erode quickly if connected to a system which has copper electrodes]
- 1190 • In very hostile environments it may occasionally be necessary to use more resilient
1191 materials such as stainless steel.

1193 **6.1.2 Avoiding Theft**

1194 At the design stage all exposed copper electrode should be reduced to a minimum.
1195 On new installations above ground exposed copper and aluminium sections should be fixed
1196 using anti-theft fixing techniques. See Section 6.3.1 for conductor fixing detail.

1197 At new and existing high risk sites the use of additional anti-theft precautions must be
1198 considered.

1199 Precautions above ground may include:

- 1200 • application of anti-climb paint on above ground sections and / or above ground copper
1201 may be painted to look like aluminium or galvanised steel;
- 1202 • fitting galvanised steel anti-theft capping over the conductor to a height of at least 3 m or
1203 the equipment position;
- 1204 • fitting steel banding around structures and pinning the fixings;
- 1205 • stamping copper tape electrode with the owner's name;
- 1206 • earth connections to such items as metal cladding, metal structures, metal door frames
1207 or any other metallic panels should be made inside buildings;
- 1208 • additional site security precautions such as the application of alarms, electric perimeter
1209 fences, CCTV etc.;
- 1210 • use of forensic traceable liquids;
- 1211 • avoiding yellow/green insulated coverings (use e.g. grey instead).

1213 Precautions below ground may include:

- 1214 • placing concrete or concrete anchor blocks over buried electrode;
- 1215 • attaching earth rods every few metres to prevent removal of electrode;

- 1216 • pinning electrode at least every 300 mm where it is installed in concrete trench work or
- 1217 over concrete plinths;
- 1218 • laying electrode in conductive concrete or similar materials.

1219 Earthing conductors located in pre-formed concrete trenches (or similar) containing power
1220 and/or multicore cables should be fixed to the walls near the top (e.g. 100mm from the top).
1221 Where possible they should be concealed or otherwise protected against theft.

1222 **6.2 Jointing Conductors and Equipment Connections**

1223 **6.2.1 General**

1224 Exothermic welded, brazed and compression type joints are acceptable above and below
1225 ground.

1226 Bolted joints are only permissible above ground. For replacement work following theft this may
1227 not be initially practical but any temporary bolted underground joints must be replaced to make
1228 the repairs permanent.

1229 For connections made to equipment welded joints may be possible, but in the majority of cases,
1230 bolted joints will be necessary. The provision of bolted earth connections on equipment needs
1231 special consideration to achieve a low resistance arrangement which can withstand the
1232 maximum earth fault current without deterioration. Purpose designed connections should
1233 preferably be provided by the equipment manufacturer.

1234 Bolted connections should preferably be of the double bolt / double hole lug fixing type,
1235 however this generally requires drillings to be provided at the equipment procurement stage.
1236 Where single bolt / single hole lug fixings are provided the application of a washer and second
1237 (lock) nut provides extra security.

1238 With aluminium conductors in particular surface preparation is critical to achieving connections
1239 with ongoing low resistance.

1240 Nuts, bolts and washers are to be of high tensile stainless steel or galvanised steel, except for
1241 transition washers used for joining dissimilar metals.

1242 **6.2.2 Transition washers**

1243 A transition washer may be used to minimise corrosion when joining dissimilar metals with a
1244 bolted connection. Transition washers designed for copper-aluminium joints shall be surface
1245 penetrating, grease protected washers manufactured from corrosion resistant copper alloy to
1246 BS2874 (grade CZ121). They are designed to provide a stable corrosion resistant interface
1247 between aluminium and copper or tinned copper, and are usually provided as a pack including
1248 appropriate matched nuts, bolts and washers.

1249 Different transition washers may be required for connections from copper to galvanised metal.

1250 Transition washers tend not to be widely used for connections between aluminium and zinc
1251 coated (galvanised) steel, because zinc and aluminium are very close in the galvanic series.
1252 Such connections are likely to corrode however once the zinc coating has been lost, and
1253 therefore precautions should be taken to exclude moisture by use of an appropriate grease or
1254 paint applied after the joint is made.

1255 All bolted joints should be painted with two coats of bitumen paint, where practicable, as an
1256 aid to preventing corrosion.

1257 **6.2.3 Copper to Copper Connections**

1258 Tape to tape connections must be brazed or exothermically welded.

1259 Stranded to stranded connections must be exothermically welded or joined using compression
1260 joints.

1261 Stranded to tape connections must be exothermically welded or a lug must be compressed
1262 onto the stranded conductor, which for underground use is bolted and then brazed or welded
1263 onto the copper tape. For above ground purposes, the lug may be bolted to the tape but should
1264 preferably have a double bolt fitting.

1265 Soft soldered joints (e.g. lead-tin or lead free solder) shall not be used.

1266 **6.2.4 Copper to Earth Rods**

1267 Connections must be brazed or exothermically welded. Bolting and U-bolts are not acceptable.
1268 [Except for smaller distribution substations where hot works may not be practicable].

1269 **6.2.5 Electrode Test Points**

1270 Electrode test points may be required either at the rod top for long single rods or inline between
1271 a rod group and the main earthing system. To allow individual rod resistance values to be
1272 tested with a clip-on meter and facilitate electrode tracing all test points should be suitably
1273 constructed to allow the test clamp to fit and to avoid corrosion.

1274 Test links are not recommended, but where installed special procedures must be adopted to
1275 avoid inadvertent disconnection and to permit safe management/testing techniques.

1276 A test point associated with pile cap connections is useful but only if the design of the rebar is
1277 electrically separated from the rest of the site. At most sites the rebar will be connected
1278 together and while this provides an excellent earth, testing the individual pile cap earths is
1279 impossible. In these cases separate earth pins should have been provided in the design
1280 perhaps for high frequency and/or lightning protection which will allow testing between
1281 individual earth rods and the main earth grid.

1282 **6.2.6 Copper to Equipment (Steel, or Galvanised Steel) Connections**

1283 Connections should, wherever possible, be in the vertical plane. Remove paint from the metal
1284 at joint position on the equipment earth, sand metal smooth and apply neutral jointing
1285 compound. Drill the copper tape to accommodate the bolts (normal diameter is 10 mm) and
1286 then tin the complete contact area. The bolt holes must be less than one-third the width of the
1287 tape. Failing this a copper flag must be jointed to the copper tape and the holes drilled into
1288 this. A two bolt fixing is preferred, unless a suitably rated fixing is provided by the manufacturer.
1289 Copper joint surfaces, once drilled should be cleaned using aluminium oxide cloth (grade 80).
1290 Copper is tinned at all bolted connections; the tinning needs to be thin, and should not exceed
1291 an average of 0.5 mm, otherwise it will 'flow' from bolted sections under pressure. Neutral
1292 jointing compound is then to be applied to the joint faces.

1293 The same procedure should be used when joining to galvanised steel, in which case the zinc
1294 coating shall be removed from the joint faces.

1295 **6.2.7 Aluminium to Equipment Connections**

1296 Aluminium conductor connections to equipment should, where possible be in the vertical plane.
1297 In all cases joints must be made in accordance with Section 6.2.6 above. However, the
1298 aluminium tape should not be tinned, and appropriate transition washers should be used at the
1299 aluminium to steel interface.

1300 **6.2.8 Aluminium to Aluminium Connections**

1301 The preferred method is either inert-gas tungsten-arc (TIG) or inert-gas metal arc (MIG)
 1302 welding provided that the area of the welded material at least matches that of the tape cross
 1303 section. Bolted joints are acceptable since aluminium is only used above ground.

1304 For bolted joints the following applies:

- 1305 • All joints require a two bolt fixing.
- 1306 • Bolts must be high tensile galvanised steel, fitted with large diameter galvanised steel
 1307 washers, or (optionally), transition washers designed to penetrate the aluminium
 1308 oxide coating.
- 1309 • The surface aluminium must be cleaned using grade 80 aluminium oxide cloth or
 1310 equivalent and coated with neutral compound grease. This may not be necessary if a
 1311 transition washer is used, in which case manufacturer's guidance should be followed.
- 1312 • Bolts must be tightened using a torque wrench, to avoid over stressing in accordance
 1313 with Table 9 below. It is important not to compress aluminium connectors by excessive
 1314 tightening, as loss of 'elasticity' by plastic deformation can result in loosening of the
 1315 connection when subject to thermal cycling.
- 1316 • All excess grease must be wiped off the finished joint.
- 1317 • The joint must be sealed with two coats of bitumastic paint or equivalent.

1318

1319 **Table 9** – Bolt sizes and torques for use on aluminium

1320 Dimensions in millimetres

Bar Width	Bar Overlap	Bolt Diameter	Hole Size	Recommended Torque (Nm)	Washer Size	Washer Thickness
40	80	10	12	35	OD 25 ID 11	2.5
60	100	12	14	50	OD 28 ID 12.5	3.0

1321

1322 **6.2.9 Aluminium to Copper Connections**

1323 Connections are to be in the vertical plane, at least 150mm above the ground or concrete
 1324 plinth. They must be located in positions where water cannot gather and the aluminium will be
 1325 above the copper. Bimetallic joints must not be made on buried sections of electrode.

1326 All connections involving dissimilar metals must be cleaned with abrasive cloth and coated
 1327 with neutral compound grease, before making a bolted connection. Copper must be pre-tinned.
 1328 The finished joint should be sealed using bitumastic paint, compound, water proof tape or a
 1329 heat shrink tube filled with neutral grease. A transition washer [section 6.2.2] may be used to
 1330 minimise corrosion at bolted joints.

1331 Where joints have been made closer to ground level than 150 mm (usually following theft), a
 1332 corrosion risk assessment is necessary. If the ground is well drained and there is little chance
 1333 of water being retained around the joint then the above arrangement is acceptable. If not then
 1334 the copper must be extended upwards to reduce risk of corrosion.

1335 **6.2.10 Earthing Connections to Aluminium Structures**

1336 The following procedures are necessary to ensure that aluminium structures used to support
1337 substation equipment do not corrode:

1338 (i) The bottom surface of the structure base and the top surface where galvanised
1339 steel or other equipment is to be fitted, must be painted with two coats of bitumastic
1340 paint, prior to bolting into position on the concrete plinth. (Note - this reduces the
1341 possibility of bimetallic action which would corrode the aluminium). A conducting
1342 strap is required between any steel of the top level equipment support and the
1343 aluminium structure.

1344 (ii) Provision should be made for connecting below ground conductor to the structure
1345 via a suitable drilling and bi metallic connection (ref. 6.2.9).

1346 (iii) Except for fault throwers and high frequency earths (capacitor voltage transformers
1347 and surge arresters) the aluminium structure leg(s) may be used to provide earth
1348 continuity down to the connection to the main earth grid. The following is also
1349 necessary:

1350 Any bolted sections of the structure that may be subject to bimetallic corrosion, and/or may be
1351 of insufficient cross section, should be bridged using aluminium earth tape. The bridged joint
1352 must be made as any other aluminium to aluminium earth connection. Totally tinned copper
1353 straps can be used if necessary on connections to insulator supports from the aluminium. The
1354 copper and completed connection must be painted to prevent moisture ingress and corrosion.

1355 The aluminium structure must be connected to the main substation earth grid, using copper
1356 tape that is tinned at the joint position.

1357 Where the legs of the support structure are greater than two metres apart or the structure forms
1358 a bolted TT (or goalpost type) formation, an earth connection must be made on two legs of the
1359 structure.

1360 **6.2.11 Steel Structures**

1361 Steel structure legs should be used wherever practicable to provide the connection between
1362 the earth grid and equipment at the top, except for fault throwers and earth switches. For
1363 equipment requiring high frequency earths (e.g. capacitor voltage transformers and surge
1364 arresters), refer to section 6.14.

1365 Ideally the structure should be of the welded type or have one or more legs formed with a
1366 continuous section from ground to equipment level.

1367 If a steel structure is used to convey fault current, it must be reliable, and of sufficient current
1368 carrying capacity to avoid excessive temperature rise. If there is reliance on a single joint or
1369 leg, bolted shunts shall be considered. Where bolted shunts are used, the temperature rise of
1370 bolted connections shall be limited to 250 °C. Refer to Section 0.

1371 Joints should be reliable. Galvanising (zinc coating) of the steel forms an oxide which
1372 increases in thickness with age and could create a high resistance at steel - steel joint surfaces.

1373 Where aluminium tape is connected to a galvanised steel structure a transition washer is not
1374 required, however adequate preparation of the joint surfaces, and protection from water
1375 ingress is required in accordance with normal best practice. Refer to Section 6.2 for more
1376 detail of jointing practices.

1377

1378 **6.3 Above Ground Earthing Installations**

1379 **6.3.1 Fixing Above Ground Conductor to Supports**

1380 Previous standards required that above ground copper or aluminium tape was fixed to
1381 structures at 1m intervals using cleats. This is acceptable from a technical prospective;
1382 unfortunately the cleats used provide a convenient way for the above ground conductor to be
1383 stolen.

1384 To prevent theft, the following methods of fixing shall be used:

1385 Pinning at least every 300 mm for higher security using stainless steel pins. (The pins should
1386 have plastic spacers to separate the pin from the conductor and in the case of aluminium,
1387 plastic spacers to separate the aluminium from galvanised steelwork).

1388 Drilling and screwing with tamper proof screw heads. This method is more appropriate if the
1389 concrete support may be damaged by use of percussion driven pins. Again a plastic spacer is
1390 required to separate the screw from the metal. The screws should be stainless steel.

1391 It is important that the pins or screws are fitted such that water cannot gather and cause
1392 corrosion. Aluminium should preferably not be in direct contact with concrete, so if practicable,
1393 the back of the conductor should be coated with a high temperature aluminium grease or other
1394 heat-proof coating to prevent this.

1395 Consideration must be given to the reduction of conductor cross sectional area and current
1396 carrying capability due to drilling. Any holes introduced into the earth conductor should not
1397 exceed 10mm in diameter and one third of the width.

1398 Note that the design final temperature of a bolted connection is 250 °C, compared to that of
1399 405°C (copper) and 325°C (aluminium). Consequently earthing conductors with bolted
1400 connections have a rating that is between 80% and 90% of their normal value.

1401 **6.3.2 Prevention of Corrosion of Above Ground Conductors**

1402 Copper strip conductor supported from or in contact with galvanised steel should either be
1403 tinned or coated in a high temperature grease to prevent electrolytic action.

1404 Unless it is protected, aluminium earthing conductor should not be laid within 150 mm of
1405 ground level.

1406 **6.3.3 Metal Trench Covers**

1407 Within substation buildings, trench covers need to be indirectly earthed. This is best achieved
1408 by installing a copper strip (25mm x 3mm) along one edge of the trench top edge. The covers
1409 will be in contact with this when in position. The copper strip should be bonded to the
1410 switchgear earth bar or internal earthing system.

1411 [Feedback awaited re: Computer flooring / suspended flooring]

1412 **6.3.4 Loops for Portable Earth Connections**

1413 Earth loops of aluminium or copper strip conductor connected to the structure earth
1414 connection, must be provided at appropriate locations where portable earth leads need to be
1415 applied. The loops, if not provided as part of the structure shall preferably be formed separately
1416 and jointed to the aluminium or copper tape. Recommended size should be not less than 230
1417 mm long and 75 mm high.

1418 Loops must not be installed in the run of high frequency earths associated with CVTs and
1419 surge arrestors since these will introduce a high impedance to high frequency/steep fronted
1420 surges. A loop for portable earths may be added in parallel to the straight earthing conductor

1421 rather than as a loop formed in the earthing conductor itself. 'D' loops should only be installed
1422 on fully rated conductors.

1423

1424 **6.4 Below Ground Earthing Installations**

1425 **6.4.1 Installation of Buried Electrode within a Substation**

1426 The electrode must be installed at least 600 mm deep. This gives physical protection to the
1427 electrode and connections. It also tends to place the electrode in moist soil below the frost line
1428 so helping ensure its resistance is stable. The resistivity of ice is in the region 10,000 to
1429 100,000 Ohm.m (e.g. compared with 10-1000 Ohm.m for most soils), therefore an earthing
1430 system's resistance will increase significantly if it is not clear of frost.

1431 Buried earth electrode should be surrounded by 150 mm of fine texture non-corrosive soil,
1432 firmly consolidated. The use of pulverised fuel ash (PFA) or coke breeze as backfill is not
1433 recommended as it may induce rapid corrosion of buried electrode and metallic cable sheaths.
1434 Where there is a risk of corrosion, the electrode size may need to be increased.

1435 If the indigenous soil is hostile to copper, i.e. acidic with a pH value of less than 6 or alkaline
1436 with a pH value of more than 10, suitable surrounding soil should be imported. However, if
1437 groundwater is present (which may serve to remove the imported soil) then other methods may
1438 be necessary to protect the electrode. More regular testing or inspection may be required.

1439 When laying stranded conductor, care should be taken to avoid distorting and opening the
1440 individual strands, because this increases the probability of accelerated corrosion.

1441

1442 **6.4.2 Positioning of Buried Electrode**

1443 The laying of earth electrode close and parallel to hessian served power cables, multicore
1444 cables, or bare metal pipes, is to be avoided. This is to reduce the risk of them being punctured
1445 due to high currents or voltage transients on the electrode.

1446 Electrode must be at laid at least 300 mm away from hessian served power cables and bare
1447 metal pipes and 150 mm away from plastic sheathed cables. Where a crossing is necessary,
1448 PVC tape or a split plastic duct must be applied around the cable or pipe for 0.5 m either side
1449 of a position where the cable or pipe crosses an earth electrode, or for the distance over which
1450 the 0.3 m separation cannot be maintained.

1451 Where copper tape within the site is to be buried under proposed cable routes care must be
1452 taken to ensure it is buried deep enough or otherwise protected in a duct so that it is not
1453 damaged during cable installation.

1454 Where electrode connected to the earthing system is laid under metal fencing, and the fencing
1455 is independently earthed, the electrode should be insulated for at least 2 m each side of the
1456 fence.

1457 Earthing conductors laid near drainage pits or other civil works should maintain a separation
1458 of at least 500 mm to avoid mechanical damage during subsequent works.

1459 Where bare electrode has to cross permanent trench routes:

- 1460 • short lengths of electrode may be laid under the trench for later connection to the
- 1461 grid;
- 1462 • a short duct may be laid under the trench to accommodate the electrode.

1463 Subsidiary connections to equipment may be laid at shallower depth. Due to variation of soil
1464 resistivity near the surface, their contribution to the overall earth resistance should be ignored

1465 in the design. Their contribution towards reducing touch and step potentials should be
1466 included.

1467 In cases where a concrete plinth covers the whole substation site, (e.g. 11 kV/LV unit type or
1468 urban 33kV substations) earth electrodes should be installed prior to construction of the plinth.
1469 Provision should be made to bring multiple connections out through the concrete. The extent
1470 of the electrode mesh required will be influenced by whether steel reinforcing is used and
1471 bonded, within the foundation.

1472 When routing bare electrode off site, either to reduce the overall earth resistance or to provide
1473 a connection to external equipment such as terminal poles, routes that may be frequented by
1474 people with bare feet or animals are to be avoided.

1475 If this is not possible, calculations or computer modelling should be used to confirm that the
1476 step potentials in these areas are acceptable (a design figure of 25 V/m may be used for
1477 livestock areas as described in Section 4.4.2). Where electrode crosses land that is ploughed
1478 it should be installed a minimum of 1m deep.

1479 When rebar is installed in building and equipment foundations duplicate connections may be
1480 made from the rebar to the grid for touch voltage control. (See section 6.5).

1481 Burying copper in concrete below ground level, and at a depth such that the moisture content
1482 remains reasonably stable, does not reduce the effectiveness of the earthing [except where
1483 damp-proof membranes are installed].

1484

1485 **6.4.3 Other Earth Electrodes**

1486 6.4.3.1 Earth Rods

1487 These are generally convenient to install where the subsoil is free from boulders and rock. Rod
1488 electrodes and their connections should be in accordance with ENA TS 43-94. The earth
1489 resistance of a rod or group of rod electrodes may be calculated from formulae given in **EREC**
1490 **S34**.

1491 A number of rods may be connected in parallel but they should be installed with sufficient
1492 spacing apart such that each is essentially outside the resistance area of any other. For
1493 worthwhile results the mutual separation should be not less than the depth of the rod.

1494 The rods may be connected to the earth grid via a test chamber which is capable of accepting
1495 a clip on resistance meter.

1496 Deep earth electrodes should, as far as possible, be driven into the earth vertically. If rods are
1497 installed in drilled holes they may be backfilled with a proprietary low resistance backfill
1498 material.

1499 Rods may be particularly advantageous if the earth resistivity falls with depth. If several deep
1500 earth electrodes are necessary in order to achieve a required parallel resistance, then, where
1501 space is available, the mutual minimum separation could usefully be double that of the effective
1502 length of an individual earth electrode.

1503 Substations in large urban developments are often located below ground level in tanked
1504 structures. In such situations special facilities for installing earth electrodes are required.

1505 6.4.3.2 Earth Plates

1506 Earth plates tended to be used in older earthing system designs when they were often situated
1507 in groups or “nests” near the main transformers. Modern designs make little use of plates,
1508 except where the soil is such that it is difficult to drive in earth rods or at the corners of the

1509 earth grid perimeter electrode. In this case a plate will be installed in the vertical plane and
1510 acts as a replacement for a rod.

1511 In older sites, should an earth plate require replacement, it is likely that the earthing system
1512 itself will require redesign and this may render the plate obsolete. Where there is any doubt,
1513 the plate can be replaced on a like for like basis, or by several 2.4m rods in parallel, close
1514 together. Plates are typically 1220 mm or 915 mm square in size, of ribbed cast iron and
1515 approximately 12 mm thick.

1516 **6.5 Use of Structural Earths including Steel Piles and Rebar**

1517 Structural metalwork (piles and foundations) can make a valuable contribution to an earthing
1518 system, specifically providing parallel paths for earth fault current, reducing overall earth
1519 resistance and increasing resilience. Such contributions should be viewed as additional, rather
1520 than instead of, a dedicated earthing system.

1521 Horizontal (meshed) rebar installed in concrete or in a screed below plant can provide good
1522 control of touch voltages. In this sense it should be viewed in terms of touch voltage control,
1523 rather than as an electrode system.

1524 **6.5.1 Sheet Steel Piles**

1525 Sheets that are more than 3m long and 2m wide are to be bonded to the earthing system, as
1526 specified by the Design Engineer. Stainless steel studs are to be exothermically welded to
1527 each second sheet at a suitable height (normally 600mm below finished ground level) and a
1528 strip of 40mm x 4mm copper tape will be bolted to these. The strip will in turn be connected to
1529 the main substation earthing system. If the piles form a separate electrode connected to the
1530 earthing system at one point, then the connection should be via a test chamber such that the
1531 contribution of the piles may be monitored. Bolted connections should be avoided where
1532 possible.

1533 **6.5.2 Horizontal Steel Reinforced Foundations**

1534 For transformer and switch rooms, the most significant benefit of shallow rebar mesh is in
1535 potential grading (touch voltage control). Where this is necessary to ensure operator safety
1536 (i.e. in situations where the EPR exceeds safe touch voltage limits), it is important to ensure
1537 the integrity of any connections.

1538 For touch voltage control, rebar will be installed normally at shallow depth (i.e. with the rebar
1539 strips bound with soft steel wire, or as a prefabricated mesh), but with two or more rebar
1540 connections left protruding from the concrete for approximately 150mm sufficient to allow
1541 connection to copper or aluminium conductors. Alternatively connections may be provided
1542 before concrete is poured using a rebar clamp with flexible earth conductor. In either case any
1543 inaccessible rebar extension used for the final connections must be welded to the main rebar
1544 assembly.

1545 Ideally the rebar should be arranged with welded connections along at least two orthogonal
1546 edges such that welded joints connect each bar.

1547 If the rebar in concrete is to function as an auxiliary earth electrode (e.g. it is installed at
1548 sufficient depth to make a contribution), then current rating considerations may mean that
1549 exothermic welding is necessary for connections to the rebar and between rebar meshes.

1550 NOTE: Protruding rebar may not be acceptable in some circumstances due to concerns with water ingress etc.

1551 **6.5.3 Vertical Steel Reinforced Concrete Columns**

1552 Where these columns have steel reinforcing that extends further into the ground than it is
1553 possible to bury a conventional earthing system, then the design may require these to be
1554 bonded to the earthing system. The easiest method is to leave a section of bonded rebar
1555 150mm out of the concrete for a connection to be made later by the earth installers. This steel
1556 reinforcing bar must have its electrical continuity maintained at joint positions by welding the
1557 connection. Some designs require electrical connections between the piles made with rebar.
1558 In this case supervision of the civil works will be required before concrete is poured.

1559 NOTE: Protruding rebar may not be acceptable in some circumstances due to concerns with water ingress etc.

1560 **6.6 Metallic Fences**

1561 Two alternative earthing arrangements may be applied to metallic substation fences. These
1562 are:

- 1563 • an independently earthed (or segregated) fence arrangement where the fence is kept
1564 electrically isolated from the substation main earth system (Figure 2) or:
- 1565 • a bonded fence arrangement where the fence is bonded to the substation main earth
1566 system (Figure 3).

1567 Occasionally it may be appropriate to employ both methods on different fence sections at the
1568 same site. In this case insulated sections are used to physically link the fences with different
1569 earthing arrangements.

1570 Where the fence panels are supported by steel posts that are at least 1m deep in the ground,
1571 the posts can be considered as earth electrodes.

1572 Where it is important (mainly overhead lines crossing or in parallel with the fence or proximity
1573 to magnetic fields) to provide electrical continuity between adjacent panels, this can be
1574 provided by attention to the bolt/fixing connections or by providing a separate continuity
1575 conductor (buried or supported on the fence).

1576 **6.6.1 Independently Earthed Fences**

1577 Where the substation earthing system is effectively within the substation perimeter fence, the
1578 fence should be separately earthed with rods approximately 2.4 m long located at:

- 1579 • all fence corners;
- 1580 • one metre either side of each point where HV overhead conductors cross the
1581 fence;
- 1582 • additional locations such that the interval between rods sites shall not exceed 50m.

1583 Gate posts should be bonded together with below ground connections to ensure that difference
1584 potentials do not arise when the two parts are bridged by a person opening the gates. Flexible
1585 copper bonds (minimum 16mm² cu or equivalent) should also be used to bond the gates to the
1586 posts as an additional safety measure.

1587 **6.6.2 Segregation between independently earthed fence and earthing system**

1588 A segregation distance above ground of at least 2 metres should be maintained between the
1589 substation fence and the substation earthing system including all items connected to it. (This
1590 is based on personnel avoiding simultaneous contact with the independently earthed fence
1591 and equipment connected to the earthing system.) A similar distance shall be maintained
1592 below ground, where practicable, taking into account the location of substation perimeter
1593 electrodes etc.

1594 The 2m segregation between the independently earthed fence and the earthing system shall
1595 be maintained on an ongoing basis. This must not be compromised by alterations such as the
1596 addition of lighting or security installations, where e.g. cable armours can compromise the
1597 segregation of the systems.

1598 Where the required segregation cannot be achieved then mitigation measures should be
1599 considered (e.g. insulating paint or barriers (that do not compromise security)). Alternatively,
1600 the risk assessment approach outlined in section 5.7 may be applied.

1601 Methods to calculate the transfer potential onto fences are described in **EREC S34.**


1602

1603

1604

1605

Figure 2 – Arrangement of separately earthed fence



1606
1607

1608 6.6.3 Fences Bonded to the Substation Earthing System

1609 This arrangement is used where substation plant and equipment is located with 2m of a
 1610 metallic fence and where internal fences which are located within the area encompassed by
 1611 the substation earthing system. The fences should be connected to the earth grid using
 1612 discrete but visible connections located at:


- 1613
- all fence corners;
 - one metre either side of each point where HV overhead conductors cross the fence;
 - additional locations such that the interval between connections does not exceed 50m.
- 1614
1615
1616
1617

1618 Where the fence which is connected to the substation earthing system is the perimeter fence,
 1619 and where the touch potential external to the fence could exceed the safety limits set out in
 1620 Table 1, then the following requirements apply.

- 1621
- A bare electrode conductor shall be buried in the ground external to the perimeter fence at approximately a distance of 1 metre away and at a depth of 0.5 metres. In agricultural locations risk of disturbance due to ploughing should be addressed;
 - The conductor should be connected to the fence and to the earthing system at intervals of 50 metres or less such that it becomes an integral part of the substation earthing system. One method to achieve this is to 'expand' the substation grid such that the fence is located within the area of this grid. (Figure 3 below);
 - Chippings or asphalt around the substation perimeter will provide additional protection to animals/persons outside the substation.
- 1622
1623
1624
1625
1626
1627
1628
1629

1630 At locations where fencing connected to the substation earth grid abuts with independently
 1631 earthed fencing and this presents a touch hazard, there should be electrical isolation between
 1632 the two fence systems. See para. 6.6.5 for methods of achieving electrical isolation between
 1633 fences using insulated fence sections.

1634 **Figure 3 – Arrangement of bonded fence**



1635
 1636

1637 **6.6.4 Third Party Metallic Fences**

1638 Third parties shall not directly connect their metal fences to a metallic substation fence, as this
 1639 may introduce a transfer potential risk. Where such third party fences are present or are likely
 1640 to be present within 2 m of the substation, one of the options listed below should be
 1641 implemented to maintain electrical isolation between the two fence systems.

1642 Note: Security considerations may preclude this if the third-party fence could act as a climbing aid.

1643

1644 **6.6.5 Insulated Fence Sections.**

1645 Insulated fence sections to segregate lengths of fencing which are bonded to the main earth
 1646 grid from those which are independently earthed or connected to third party fences may be
 1647 used. The insulated sections may be formed by:

- 1648 a) Installing a 2 m (or longer) insulated fence panel made wholly of insulating material.
- 1649 b) Installing a 2 m (or longer) metal fence panel mounted on insulated supports / standoff
 1650 insulators. (The insulators need a voltage withstand capability in excess of the highest
 1651 EPR at the perimeter of the site whilst at least maintaining the equivalent physical
 1652 strength of the fence).

1653 Coated fences (section 6.6.7) must not be treated as insulated sections unless specifically
1654 designed and tested for such purposes.

1655 **6.6.6 Chain Link Fencing (Galvanised or Plastic Coated)**

1656 Such fencing should be earthed by bonding the support posts, fence and straining wires and
1657 any anti-climbing devices to the independent or bonded fence earth electrode system as
1658 appropriate. This may conveniently be achieved by the addition of an electrode run with the
1659 fence to aid bonding/earthing. The fence shall be treated as if it were bare metal, i.e. no
1660 insulation withstand should normally be assumed.

1661 If a touch potential issue exists with a plastic coated chain link fence it should be addressed
1662 by installing a grading electrode rather than by relying on the integrity of the plastic fence
1663 coating which may not be comprehensive and is also likely to deteriorate.

1664 **6.6.7 Coated Fence Panels**

1665 These typically consist of galvanised steel support posts and galvanised steel mesh panels,
1666 all of which are coated. When used for enclosing electrical apparatus or a substation, they
1667 shall be earthed and precautions are necessary to cater against damage or erosion of the
1668 coating. The support posts shall be earthed via a bolted connection and ideally the metal of
1669 each panel should in turn be similarly connected to the post. Ideally these should be via
1670 manufacturer provided facilities. The overall fence is connected to earth in a similar manner to
1671 a separately earthed or bonded metal palisade fence.

1672 Such fences should not be treated as insulating, unless the covering is specifically designed
1673 for this purpose and its longevity can be assured.

1674 If a touch potential issue exists with a coated fence it should be addressed by installing a
1675 grading electrode.

1676 **6.6.8 Electric Security Fences**

1677 When electric security fencing is installed on independently earthed fence installations, the
1678 isolation of segregated fence sections from the main substation earthing system must be
1679 maintained. This may require independent electric fence zones and special consideration of
1680 electric fence earth connections.

1681 **6.6.9 Anti-climbing Precautions**

1682 Where barbed wire or other metal anti-climbing devices are erected along the top of brick walls
1683 or other non-metallic barriers they may be connected to earth using the same procedure as
1684 with fencing. Note that metallic parts not liable to introduce a potential need not be bonded
1685 (e.g. short lengths of barbed wire or spikes etc.).

1686 Care should be taken to ensure that anti climbing guards do not bridge fencing sections that
1687 are designed to be separately earthed or isolated. This includes e.g. the metal centre rods of
1688 plastic 'vane' guards etc.

1689 **6.7 Specific Items**

1690 **6.7.1 Water Services to Substations**

1691 Water supplies to substations shall be run in non-metallic pipes. This avoids the substation
1692 potential rise being transferred outside so endangering other users of the water supply system.
1693 This is now largely a legacy issue at older sites as insulated pipes are used for new
1694 construction. When such an existing site is being refurbished or upgraded at least a section of
1695 insulated plastic pipe should be inserted in the incoming metallic water service.

1696 Any metallic pipe used within the substation site should be bonded to the substation earthing
1697 system and adequately segregated from separately earthed fence sections.

1698 **6.7.2 Non-current carrying metalwork**

1699 Most non-current carrying metalwork of all kinds within the perimeter fence shall be securely
1700 bonded to the main earthing system to ensure that all such items are held to the same potential
1701 and, if called upon to do so, will carry fault currents without damage. Exceptions apply to
1702 conductive parts not liable to introduce a potential, and these need not be bonded.

1703 The cross section of any bonding conductors shall be as described in Table 5 and Table 6. If
1704 there is no likelihood of current flow or corrosion/erosion, equipotential bonding conductors
1705 should be no smaller than 16mm² copper or equivalent.

1706 NOTE: Small metallic items (extraneous metalwork) that are unlikely to introduce or carry a significant potential,
1707 need not be bonded to the main earthing system (ref: 4.2). Such items may include, but are not limited to, window
1708 frames, signposts, wall brackets, small access steps/handrails etc.; However if there is any foreseeable likelihood
1709 of them adopting a potential in service (sufficient to cause a touch voltage hazard), such items should be bonded
1710 to the main earthing system.

1711 Larger items, even if some distance from current carrying metalwork, may adopt a stray voltage due to induction or
1712 capacitive coupling and should always be bonded.

1713 **6.7.3 Items normally bonded to the main earth grid:**

1714 These include:

- 1715 • overhead line termination structures including towers, gantries and earthed wood pole
1716 structures within or adjacent to the substation;
- 1717 • power cable sheaths and armours (at one or more points);
- 1718 • transformer and reactor tanks, coolers and radiators, tap changers, earthing resistors,
1719 earthing reactors, high voltage transformer neutral connections;
- 1720 • metal clad switchgear assemblies and cases, isolators and earth switch bases;
- 1721 • metal gantries and structures and metalwork mounted on wood structures;
- 1722 • metallic building structures including steel frames (bonded at each corner), rebar and
1723 piles. Miscellaneous metalwork associated with oil and air tanks, screens, steel structures
1724 of all kinds;
- 1725 • all panels, cubicles, kiosks, LV AC equipment, lighting and security masts.

1726 Critical items such as transformer tanks and terminal towers shall have duplicate connections
1727 to the main earth grid.

1728 **6.7.4 Items NOT normally bonded to the Earth Grid**

1729 The following list is not exhaustive, and includes some typical items that a designer may specify
1730 to remain un-bonded.

- 1731 • The perimeter fence is only bonded to the main earth system if all or part of it cannot be
1732 kept at least 2 m clear of earthed structures and the main earthing system. (Section 6.6)
- 1733 • Screens of telephone cables where they are taken into HOT sites. (Refer to 4.3.7);
- 1734 • Extraneous non-current carrying metalwork as described in Section 6.7.2
- 1735 • Parts intended to be isolated from earth (e.g. floating fence panels, some stay wires, etc.)
- 1736 • Some protection equipment, or equipment connected to (e.g.) frame leakage protection,
1737 which must be connected to earth in a specific manner.
- 1738 • LV neutrals/earths in some circumstances.

1739 **6.7.5 Non-standard bonding arrangements**

1740 Sometimes it may be necessary to isolate cable sheaths and screens from the main substation
1741 earth grid to avoid transfer potential issues. Such arrangements must be the subject of a
1742 bespoke design and precautions taken at the earth isolation point to avoid touch potential
1743 issues.

1744 NOTE: There may be other considerations which make a sheath break unacceptable or ineffective in some
1745 circumstances. ENA EREC C55 provides further related information.

1746 **6.8 Overhead Line Terminations**

1747 **6.8.1 Tower Terminations Adjacent to Substation**

1748 Where the aerial earth wire of an incoming overhead line terminates on a steel tower / terminal
1749 support adjacent to a substation, continuity shall be provided for current in the earth wire to
1750 flow into the main earthing system. Continuity is to be provided by:

- 1751 • bonding the aerial earth wire to the top of the line gantry, or;
- 1752 • bonding the aerial earth wire to the top of the tower, and bonding the base of the tower to
1753 the main substation earthing system.

1754 The rating of the bonds must at least be equal to that of the aerial earth wire.

1755 If not bonded via aerial earth wire, the tower must be bonded to the main earth grid via two
1756 continuous conductors which run from different tower legs via separate routes and connect to
1757 two different points on the main earth grid. Each below ground conductor must be fully rated.
1758 The bonds should be buried and be installed so as to minimise risk of theft. If the bonds run
1759 under an independently earthed fence they must be insulated for a 2 metre distance on either
1760 side of the fence.

1761 If the tower legs are located within 2 m of an independently earthed metal fence then the
1762 section of fence adjacent to the tower should be bonded to the tower and electrically isolated
1763 from the rest of the fence. Alternatively the relevant metal fence panels may be replaced by
1764 insulated panels, or suitable insulating coating applied (ref: 4.4.3 and 6.6). If this is not
1765 practicable a risk assessment should be carried out (section 5.7).

1766 **6.8.2 Steel Tower Termination with Cable Sealing Ends**

1767 Where an aerial earth wire terminates on a tower with a sealing end platform or an associated
1768 cable sealing-end compound that is well outside the substation, continuity between the base
1769 of the tower and the main earthing system will be provided by either the sheaths of the power
1770 cables or by an earth continuity conductor laid and installed in accordance with ENA EREC
1771 C55.

1772 **6.8.3 Terminal Poles with Stays Adjacent to Substation Fence**

1773 Stay wires that are external to the site and more than 2 m from the fence or earthed metalwork
1774 may be left un-earthed, if this is in accordance with normal practice. They should be earthed
1775 within the substation compound where possible to minimise risk from current leakage across
1776 the stay insulator.

1777 Earthed stay wires can present a touch potential risk if the stay is in very close proximity to an
1778 independently earthed fence, and may form an inadvertent connection between the
1779 independently earthed fence and the main earth grid. To address this, in addition to installing
1780 the normal upper stay insulator a second stay insulator should be installed as close to ground
1781 level as possible leaving the centre section of the stay unearthed. 2 m segregation must be
1782 achieved between the lower earthed section of the stay including the rod and the fence.

1783 Unless the earthed stay rod is inside the earth grid, a loop of buried electrode should be laid
1784 around the rod at a 1m radius, and bonded to the rod/main earthing system to control touch
1785 potential.

1786 **6.8.4 Down drop Anchorage Arrangement with Arcing Horns**

1787 Where it is necessary to have an assembly of ferrous fittings such as turn buckles, links,
1788 shackles etc. between the insulators and an earthed structure or ground anchor point,
1789 precautions may be required if the earth fault current is very large.

1790 The earthed end arc-ring (or horn) anchorage arrangement may be attached to the main earth
1791 connection by means of a flexible copper shunt, in order to limit earth fault current flowing
1792 through the discontinuous ferrous fittings. This prevents mechanical damage due to arcing.

1793 **6.8.5 Loss of Aerial Earth Wires**

1794 If alterations are carried out to overhead lines which break an otherwise continuous aerial earth
1795 wire between substation sites, consideration must be given to the increase in ground return
1796 current and consequent increase in EPR which arises.

1797 There may also be a further increase in EPR due to reduction of the chain impedance
1798 contribution. It may be necessary to consider the installation of an overhead or buried earth
1799 conductor to provide continuity of the aerial earth wire.

1800 **6.9 HV Cable Metallic Sheath / Armour Earthing**

1801 This section covers all HV power cables contained within or entering HV substations but
1802 excludes those HV cables which feed HV/LV transformers located in the substation where the
1803 LV supply is exclusively for use in the substation. The requirements for these latter cables are
1804 dealt with under Section 9.

1805 **6.9.1 Insulated (Polymeric) Sheath Cables**

1806 The metallic sheath/armour of cables can, due to their inductive coupling properties, provide a
1807 very low impedance return path for earth fault current flowing in the cable phase conductors.
1808 This can greatly reduce the current that returns to source though the ground and subject to the
1809 sheath being continuous significantly reduce the EPR at associated terminal substations.

1810 To achieve this, the sheath/armour must be earthed at least at both ends. This arrangement
1811 of earthing is generally satisfactory for three-core and TRIPLEX type high voltage cables
1812 forming part of general distribution system circuits.

1813 Simply bonding sheaths/armours at both ends of single-core cables or very heavily loaded
1814 circuits such as transformer interplant cables can cause de-rating as large steady-state
1815 currents may flow in the sheath/armours, causing additional heating and risking damage.

1816 Consequently two methods of installation have been developed for single-core cables where
1817 the length is sufficient to cause this problem.

1818 a) Single Point Bonding – where the sheaths are connected to earth at one point. A parallel
1819 Earth Continuity Conductor may be laid with the cables to provide continuity between items
1820 of plant.

1821 b) Cross bonding – where the sheaths are connected to earth at each end, and periodically
1822 transposed to cancel circulating currents flowing in the sheaths.

1823 Single-point bonding preserves the rating of the cables, but permits a voltage to develop
1824 between the sheaths/armours and earth at the unearthed ends of the cables which could, on
1825 long cable runs, require shrouding or other measures to ensure safety.

1826 Cross-bonding provides a return path for earth fault current in the sheaths without permitting
1827 significant steady-state de-rating current to flow or exceeding the sheath voltage rise limit. Care
1828 is needed at link boxes/transposition points.

1829 Both methods, together with their merits and disadvantages are described in detail in ENA
1830 EREC C55 “Insulated Sheath Power Cable Systems”, together with solutions to the problems
1831 described above. A bespoke cable and earthing / bonding design is usually required for very
1832 heavily loaded circuits (e.g. interplant cables) or circuits operating above 33 kV.

1833 Methods for calculating the sheath return current and resulting ground return current (for
1834 systems with sheaths earthed at both ends) are given in **ENA EREC S34**.

1835 **6.9.2 Cables Entering Substations**

1836 The sheath/armour at the substation end of the cable should be earthed to the substation
1837 earthing system.

1838 TRIPLEX, three-core, and fully cross-bonded cables will, in addition, be earthed at their remote
1839 ends. This provides both a conductive and inductive path for fault current. With cross-bonded
1840 single-core cables, it is the usual practice to install further additional sheath earths along the
1841 route of the cable. The additional sheath earths will normally produce an insignificant benefit,
1842 and can be ignored in the assessment of the substation earth resistance.

1843 **6.9.3 Cables Within Substations**

1844 Three-core cables will have their sheath/armour earthed at both ends.

1845 Single-core cables will usually be short enough to allow single-point sheath/armour earthing,
1846 without causing serious sheath voltage rise problems. The single sheath/armour bond to earth
1847 should be located where personnel are most frequently present, for example at switchgear.
1848 Screens should be shrouded at the unearthed end. An earth continuity conductor may be
1849 required. Refer to ENA EREC C55 for further details.

1850 For the higher voltage systems, sheath voltage limiting devices (SVLs) may be installed
1851 between the sheath and earth at the unearthed end of the cable to protect the integrity of the
1852 sheath and its terminating point insulation against transient voltage surges on the sheath.

1853 **6.9.4 Outdoor Cable Sealing-Ends**

1854 Where cables terminate at outdoor sealing-ends, pedestal-type insulators are fitted to insulate
1855 the sealing-end base and gland from its support structure. If sheath earthing is made at this
1856 location special earthing bonds are required in accordance with ENA TS 09-15 or EREC C55
1857 as appropriate.

1858 When the standing sheath-voltage at a termination can exceed 10 volts to earth, the base
1859 metalwork of the sealing-end shall be screened against accidental contact by means of an
1860 insulating shroud of the type illustrated in EREC C55.

1861 Sealing-end support insulators should be used only for short single-core cable tails with an
1862 earth bond made at the trifurcating point of any three-core cable.

1863 **6.9.5 Use of Disconnected, Non-Insulated Sheath/Armour Cables as an Electrode**

1864 Metallic sheathed/armoured hessian served cables are often decommissioned or replaced with
1865 insulated sheath cables. Where these are laid direct in soil, they can provide a valuable
1866 electrode contribution. Where practicable (particularly if the buried length exceeds 200 m)
1867 these redundant cables should be retained as earth electrodes to maintain their contribution
1868 towards lowering overall substation earth resistance and EPR.

1869 If such sections are retained, the phase conductors and sheaths/armours of these cables, once
1870 disconnected should be joined together to maintain their contribution to the electrode system.
1871 The start ends should ideally be connected to the earth grid via test chambers to permit
1872 continuity or resistance measurements. The remote ends should, if practicable, be connected
1873 to the electrode system at a joint or distribution substation. Cable and earthing records should
1874 be annotated to show such cables are being used as substation earth electrode.

1875 Constant-force springs (CFS) or plumbed joints may be appropriate for connecting stranded
1876 copper conductor to lead sheathed cables; other types of connection may loosen in service as
1877 the lead continues to flow or 'creep' under contact pressure. In any case moisture should be
1878 excluded from such joints using heat shrink boots or similar. Manufacturer's guidance should
1879 be sought if connecting to sheaths of other cable types.

1880 **6.10 Light-current Equipment Associated with External Cabling**

1881 All exposed conductive parts of light current equipment shall be earthed to the main earthing
1882 system as required. Where pilot or communication cables operate between two remote points
1883 and the rise of earth potential at each end of the circuit does not exceed the appropriate ITU-
1884 T limit, any required circuit earth may be made at either end. If the rise of earth potential at
1885 either end exceeds the appropriate ITU-T limit, then protective measures shall be applied to
1886 those circuits. Refer to ENA EREC S36, and sections 4.3.7 and 6.9.3.

1887 **6.11 Metal Clad and Gas Insulated (GIS) Substations**

1888 **6.11.1 Metal Clad Substations**

1889 Metal clad substations will normally be erected on a concrete raft. The provisions for an earth
1890 electrode system in these circumstances will be similar to those described under item 9.3.1.
1891 Where touch potential is an issue consideration should be given to using an enclosure made
1892 of insulating material and to using surface-laid earth mat/grating.

1893 **6.11.2 Gas Insulated Switchgear (GIS)**

1894 Gas Insulated Switchgear (GIS) employing single-phase busbar enclosures require additional
1895 earthing precautions incorporated into the design of the substation earthing system.

1896 Due to close coupling with individual phase conductors busbar enclosures can experience high
1897 levels of induction. Steelwork used to support the enclosures and adjoining items of plant may
1898 form closed paths in which induced inter-phase and earth currents flow under both steady-
1899 state and fault conditions. These currents can be undesirably high and may approach the
1900 phase conductor current. The flow of circulating current renders secondary wiring more
1901 vulnerable to inductive interference.

1902 A further issue with GIS is the creation of surge voltages on the enclosures and associated
1903 steelwork during switching or other transient/high frequency system disturbances.

1904 To help minimise the above effects it is recommended that an earth grid, well integrated and
1905 with locally enhanced electrode (e.g. increased mesh density and vertical rods) in the regions
1906 close to the plant, be laid over the raft from which short spur connections can then be taken to
1907 the specific earthing points on the equipment. Typical arrangements are described in CIGRE
1908 Paper 044/151 - "Earthing of GIS – An Application Guide", issued by Working Group 23.10
1909 (December 1993).

1910 To retain current in the busbar enclosures, short circuit bonds, together with a connection to
1911 the earthing system, should be made between the phase enclosures at all line, cable and
1912 transformer terminations, at busbar terminations and, for long busbar runs, at approximately
1913 20 metre intervals. Switchboards > 20 m long will require intermediate connections. Except
1914 where adjacent enclosures are insulated from each other the interface flanges of the

1915 enclosures should have bonds across them and the integrity of bolted joints of all bonds should
 1916 be checked.

1917 As a guide the resistance of the bonded flanges should not exceed 5 micro-ohm. At insulated
 1918 flanges consideration should be given to the installation of non-linear resistive devices to
 1919 prevent transient flash-over.

1920 **6.12 Fault Throwing Switches, Earth Switches and Disconnectors**

1921 **6.12.1 Background**

1922 Fault throwing switches, earth switches and disconnectors are normally mounted on steel,
 1923 aluminium, steel reinforced concrete or wood pole structures.

1924 Metallic structures may be of electrically continuous all welded construction or assembled
 1925 using several large pre welded sections or individual bolted members. In some cases though
 1926 the structure is of bolted construction there may be a continuous metallic section from ground
 1927 to equipment level. Where there is more than one metallic section in series in a fault current
 1928 path continuity between sections needs to be considered.

1929 Where steel or aluminium support structures are used to support isolators and / or earth
 1930 switches it is desirable to use the structure itself to carry earth fault current in order to reduce
 1931 the need for above ground earth conductors with consequent risk of theft. This arrangement is
 1932 only acceptable where the metallic structure can provide a reliable earth connection with
 1933 adequate current carrying capacity.

1934 NOTE: Some Network Operators may not use support structures in lieu a dedicated earthing conductor. See also
 1935 6.2.6

1936 When installing earth connections to earth switches and isolators the design will take into
 1937 account the magnitude and duration of the prospective earth fault currents involved. **Fault**
 1938 **throwing switches shall have a dedicated earth connection, see 6.12.2.**

1939 The main earth connection to these devices carries earth fault current under the following
 1940 conditions:

1941 **Table 10 – Conditions for the passage of earth fault current**

Device	Condition For Passage of Earth Fault Current
Fault Throwing Switch	By design when protection operates
Earth Switch	When there is an equipment failure or switching error. May also carry lightning induced current when closed.
Isolator	When the isolator or its connections fault, or when the isolator is used in a sacrificial mode if main protection fails.

1942

1943 The main options for connecting earth switches and isolators are to use either:

- 1944 • a fully rated earth conductor, fixed to the structure. This method is most applicable to higher
 1945 fault current applications (e.g. systems operating at 90kV and above) or where the support
 1946 structure cannot provide an adequate earth fault current path. See Table 5 and Table 6 for
 1947 conductor ratings;
- 1948 • alternatively a metallic structure may be used to conduct earth fault current from the top of
 1949 the structure equipment to the grid. This is subject to the structure having sufficient current

1950 carrying capability and being electrically continuous. The method is more applicable to
1951 lower fault current applications (e.g. 33 kV systems) which use welded or continuous
1952 metallic structures.

1953 The following earthing arrangements apply to fault throwing switches, earth switches and
1954 isolators located within secured substation sites fitted with earth grids.

1955 Different arrangements (e.g. insulated down-leads) may be required for equipment located
1956 outside substations in areas accessible to the public.

1957 **6.12.2 Fault Throwing Switches (Phase - Earth)**

1958 A direct earth connection shall be made from the switch earth contact to the main earth grid
1959 using a conductor fixed to the structure.

1960 **6.12.3 Earth Switches**

1961 Connections from earth switches to the main earth grid may be made by either:

1962 a) An earth conductor, fixed to the structure or:

1963 b) By using the metallic support structure as a conductor subject to the aluminium or steel
1964 structure having sufficient current carrying capability and being electrically continuous.

1965 **6.12.4 Isolators**

1966 Connections from isolator support metalwork to the main earth grid may be made by either:

1967 a) A fully rated earth conductor, fixed to the structure or:

1968 b) By using the metallic support structure as a conductor subject to the aluminium or steel
1969 structure having sufficient current carrying capability and being electrically continuous.

1970 **6.13 Operating Handles, Mechanisms and Control Kiosks**

1971 **6.13.1 Background**

1972 Earthing arrangements for operating handles of isolators, circuit breakers, earth and fault
1973 throwing switches must provide touch and step potential control for the operator.

1974 These are critical locations which require careful consideration and sound construction.

1975 A full earth grid may not always be present at some older sites and additional precautions may
1976 be required when operational work and/or minor alterations are being carried out to ensure
1977 safe touch and step potentials. Generally, with exceptions outlined below, stance earths shall
1978 be provided at all locations where operators may stand to operate high voltage equipment
1979 handles, mechanisms and control equipment.

1980 **6.13.2 Earth Mats (Stance Earths)**

1981 New installations will have touch and step potential control provided by a purpose designed
1982 earth grid. If it can be demonstrated that such measures are adequate to ensure operator
1983 safety, and if a network operator's operational policy allows, an additional stance earth may
1984 not be required. In making this assessment, the likelihood of deterioration due to theft or
1985 corrosion should be considered. Portable or visible (surface laid) stance earths may be
1986 required in addition to any buried grading electrode as a risk reduction measure.

1987 NOTE: Surface-laid earth mats are preferred over buried earth mats; they give much better touch control and their
1988 presence can readily be checked. The size and position of the mat must match the operator stance position(s) for
1989 the given equipment. Galvanised steel grating earth mats can be readily extended to cover the operator path
1990 followed with horizontal operation handles. Buried earth mats may be a suitable alternative to surface-laid earth
1991 mats where the resulting touch voltage is sufficiently low.

1992 **6.13.3 Connection of Handles to the Earth Grid and Stance Earths**

1993 The earth connection from the handle to the grid shall always be separate to that for the switch
1994 metalwork and be as short as possible.

1995 The earth connection shall use standard copper conductor connected direct to the main
1996 substation earth.

1997 In some cases an insulated insert may be fitted between the operating handle and the switch
1998 metalwork to help prevent any fault current flowing down the handle and mechanism into the
1999 earth grid.

2000 Refer also to Section 10.6 (Earthed Operating Mechanisms Accessible From Ground Level).

2001 **6.14 Surge Arrestors and CVTs**

2002 Plant including surge arresters and CVTs (Capacitor Voltage Transformers), which are
2003 connected between line and earth, present relatively low impedance to steep-fronted surges
2004 and permit high-frequency currents to flow through them to earth.

2005 Unless a low impedance earth connection is provided, the effectiveness of the arrester could
2006 be impaired and high transient potentials appear on the earthing connections local to the
2007 equipment. The following installation earthing arrangements are recommended:

2008 Two connections to earth are required for both surge arresters and capacitive voltage
2009 transformers (CVTs):

2010 • The first connection (for power frequency earthing) will use the structure to the main
2011 substation earth grid.

2012 • The second (high frequency) connection should be direct to an earth rod, installed
2013 vertically in the ground as near to the surge arrester base as possible, with a tee
2014 connection to the support structure if metal. High frequency earth rods shall be driven
2015 vertically into the ground to a depth of approximately 4.8m. Where this is not achievable,
2016 a high density earth mesh arrangement or four (or more) long horizontally buried
2017 conductors (nominally 10m in length, minimum depth 600mm) dispersed at 90° (or less,
2018 equally spaced across the full 360°) may be used in place of the rod. Calculations must
2019 be provided to demonstrate that any proposal is equivalent to the 4.8m long earth rods.
2020 The high frequency connection shall be made to the centre of the alternative HF earthing
2021 designs. Dedicated earth mats or similar may be considered in difficult circumstances.

2022 Refer to BS EN 62305 (Lightning Protection Standard) and BS EN 62561-2 (Lightning
2023 Protection System Components – requirements for conductors and earth electrodes), or ENA
2024 ER 134 for more information.

2025 The benefit of surge arresters over arc gaps is greatest when the resistance to earth is less
2026 than 20 Ohms. When a surge arrester is provided at a cable termination, the earth side of the
2027 arrester should be connected to the cable crucifix and thereby to the cable sheath. Surge
2028 arresters should be sited as close as practical to the terminals of the plant, (e.g. transformer
2029 bushings or cable sealing ends) which they are protecting.

2030 The support structure and plinth will be designed to allow the high frequency earth connection
2031 to either pass through its centre, or through an angled slot to ensure that the connection is as
2032 short and straight as possible. This will aid performance and deter theft. It is particularly
2033 important to avoid sharp bends. This connection must not be enclosed within a steel support
2034 tube or box.

2035 Fully rated conductors must be used for both high frequency and power frequency
2036 connections. High frequency downleads should be insulated from the support structure
2037 (except where bonded to the structure at low level) to accommodate surge counters, and also
2038 to facilitate testing of the electrode with a clamp meter (Section 7.6.2(b)).

2039 **7 Measurements**

2040 **7.1 General**

2041 This section describes some of the most common measurements which may be required
2042 during the design, commissioning or maintenance of an earthing system at an electrical
2043 installation. An overview of the important measurement and interpretation methods is provided
2044 together with some guidance on avoiding sources of error. More detailed guidance and method
2045 statements would be expected to be available in company manuals and operational
2046 documentation.

2047 **7.2 Safety**

2048 The earthing related measurements described in this section are potentially hazardous. They
2049 must be carried out by competent staff using safe procedures following a thorough assessment
2050 of the risks. The risk assessment should include, but not be limited to, consideration of the
2051 following aspects and the necessary control measures implemented, e.g. personal protective
2052 equipment, special procedures or other operational controls.

2053 a) Potential differences that may occur during earth fault conditions between the
2054 substation earthing system and test leads connected to remote test probes.
2055 The likelihood of an earth fault occurring should be part of this assessment,
2056 e.g. not allowing testing to proceed during lightning conditions or planned
2057 switching operations.

2058 b) Potential differences that may occur between different earthing systems or
2059 different parts of the same earthing system. In particular, approved safe
2060 methods must be used when disconnecting earth electrodes for testing and
2061 making or breaking any connections to earth conductors which have not been
2062 proven to be effectively connected to earth*.

2063 c) Potential differences occurring as a result of induced voltage across test leads
2064 which are in parallel with a high-voltage overhead line or underground cable.

2065 d) Environmental hazards of working in a live substation or a construction site as
2066 governed by the electricity company safety rules or the CDM regulations as
2067 applicable.

2068 e) Injury when running out test leads for large distances in surrounding land.

2069

2070 * NOTE: Disconnection from earth can cause voltage differences to arise in the case of the path from tower line-
2071 earthing system due to induction; as it is related to current in the tower line, and therefore present continuously, it
2072 represents a particularly serious hazard.

2073

2074 **7.3 Instrumentation and Equipment**

2075 It is imperative that measurements are taken using the most suitable instrumentation for the
2076 required task which is in good working order and has a valid calibration certificate. The
2077 instrumentation will be used for field measurements in all weather conditions. It must therefore
2078 be robust, have a sufficient level of water resistance and be suitably protected from electrical
2079 transients (e.g. by fuses) and shielded for use in high-voltage installations. Further advice on
2080 this may be sought from a reputable instrument manufacturer.

2081 Instruments shall be calibrated regularly (e.g. annually) to a traceable national standard.
2082 Heavily used instruments should be checked more frequently, e.g. against other calibrated
2083 instruments or standard resistors, between formal calibration periods. Instruments must be

2084 periodically serviced/safety tested and any identified damage or faults must be rectified before
2085 re-use.

2086 Many of the measurements require ancillary equipment such as test leads, earth rods,
2087 connection clamps, etc. and it is equally important that these are also fit-for-purpose and well-
2088 maintained.

2089 **7.4 Soil Resistivity Measurements**

2090 **7.4.1 Objective**

2091 Site specific measurements are required to determine the resistivity of the materials (soil, rock,
2092 etc.) that make up the ground where an earth electrode is installed. The results obtained can
2093 be interpreted to provide a uniform equivalent resistivity for use in standard design equations
2094 (EREC S34) or a multi-layer soil model, which can be used in commercially available computer
2095 simulation tools. Important design parameters such as the earth resistance and EPR are
2096 strongly dependent on the soil resistivity so it is essential for the accuracy of the design that
2097 proper attention is given to these measurements and their interpretation as early as possible
2098 in the design process.

2099 **7.4.2 Wenner Method**

2100 A four-terminal earth tester is used for these measurements. There are a number of available
2101 measurement techniques which involve passing current through an array of small probes
2102 inserted into the surface of the soil and measuring the resulting potentials at specified points.
2103 Using Ohm's law a resistance can be calculated which may be related to the apparent
2104 resistivity at a particular depth using suitable formulae. Varying the positions of the probes,
2105 and hence forcing the current to flow along different paths, allows the apparent resistivity at
2106 different depths to be measured. The most commonly used arrangement for earthing purposes
2107 is the Wenner Array (Dr Frank Wenner, US Bureau of Standards – now NIST) and this is
2108 described in more detail in BS EN 50522 UK National Annex C.

2109 NOTE: There are variations on the Wenner Array method using uneven electrode spacings that can be used and
2110 these include the Schlumberger Array method and the General Array method.

2111 For large substations it is important to take measurements at a number of different locations
2112 around the site so that an average may be used. In urban areas meaningful measurements
2113 may only be obtained from the nearest parks or open ground and so results from several
2114 locations around the substation are essential.

2115 **7.4.3 Interpretation of Results**

2116 It is difficult to interpret measurement results by inspection other than for a uniform or two-layer
2117 soil model. Formulae for interpretation of data for soils with three or more layers are
2118 cumbersome and practically requires the use of software. There are a number of suitable
2119 software tools available commercially. Because most of these are based on a curve-fitting
2120 approach, geo-technical information such as borehole records are useful to reduce uncertainty
2121 in the soil resistivity model by indicating layer boundary depths, materials, water table height,
2122 bedrock depth, etc. and should be used where available.

2123 Knowledge of the soil resistivity at different depths is important when designing the most
2124 effective electrode to reduce the substation earth resistance. For example, vertical rods are
2125 better suited to a soil with a high resistivity surface layer and low resistivity material beneath.
2126 Conversely, where there is low resistivity material at the surface with underlying rock then
2127 extended horizontal electrodes will be more effective.

2128 **7.4.4 Sources of Error**

2129 There are a number of sources of measurement error which must be considered when planning
2130 and carrying out these measurements. These include, but are not limited to:

- 2131 (a) influence of buried metallic structures such as bare cable armouring/sheaths, earth
2132 electrodes, pipes, etc. Measurements taken above or near buried metallic services will
2133 indicate lower resistivity values than actually exists. This can lead to under-designed
2134 earthing systems which may be costly to rectify at the commissioning stage.
2135 Measurement locations must be carefully planned to avoid interference from metallic
2136 structures by consulting service records and, where there remains uncertainty, the use
2137 of scanning methods on site. It is also important that measurements are taken at a
2138 number of different locations (minimum of two) around the site of interest so that any
2139 influenced results become apparent in comparison to unaffected results. Two
2140 orthogonal sets of measurements can also help to indicate an error;
- 2141 (b) interference from stray voltages in the soil or induction from nearby electrical systems
2142 may adversely affect measurement results, normally evident as an unstable reading on
2143 the instrument or unexpectedly high readings. This may be reduced by avoiding test
2144 leads running in parallel with high voltage power lines/cables or near other potential
2145 sources of interference, e.g. electric traction systems.
- 2146 (c) the wenner spacings used must be appropriate for the size of the earthing system and
2147 recommended spacings are provided in BS EN 50522 National Annex C. Spacings that
2148 are too short may not identify the lower layer resistivities which can introduce large
2149 positive or negative error into design calculations;
- 2150 (d) low resistivity soils, especially at long wenner spacings, require relatively small
2151 resistances to be measured at the surface. Instrumentation with an inadequate lower
2152 range may reach its limit and incorrectly indicate higher resistivity values than exist;
- 2153 (e) care must be taken in interpreting the measurement data. If using computer software
2154 tools, it should be remembered that the result is a 'model' of the soil conditions which
2155 is largely determined by automatic curve-fitting routines or user judgement. To increase
2156 confidence it is good practice to 'test' the model by comparing it to other geological
2157 data available for the site and the expected range of resistivity values for the materials
2158 known to be present. Measured resistances of vertical rods installed at the site can also
2159 be compared to calculated values obtained using the soil model to increase confidence.
2160 It should be recognised that the soil resistivity model may need to be refined throughout
2161 the project as more supporting information becomes available.

2162 **7.4.5 Driven Rod Method**

2163 The driven rod method is an alternative to the Wenner Method which is particularly useful in
2164 built-up urban areas where there is inadequate open land to run out test leads. This method
2165 should be used with caution and measures must be taken to avoid the possibility of damage
2166 to buried services, in particular HV cables. Where the absence of buried services cannot be
2167 established, rods must not be driven. An earth rod is driven vertically into the ground and its
2168 earth resistance measured as each section is installed using either of the methods from
2169 Sections 12.5 and 12.6. Using a simple equation (for uniform soil equivalence – refer to ENA
2170 EREC S34) or computer simulation (for multi-layer analysis) the soil resistivity may be deduced
2171 from the measured rod resistance and its length in contact with the soil. This method can be
2172 cost-effective as the rods can be used as part of the earthing installation. Where possible the
2173 results from driven rods at a number of locations around the site should be used together with
2174 any available Wenner Method data to improve confidence in the derived soil resistivity model.

2175 **7.5 Earth Resistance/Impedance Measurements**

2176 **7.5.1 Objective**

2177 The substation earth resistance or impedance is normally measured where practicable on
2178 commissioning of a new substation and subsequently at maintenance intervals. The

2179 measurement will include all earthing components connected at the time of the test and the
2180 result represents the value which is normally multiplied by the ground return current to
2181 determine the EPR. This method may also be used to measure the earth resistance or
2182 impedance of individual electrodes, tower footings or tower line chain impedances. (Refer to
2183 **ENA EREC S34** for details of chain impedance and relevant calculations).

2184 **7.5.2 Method**

2185 The most commonly used method of measuring substation earth resistance or impedance is
2186 the fall-of-potential method and this is described in BS EN 50522 UK National Annex C. It
2187 requires temporary electrodes to be installed in the ground some distance from the substation
2188 and connected back via trailing leads. A standard four-pole earth tester should be used (as
2189 opposed to a three-pole tester – refer to 7.5.4(e) to inject a small test current into the earth
2190 electrode and returned via a remote probe. A voltage gradient is set up around the electrode
2191 and a second probe is used to measure this with respect to the electrode voltage rise. The
2192 resistance is calculated and results are normally presented as a curve of resistance versus
2193 distance from the substation along a particular route. Voltage measurements may be taken
2194 along any route but traverses which are parallel or orthogonal to the current lead are most
2195 commonly used and are more readily interpreted using standard methods.

2196 Most commercially available earth testers use a switched DC square wave signal. Where it is
2197 possible to select a very low switching frequency (below 5 Hz) the measured values will
2198 approach the DC resistance which will be accurate for small earth electrode systems in
2199 medium to high soil resistivity. When higher switching frequencies are used (128 Hz is
2200 common) inductive effects may be evident in the results. Where an appreciable inductive
2201 component is expected and long parallel test leads are used it is advisable to use an AC
2202 waveform, so that mutual coupling between the test lead may be subtracted and a true AC
2203 impedance obtained. Because of the appreciable standing voltage commonly found on live
2204 substation earth electrodes, AC test signals are normally selected to avoid the fundamental
2205 and harmonic frequencies. For the most accurate results, measurements should be taken
2206 using frequencies either side of the power frequency to allow interpolation. Additional guidance
2207 may be found in IEEE 81 (add ref).

2208 It may not be possible to use the fall-of-potential method where no suitable routes exist for the
2209 test lead / probe set up, e.g. in urban or industrial areas. Alternative methods must be used in
2210 these locations as described in Section 7.6.

2211 The substation earth resistance or impedance can also be measured by injecting a current
2212 from a generator connected to a remote substation earthing system via a de-energised power
2213 line. The rise in electrode potential is then measured with respect to another remote earth
2214 electrode such as a telecommunication circuit earth. This method is more costly in terms of
2215 equipment resources and circuit outages; it is rarely used in the UK. Experience has shown
2216 that care must be taken to ensure that there are no unwanted metallic paths between the
2217 substation electrode and either of the reference electrodes as this will divert current and
2218 introduce errors, unless the diverted current can be measured and a correction applied. This
2219 is especially difficult to achieve in urban environments, otherwise this technique would be a
2220 good option where no suitable area for a fall-of-potential measurement exist.

2221 **7.5.3 Interpretation of Results**

2222 Earth resistance or impedance measurement results are normally in the form of a series of
2223 points on a curve which must be interpreted using a mathematical rule or procedure. Care
2224 must be taken in selecting a suitable method and their limitations must be understood. More
2225 detail on the methods available is given in BS EN 50522 UK National Annex C.

2226 **7.5.4 Sources of Error**

2227 There are a number of sources of measurement error which must be considered when planning
2228 and carrying out these measurements. These include, but are not limited to:

2229 (a) influence of buried metallic structures such as bare cable armouring/sheaths, earth
2230 electrodes, pipes, etc. Measurements taken above or near buried metallic services will
2231 generally underestimate the substation resistance. Measurement locations must be
2232 carefully planned to avoid interference from metallic structures by consulting service
2233 records and, where there remains uncertainty, the use of scanning methods on site.
2234 Measurement results that have been influenced by a parallel buried metallic structure
2235 will typically be lower than expected and the resistance curve will be flat. A metallic
2236 structure crossing the measurement traverse at right-angles will result in a depression
2237 in the resistance curve. If interference is suspected the measurement should be
2238 repeated along a different route or an alternative method used;

2239 (b) the distance between the substation and the remote current probe is important to the
2240 accuracy of the measurement. The theoretical recommended distance is between five
2241 and ten times the maximum dimension of the earth electrode with the larger separations
2242 required where there is underlying rock. In practice, where there is insufficient land to
2243 achieve this, the current probe should be located as far away from the substation as
2244 possible. Measurements taken using relatively short distances between the substation
2245 and return electrode may not be accurately interpreted using standard methods and
2246 require analysis using more advanced methods. Typical distances used range from
2247 400 m for standard 33/11 kV Primary Substations up to 1000 m or greater for large
2248 transmission substations or for large combined systems;

2249 (c) interference caused by standing voltage ('noise') on a substation earthing system may
2250 result in standard earth testers failing to produce satisfactory results. This is normally
2251 evident as fluctuating readings, reduced resolution or via a warning/error message.
2252 Typical environments where this may be experienced include transmission substations
2253 (275 kV and 400 kV), railway supply substations or substations supplying large
2254 industrial processes such as arc furnaces or smelters;

2255 (d) results must be interpreted using an appropriate method and compared to calculations.
2256 Where there is significant difference further investigation is required. Interpretation
2257 using the 61.8% Rule or Slope Method may not be appropriate in all circumstances as
2258 they are based on simple assumptions; Detailed analysis using computer software may
2259 give greater accuracy where:

- 2260 • the soil resistivity is non-uniform, i.e. multi layered soils;
- 2261 • where the current return electrode is relatively near to the electrode under test,
2262 e.g. less than five times the size of the earth electrode being tested;
- 2263 • for a large and irregular shaped electrode where the test is taken far away from
2264 the centre of the electrode
- 2265 • where there are known nearby buried metallic objects that may have influenced
2266 the measurements.

2267 (e) use of a three-pole earth tester is acceptable where the resistance of the single lead
2268 connecting the instrument to the electrode is insignificant compared to the electrode
2269 resistance. These instruments are generally suitable only for measuring small electrode
2270 components such as rods or a small group of rods in medium to high resistivity soils.
2271 For larger substations or low resistance electrodes a four-pole instrument is essential
2272 to eliminate the connecting lead resistances which would otherwise introduce a
2273 significant error.

2274 **7.6 Comparative Method of Measuring Earth Resistance**

2275 **7.6.1 Objective**

2276 To measure the earth resistance of small individual electrode components within a large
 2277 interconnected earthing system. This method is most effective where a relatively high
 2278 resistance electrode is measured in comparison to a 'reference earthing system' which has a
 2279 much lower resistance.

2280 **7.6.2 Method**


2281 Two different approaches may be used as follows:

2282 (a) The first method, illustrated in Figure 12.1, requires that the electrode being tested is
 2283 disconnected from the remainder of the substation earthing system, e.g. immediately after
 2284 installation prior to the connection being made or via opening of a test link at existing sites.
 2285 A standard four-pole earth tester may be used with terminals C1 and P1 connected to the
 2286 electrode component being tested. Terminals C2 and P2 are connected to the 'reference
 2287 earth'. Current is circulated around the earth loop containing the electrode and the
 2288 reference earth resistances and the voltage developed across them is measured. Using
 2289 Ohm's Law the series 'loop resistance' is calculated and if the reference earth resistance
 2290 is sufficiently low relative to the electrode resistance the measured value will approach the
 2291 electrode resistance.

2292 (b) The second method, illustrated in Figure 12.2 uses a similar principle but does not require
 2293 disconnection of the electrode. A clamp type meter is placed around the connection to the
 2294 electrode which generates and measures current and voltage in the electrode loop and
 2295 displays the 'loop resistance'. The advantage of this method is that the earth electrodes
 2296 may be tested without disconnection hence avoiding the associated safety risks and the
 2297 need to apply earth disconnection procedures. This is the preferred method for safety and
 2298 facilities should be included in the design to allow access to rods for testing with a clamp
 2299 meter.

2300


2301



2302 **Figure 12.1 — Illustration of Earth Resistance Measurement using the Comparative Method and**
 2303 **a Four-Pole Earth Tester (Test Electrode Disconnected).**

2304

2305



2306
 2307
 2308
 2309
 2310

Figure 12.2 Illustration of Earth Resistance Measurement using the Comparative Method and a Clamp Type Resistance Meter (Test Electrode Connected)

2313

2314 7.6.3 Interpretation of Results

2315 In order to accurately measure an electrode resistance via this method it is necessary to have
 2316 a very low reference earthing system resistance compared to the electrode resistance (10%
 2317 or lower is recommended). It is also necessary to have a reasonable physical separation
 2318 between the electrode and reference earth to reduce mutual coupling through the soil.

2319 If the reference earth resistance is too high the measured result will be significantly higher than
 2320 the Electrode resistance (if it is known it can be subtracted). If the electrode and reference
 2321 earths are too close together then a value lower than the electrode resistance may be
 2322 measured. These errors may be acceptable if the purpose of the measurement is a
 2323 maintenance check where it is only necessary to compare periodic readings with historical
 2324 results to identify unexpected increases, e.g. due to corrosion or theft.

2325 If several different electrodes can be tested with respect to the same reference earth more
 2326 detailed interpretation methods may be developed to increase confidence in the individual
 2327 electrode resistances and in some circumstances allow the reference earth resistance to be
 2328 deduced.

2329 7.6.4 Sources of Error

2330 (a) If the reference earth resistance is too high relative to the electrode resistance the
 2331 measured value may be significantly higher than the electrode resistance. An approximate
 2332 assessment of this may be made by comparing the physical area covered by the respective
 2333 earthing systems, e.g. a rod electrode measured with respect to a large substation earth
 2334 grid would be expected to provide a reasonable accurate resistance for the rod electrode.

2335 (b) Where the test electrode and reference earth are in close proximity to each other there will
 2336 be significant mutual coupling via the soil which may result in an apparently lower reading
 2337 than the true electrode resistance.

2338 (c) The electrode under test may be inadvertently in contact with the reference electrode below
 2339 ground level, or otherwise connected to it. The test current is then circulated around a loop
 2340 and does not represent the intended earth electrode resistance.

2341 (d) This method cannot be directly used to measure the overall substation earth resistance
 2342 which requires the use of the fall-of-potential method described in Section 12.6.

2343


2344 7.7 Earth Connection Resistance Measurements (Equipment Bonding Tests)

2345 7.7.1 Objective

2346 To measure the resistance between a plant item and the main substation earth electrode to
2347 check bonding adequacy. This is essential during commissioning of a new substation to
2348 confirm that each item of plant is effectively connected to the earth electrode system. It is also
2349 useful as an on-going maintenance check and for operational procedures, e.g. post-theft
2350 surveys.

2351 7.7.2 Method

2352 The procedure is based upon the principle of measuring the resistance between a set point (or
2353 points) on the main electrode system and individual items of earthed equipment. A micro-
2354 ohmmeter is used and the connection arrangement is illustrated in Figure 12.3. Measurements
2355 can be taken from one central point (such as the switchgear earth bar) or, to avoid the use of
2356 unduly long leads, once a point is confirmed as being adequately connected, it can be used
2357 as a reference point for the next test and so on.



2358

2359 **Figure 12.3 Connections for Earth Bonding Conductor Resistance Measurements**

2360 To establish that a satisfactory connection exists between the grid and any exposed metalwork
2361 it is necessary to measure in the micro-ohms or milli-ohms range. An injection current of at
2362 least 100 mA is recommended.

2363 The probable path of the injected current must be considered and where the substation uses
2364 a bus-zone protection scheme care must be taken to ensure that any test current does not
2365 produce enough current to operate protection systems.

2366 Special procedures must be adopted when checking bonding between a substation earthing
2367 electrode and a terminal transmission tower. If the bond is ineffective or missing a potential
2368 difference may exist which may pose a shock hazard or damage to a test instrument. Normally
2369 these methods will include checking current flow in the terminal tower legs prior to testing as
2370 a higher proportion of current will flow in a leg with an effective connection to the substation.
2371 This would be supplemented by voltage measurements using suitably insulated probes and
2372 meters and buried electrode location techniques.

2373 7.7.3 Interpretation of Results

2374 The measured resistance between the two connection points will depend on the length, cross-
2375 sectional area, material and number of earth conductors between them. Based on a maximum
2376 distance of 50 m between connection points, a threshold value of 20 mΩ will provide a good
2377 indication of when further investigation is required.

2378 **7.8 Earth Conductor Joint Resistance Measurements**


2379 **7.8.1 Objective**

2380 To measure the resistance across an earth conductor joint to check its electrical integrity. This
2381 is normally performed for every joint created at a new substation prior to backfilling. It is also
2382 carried out during periodic maintenance assessments.

2383 **7.8.2 Method**

2384 The method described uses a micro-ohmmeter to measure electrical resistance and is suitable
2385 for bolted, compression, brazed and welded joints. It does not check the mechanical integrity
2386 of welds or for voids inside a joint.

2387 Most micro-ohmmeters are supplied with standard leads with two sharp pins that can penetrate
2388 through paint or surface corrosion to reach the metal underneath. The first set of leads is
2389 connected to one side of the joint and the second set to the other as illustrated in Figure 12.4.
2390 Ideally, the connectors should be no more than 25 mm either side of the joint. A suitable scale
2391 must be selected on the instrument (normally a minimum current of 10 A is required to measure
2392 in the micro-Ohm range) and an average value recorded after the test polarity has been
2393 reversed.



2394

2395 **Figure 12.4 Connections for Earth Conductor Joint Resistance Measurements**

2396 Joints must also be mechanically robust and survive a firm tap with a steel hammer.

2397 **7.8.3 Interpretation of Results**

2398 The measured resistance should not significantly exceed that of an equivalent length of
2399 conductor without a joint. Joints which exceed this by more than 50% must be remade. Where
2400 different sized tapes are involved, the threshold value used should be that of the smaller tape.

2401 At new installations it is recommended that a few sample joints are made under controlled
2402 conditions (e.g. in a workshop), their resistance measured and the median of these values
2403 used as the benchmark for all other similar joints made at the installation.

2404 **7.9 Earth Potential Measurements**

2405 **7.9.1 Objective**

2406 To measure Touch, Step and Transfer Voltages (e.g. 'Hot Zones') for comparison with
2407 calculated values. These measurements may be required to confirm that the installed design
2408 complies with the main safety limits (see Section 4.4). Advanced techniques and equipment
2409 are required to perform these measurements at live substations and guidance on the different
2410 methods available can be found in IEEE 81 (add ref).

2411 **7.9.2 Method**

2412 Earth potential measurements may be measured by injecting a current into the substation
2413 electrode and returning through a remote electrode via a connecting conductor. The return
2414 electrode may be another substation electrode connected via a de-energised power line or a
2415 temporary test lead and set of probes. Providing the return electrode is located at a large
2416 distance from the substation (relative to the size of the substation electrode) a potential profile
2417 will be set up around the substation proportional to that which would exist during fault
2418 conditions. The voltage between the substation electrode and different points on the surface
2419 can then be measured and related to Touch Voltage. Step Voltage can also be determined
2420 from measurements of the potential difference between points on the surface which are 1 m
2421 apart. In both cases the actual touch voltage can be found by scaling in the ratio of the test
2422 current and fault current.

2423 In a similar way, the potential gradients may be measured around the substation, for example
2424 emanating out from each corner, and equipotential contours derived to provide Hot Zone
2425 information. Measurements may also be carried out to determine the voltage transferred from
2426 a substation electrode to a nearby metallic structure, e.g. a steel pipe or the earthing system
2427 associated with a different electrical system.

2428 **7.9.3 Interpretation of Results**

2429 The measurement results must be interpreted by competent engineers and compared to
2430 calculated values. It is recommended that a series of measurements are taken at a number of
2431 locations around the substation where high touch or step voltages are expected (normally at
2432 the corners or in areas where the electrode mesh is less dense). This will enable the trends in
2433 the voltage gradients to be assessed to identify spurious data points. Where the return
2434 electrode is not located sufficiently far away from the test electrode large errors may be
2435 introduced. These errors may be corrected using a detailed computer model or by averaging
2436 the measurements obtained using different current return electrode locations.

2437 **7.10 Earth Electrode Separation Test**

2438 **7.10.1 Objective**

2439 To assess the electrical separation of two electrodes in the soil by measurement, e.g.
2440 segregated HV and LV electrodes at an 11 kV distribution substation or a substation earth
2441 electrode and a separately earthed fence.

2442 **7.10.2 Method**

2443 This method requires that the earth resistances of the two electrodes (R_1 and R_2) have been
2444 measured separately using the fall-of-potential method described in Section 12.5.

2445 Similar connections are then made as the bonding integrity checks (figure 12.3) and the 'earth
2446 loop' resistance (R_3) of the two electrodes via the ground is measured.

2447 **7.10.3 Interpretation of Results**

2448 If the two electrodes are separated by a large distance then the R_3 will approach the series
2449 resistance of $R_1 + R_2$. Lower measured values of R_3 indicate a degree of conductive coupling
2450 through the soil. Generally, for the purposes of checking satisfactory segregation of earth
2451 electrodes the following test is used: $R_3 > 0.9(R_1 + R_2)$. Values lower than $0.9(R_1 + R_2)$ may
2452 indicate inadequate separation and further investigation is required (refer to Section 9.7.3).

2453 **7.11 Buried Earth Electrode Location**

2454 **7.11.1 Objective**

2455 At older substation sites, whilst an earthing system is in place, a record of its design may not
2456 exist or may be out of date. An earthing record is desirable to ensure that the design is
2457 satisfactory and to assist in the planning of new construction work. The record should include
2458 the position of the electrode, its burial depth, material, size and installation method (e.g. above
2459 ground, in ducts, or buried directly).

2460 Where existing electrode needs to be located within live substations, surface detection
2461 methods are usually the lowest cost option.

2462 **7.11.2 Method**

2463 The most effective surface detection techniques, found by experience are documented below.
2464 This includes commercially available low to medium frequency systems and Ground
2465 Penetrating Radar (high frequency) systems. It should be noted that these methods are subject
2466 to interference from other buried services and often need to be supplemented by trial
2467 excavations.

2468 A low to medium frequency system comprises a transmitter and receiver, working at
2469 frequencies from 50 Hz (detection of live mains cables) to nearly 100 kHz. The transmitter
2470 injects a signal into the earthing system which is to be traced (the “target line”). As this signal
2471 passes through the earth electrodes, it radiates an electric and magnetic field, one or both of
2472 which can be detected and interpreted by coils in the receiver. Basic receivers simply emit an
2473 audio tone as they are passed over the target line. More advanced receivers give information,
2474 such as burial depth and test current magnitude. This feature can sometimes enable one to
2475 distinguish between the target line and others which have erroneously picked up the
2476 transmitter’s signal through coupling.

2477 A ground penetrating radar system, used in conjunction with appropriate analysis software,
2478 can also be used to produce a reasonable graphical image of structures below the surface.
2479 Radar systems detect the dielectric contrast between a target and its surroundings and so are
2480 well suited for detecting conductive, metallic electrodes against soil which is relatively resistive.
2481 They are well suited to drained, high soil resistivity locations. The radar system is usually
2482 guided over the trace area in a grid pattern, with detection results being stored for later analysis
2483 by the computer.

2484 Where neither of the above methods are conclusive, e.g. in areas with a high density of buried
2485 services, selected trial holes may be required.

2486

2487 **8 MAINTENANCE**

2488 **8.1 Introduction**

2489 Earthing systems shall be inspected, maintained and repaired so as to ensure they will operate
2490 in the manner required on an ongoing basis.

2491 **8.1.1 Inspection**

2492 This falls into two main categories:

2493 (a) Visual Inspection

2494 (b) Detailed Physical Examination and Testing

2495 When setting inspection, testing and maintenance regimes for a substation consideration shall
2496 be given to identifying and where necessary rectifying issues arising from:

- 2497 • physical deterioration and damage/theft;
- 2498 • inappropriate installation alterations or third party actions which prejudice the principal of
2499 operation of the earthing system;
- 2500 • inappropriate installation / design;
- 2501 • changes to system operating regimes or construction which alter the magnitude, flow and
2502 / or duration of earth fault current to values outside the original earthing system design
2503 parameters;
- 2504 • magnitude of EPR and how close touch and step potentials are to safety limits.

2505 The frequency of inspection and testing should be set according to EPR, risk of theft, damage,
2506 and deterioration. It may be revised from time to time if circumstances change.

2507 If an extraordinary event occurs (e.g. delayed fault clearance) then additional ad hoc inspection
2508 and testing may be required

2509 **8.1.2 Maintenance and Repairs**

2510 When undertaking repairs or minor alterations to damaged earth conductor and buried
2511 electrode the procedures adopted must take into account:

- 2512 • Broken conductors may operate at elevated voltages even when the rest of the
2513 associated network is operating normally.
- 2514 • The possibility of transient or sustained system earths fault occurring while repairs are
2515 being undertaken.

2516 Inspection, testing and maintenance work must be undertaken in accordance with company
2517 operational and safety procedures. Where required risk assessments and method statements
2518 will be prepared. Inspectors must wear company specified personal protective equipment and
2519 only approach plant and equipment when it is safe to do so. See Sections 8.3 and 8.4 for
2520 further issues.

2521

2522 **8.2 Types of Inspection**

2523 **8.2.1 Introduction**

2524 The main types of inspection may be summarised as:

- 2525 • a frequent basic visual inspection to check there is no visible damage, theft or obvious
2526 impairment of the earthing system;
- 2527 • a less frequent and more detailed visual inspection to review the standard of construction
2528 and condition as well as checking for damage, theft and impairment;
- 2529 • an infrequent more thorough visual inspection combined with testing, measurement and
2530 analysis.

2531 For an open busbar substation typical areas to be inspected include earth connections
2532 associated with:

- 2533 (i) aluminium, steel, concrete and wood structures;
- 2534 (ii) towers, earthed poles and above ground cable connections within or adjacent to
2535 the substation site.
- 2536 (iii) isolator mechanisms, fault-throwing switches, earth switches and control kiosks
2537 including associated surface and buried earth mats;
- 2538 (iv) transformers, reactors, VTs, CVTs, CTs, surge-arresters and arcing horns;
- 2539 (v) transformer neutral links and switches and associated connections to earth either
2540 direct or via earthing resistors, reactors or earthing transformers;
- 2541 (vi) metallic Fencing and gates;
- 2542 (vii) indoor switchgear (if present) including connections to plant, cables, structural steel
2543 work and earth bars.

2544 **8.2.2 Frequent Visual Inspection**

2545 This can form part of a normal routine substation inspection procedure or be a part of the
2546 procedures operation staff conduct when entering a substation. The objective is to frequently
2547 and quickly check for visible damage, theft or obvious impairment of the earthing system.

2548 During routine visual inspections accessible earth connections associated with key items of
2549 electrical plant in the substation should be checked. Procedures such as lifting trench covers
2550 will normally be avoided unless the initial inspection gives cause for concern.

2551 **8.2.3 Infrequent Detailed Visual Inspection**

2552 Before commencing a detailed examination, the substation earthing records should be
2553 checked to confirm they correspond to the actual layout. The inspector should be aware of the
2554 fence earthing arrangement and whether it is independently earthed or bonded to the earth
2555 grid or a mixture of both.

2556 The key items covered in the Frequent Inspection plus all other accessible connections to
2557 plant, circuits and civil infrastructure should be inspected thoroughly. As well as condition, the
2558 standard of construction should be reviewed against present practices and any inadequacies
2559 reported. Checks for damage, theft and impairment of the earthing system should also be
2560 carried out. Visual checks should be carried out on less accessible earthing conductors not
2561 covered in the Frequent Inspection such as those located under trench covers or located in
2562 basements.

2563 The results of all inspections must be documented in accordance with company procedures.

2564 A pre-prepared check list for each site will assist consistent reporting and record keeping.

2565 **8.2.4 Detailed Visual Inspection, Testing and Analysis**

2566 This consists of four related parts:

2567 • A thorough detailed visual inspection and review of the earth connections to all electrical
2568 plant, circuits and civil infrastructure as per 8.2.3

2569 • Carrying out specific testing and measurement of the earthing installation as per 8.2.4.1

2570 • Selecting portions of the buried electrode system for examination via trial holes as per
2571 8.2.4.2

2572 • Analysis and recording of results including review of EPR related issues as per 8.2.4.3

2573

2574 8.2.4.1 Testing

2575 See Section 7 for specific measurement and analysis techniques.

2576 Testing may include:

2577 (i) Measurement of the overall substation earth resistance/impedance value;

2578 (ii) Measuring resistance of:

2579 • Individual earth electrodes

2580 • Rod and plate groups

2581 • Fence earth rods

2582 • Test electrodes (where fitted).

2583 • Surge arrester, CVT and GIS high frequency earths;

2584 (iii) Measurement of soil resistivity;

2585 (iv) Resistance tests across a representative sample of important joints using a micro-
2586 ohmmeter. The value should be recorded and compared with the values
2587 recommended by the manufacturer, or taken for similar joints elsewhere. Any joint
2588 where the resistance value is excessive will require to be broken down, cleaned
2589 and remade, or replaced;

2590 (v) Confirmation of continuity between key items such as transformers, switchgear,
2591 terminal tower(s) etc. and the main substation earth grid using a micro-ohmmeter.
2592 This is especially important for items where corrosion, theft or damage is
2593 considered to have prejudiced the integrity of the connection;

2594 (vi) Confirmation of continuity between adjacent site earthing systems;

2595 (vii) Confirmation of whether metallic fences are isolated from or bonded to the main
2596 substation earth grid by carrying out a separation test;

2597 (viii) For substations fitted with frame leakage earth fault protection checking the integrity
2598 of the segregation between earth zones by testing and/or visual inspection and also
2599 testing across cable terminations where island glands are fitted;

2600 (ix) Measurement of Soil pH value;

- 2601 (x) Tracing of buried electrode if required to update the substation earthing drawing;
2602 (xi) Segregation tests and review of segregation between distribution substation HV
2603 and LV earths. (Refer to Sections 7.10 and 9.7);

2604 8.2.4.2 Selected Excavation and Examination of Buried Earth Electrode

2605 Since the earth electrode system is largely buried, it is impracticable to carry out a detailed
2606 examination of the whole installation. However, it cannot be assumed that the buried electrode
2607 system, once installed will remain in good condition.

2608 Particularly where a substation site is associated with former industrial use such as a coal
2609 power station or foundry which may have produced corrosive material used as landfill there is
2610 enhanced risk of corrosion of buried copper conductor. A similar risk may also arise if material
2611 from such sites is imported to construct a substation. It is recommended that representative
2612 locations be chosen to excavate and expose the buried electrode, in order to check its
2613 condition.

2614 These should include some below ground connections, e.g. an earth rod connection position,
2615 or other locations where the electrode is jointed. Several connections from above ground plant
2616 should be uncovered back to the connection to the buried earth tape/grid, to check their
2617 condition through the layers of chippings and soil. Conductor size should be compared with
2618 records.

2619 Whilst carrying out excavation, the soil pH value should be checked. This should lie between
2620 6.0 and 10.0. For pH values outside these limits, it is probable that corrosion of the copper
2621 conductors/connectors will be evident. In the past, power station ash has been used as
2622 bedding for earth electrodes. This is known to be acidic, and is likely to cause corrosion of the
2623 conductors.

2624 Where tests show the pH value of the soil to be outside the limits, if the copper electrode is
2625 corroded, then repairs or a new electrode system and either some imported soil or an inert
2626 backfill (such as bentonite) is required. If the electrode has limited corrosion, then a soil /
2627 corrosion investigation is necessary to assess the risk of future corrosion and any precautions
2628 necessary. Normally the corrosion rate will be uneven, with severe corrosion in some areas
2629 and none in others. Severely corroded electrodes will need to be replaced, whilst that
2630 elsewhere will need to be monitored and measures taken to limit corrosion in all important
2631 areas.

2632 Should examination of the exposed conductors or connections give cause for concern, then
2633 additional excavations elsewhere on site may be necessary to assess the extent of the
2634 problem.

2635 8.2.4.3 Analysis and Recording of Test Results

2636 Resistance values for the substation, individual electrode groups and for joints should be
2637 recorded and where previous values are available compared to indicate any trend.

2638 The earthing drawing should be updated if required with revised electrode sizes and positions.

2639 Once a new substation earth resistance is obtained it should be used to recalculate the
2640 substation EPR using up to date earth fault current data and earth fault current return paths
2641 (earth wires/cable sheaths etc). Safety voltages and conductor current ratings should be
2642 recalculated and any deficiencies identified.

2643 The presence (or otherwise), values and configuration of any resistances / impedances placed
2644 in high voltage transformer neutrals should be recorded and aligned with those contained in
2645 the company power system model.

2646 Defects should be listed and prioritised for remedial action.

2647 **8.3 Maintenance and Repair of Earthing Systems**

2648 In some cases, earthing related maintenance and repair work will be reactive, following theft
2649 or damage revealed by an inspection.

2650 Before undertaking earthing system repair or measurement work, the responsible person in
2651 charge of the work must familiarise themselves with the site specific risks and consequences
2652 of:

- 2653 • Working on or touching unsound earthing systems;
- 2654 • Open circuiting (even for a short time) earth conductor circuits;
- 2655 • Extending (even temporarily) earthing systems from sites where touch and step potentials
2656 are controlled;
- 2657 • Working on broken earthing conductors;
- 2658 • An earth fault occurring on the system being worked on. For primary substations
2659 supplying extended high voltage rural overhead line networks this can be a relatively
2660 frequent occurrence (e.g. at least once a week). Supervisors should avoid work or testing
2661 being carried out in high risk periods such as during storms or fault switching.

2662 There is risk of serious or fatal electric shock when working on intact and depleted/damaged
2663 earthing systems. The responsible person in charge of any remedial work should be suitably
2664 qualified to undertake this area of work. Network Operators should develop their own
2665 policies/procedures for dealing with depleted earthing systems.

2666 Specialised equipment including insulated rods, shorting leads and conductor clamps are
2667 required to make repairs. PPE including insulated footwear and gloves must be available if
2668 required.

2669 High voltages can appear on earth system conductors even under normal running conditions.
2670 Items requiring particular caution include connections associated with CVTs, transformer
2671 neutrals, underground cable bonding arrangements and connections between main earth grids
2672 and overhead line towers.

2673 Examples of situations requiring remedial work include:

- 2674 • broken or damaged below ground earthing conductors which have been exposed in the
2675 course of excavation work;
- 2676 • broken or damaged bonding conductors on underground cable systems (such as cross-
2677 bonding connections that can be expected to carry significant current under normal
2678 operating conditions);
- 2679 • repairs to/replacement of high resistance earth connections (Para 8.4);
- 2680 • minor alterations to/diversions of earthing systems for construction work;
- 2681 • repairs after theft of earthing conductors (Remedial work on depleted earthing systems is
2682 normally the subject of a bespoke company instruction and is outside the scope of this
2683 document).

2684

2685 **8.4 Procedure for the Remaking Defective Joints or Repairing Conductor Breaks**

2686 **8.4.1 Introduction**

2687 It may be necessary to remake a joint or repair a break on the earth electrode system at a
2688 substation for a number of reasons:

2689 (a) The joint is obviously damaged.

2690 (b) The joint has failed a micro-ohmmeter test.

2691 (c) An earth electrode has been severed.

2692 (d) A minor diversion of the electrode system or other repair work may be proposed.

2693 Should a fault occur during the period when a repair is being carried out, to prevent danger
2694 from a high voltage, which could appear across the joint, precautions must be taken.

2695 The design of the earth grid (if present) may or may not be adequate to eliminate danger to
2696 personnel when touching a bare broken conductor even after a temporary earth continuity
2697 conductor has been applied.

2698 Before carrying out any repairs, the joint or break to be repaired must be short-circuited by
2699 connecting a fully-rated conductor to positions either side of the break or defective joint. This
2700 short must be applied using an approved procedure involving insulated rods.

2701 If company policy so states or any doubt exists the operator shall wear insulating footwear and
2702 gloves designed for electrical application when handling earth conductor to make a permanent
2703 repair.

2704 Whilst carrying out work, the operator should stand within the boundaries of the earth grid, or
2705 immediately above a bare buried earth conductor.

2706 For example, if a terminal tower earth connection is broken, a significant potential difference
2707 may be present between the tower and earth grid. Arcing and current flow will occur when
2708 trying to remake the connection. Insulated rods and approved connectors are required to apply
2709 the initial short-circuit. The repairs, as detailed in the next paragraph, can then be carried out.

2710 Similarly high voltages may appear across open circuited cross bonding conductors on high
2711 voltage underground cable circuits.

2712 **8.4.2 Joint Repair Methods**

2713 (i) Compression Joint – Cannot be repaired, must be replaced.

2714 (ii) Mechanical Connector - Disconnect, clean all contact surfaces, apply a company
2715 approved contact lubricant, reconnect and re-tighten.

2716 (iii) Cold-weld/Exothermic weld Joint - If defective this type of joint must be replaced.

2717 On completion of repair of any joint, having first connected the instrument across the joint, the
2718 temporary earth continuity conductor* should be removed; a micro-ohmmeter resistance test
2719 must then be carried out across the joint.

2720 * Shorting strap

2721 **8.4.3 Flexible Braids**

2722 Flexible bonding braids or laminations should be inspected for signs of fracture and corrosion
2723 and changed as required. A protective compound may be applied to flexible braids where
2724 corrosive conditions exist.

2725 **9 Ground Mounted Distribution Substation Earthing**

2726 **9.1 Introduction**

2727 Whilst the general principles of earthing can be applied to all voltage levels, small (distribution)
2728 substations providing supply to LV networks can present their own additional challenges. The
2729 key earthing related differences between distribution (or 'secondary') substations, and larger
2730 ('primary', or 'grid' substations) include:

- 2731 • high voltage distribution apparatus is often located in densely populated areas in close
2732 proximity to the public;
- 2733 • earth fault clearance times on distribution systems are usually longer;
- 2734 • many older 'legacy' installations do not have the benefit of a comprehensive earth grid
2735 environment, as they rely on metallic sheath cable systems to control touch and step
2736 potentials;
- 2737 • low-voltage earth connections may be combined with HV earthing systems, or in close
2738 proximity to them;
- 2739 • connections from the low voltage distribution system are taken into almost every property;
- 2740 • for new connections distribution network operators have a legal obligation to provide a
2741 low voltage earth terminal to their customers as long as it is safe to do so;
- 2742 • the low voltage system must be earthed such that earth potential rise due to high voltage
2743 earth faults does not cause shock or injury (to installation users, public or staff) or
2744 damage to internal electrical installations, distribution equipment or telecommunication
2745 systems.

2746 The design issues, therefore, can be summarised as: a) achieving safety in and around the
2747 HV:LV substation, and b) ensuring that danger does not arise on the LV system as a
2748 consequence of HV faults.

2749 The design approach outlined in Section 5.6.1 applies equally to distribution substations, and
2750 special considerations are described below.

2751 **9.2 Relocation of Pole Mounted Equipment to Ground Level**

2752 Due to the high EPR that can appear on pole mounted equipment, metallic items must not be
2753 re-located at ground level (e.g. replacing a pole transformer with a small padmount substation)
2754 without appropriate modifications to the earthing system.

2755 Ground mounted substations will introduce a touch potential risk that is absent from pole
2756 mounted installations, and consequently require an electrode system that not only limits EPR,
2757 but controls touch and step voltages to safe limits.

2758 Similarly, care should be exercised if other earthed equipment on the pole (e.g. auto-reclose
2759 relay cabinet) is within reach of those on the ground.

2760 Section 10 describes pole mounted installations in detail. In either case, the decision to
2761 operate with combined HV and LV, or otherwise, must consider the voltage that will be
2762 impressed on the LV system under HV fault conditions (Section 9.5).

2763 **9.3 General design requirements**

2764 In common with any earthing system, the design of any new build substation must satisfy
2765 requirements for EPR, touch/step voltages, transfer voltages, and stress voltages. If major

2766 changes are to be made to an existing substation, the effects of these proposed changes on
2767 the existing earthing system need to be considered. A significant consideration in all cases is
2768 the transfer potential that will be impressed on the LV network under HV fault conditions. See
2769 9.5

2770 **9.3.1 Design Data Requirements**

2771 The data required is similar to that described in Section 5.4, as necessary to determine the
2772 current flow into the electrode system, and the fault duration. These include:

- 2773 1) fault level at the new substation, or at the source (primary);
- 2774 2) resistance of the earthing system at the primary substation (R_a), and at the new
2775 distribution substation (R_b);
- 2776 3) circuit length and cable type(s);
- 2777 4) whether there is any overhead line in the circuit.

2778 For worst case studies, if there is any overhead line, the ground return current (I_{gr}) can be
2779 assumed equal to the earth fault current at the distribution substation (i.e. $I_{gr}\% = 100\%$).

2780 **9.3.2 Conductor and electrode sizing**

2781 Earth conductors at distribution substations will usually connect key items of plant such as
2782 transformer(s), ring main unit / switchgear, and low voltage cabinets. In many 'unit substations'
2783 these items may be supplied with bonding connections in place. These bonds must be sized
2784 as described in 5.5.1; in general they must be sized for the maximum foreseeable earth fault
2785 level. For ASC systems the limited ASC current must not be used (see Section 5.4.5). DNOs
2786 may wish to use the earth fault level at the primary substation, or higher value allowing for
2787 growth and uncertainty, up to the 3-phase fault current.

2788 Electrodes must have sufficient surface area to meet the requirements of Sections 5.4.6 and
2789 5.5.2. The worst case foreseeable 'electrode current' should be used for design purposes, this
2790 may be taken as the maximum earth-fault current at the substation or its source, or the larger
2791 of cross-country fault current or bypass fault current on ASC systems.

2792 Note: If detailed modelling of current distribution is carried out, it will be seen that the 'ground return current', if
2793 calculated using a contribution from a wide area network, will be significantly higher than the local 'electrode current'.
2794 The electrode current or ground return currents may be used for electrode design purposes, providing that
2795 connection to the wider network contribution is reliable. If any doubt exists as to the prolonged integrity of sheath
2796 return paths and/or auxiliary electrode connections, the larger earth fault level (calculated for a zero ohm fault)
2797 should be used.

2798 **9.3.3 Target resistance**

2799 A HV electrode system must be established for the substation, that is of sufficiently low
2800 resistance to ensure reliable protection operation and to limit EPR (and touch/step voltages)
2801 to acceptable levels. The design process in this respect is no different to that outlined in
2802 Section 5.3. The resistance that must be achieved is termed the 'target resistance', and may
2803 be specified with and without contribution from parallel systems. Use of a target resistance for
2804 the substation's earthing system, which ensures compliance with the safety criteria, is useful
2805 as it is a more readily understood parameter that can be achieved and tested by installers.
2806 'Network contribution' is discussed in Section 9.4.3.

2807 For ground mounted substations, traditional custom and practice (permitted by previous
2808 versions of this standard) was to apply a target resistance (before connection to the network)
2809 of 1 ohm. If this could be achieved, it was permissible to combine the HV and LV earthing
2810 systems. No perimeter or grading electrodes were installed in such 'legacy' systems, and often
2811 only one vertical rod or horizontal electrode would be installed. This approach relied heavily

2812 on contributions from lead sheathed cables radiating away from the substation, and often
2813 passing under the operator's position. In this way, these cables provided a degree of potential
2814 grading (thus reducing touch potentials) as well as reducing the overall (combined) earth
2815 resistance of the substation. Experience has shown that this approach is no longer applicable,
2816 particularly given the now widespread use of polymeric (insulated sheath) cables.

2817 Network operators may find that different 'target values' for earth resistance are generally
2818 applicable in different geographical areas, and for overhead or underground networks, and
2819 thus may choose to adopt a 'rule of thumb' to assist designers and other connections providers.
2820 In any case, calculations or measurements sufficient to demonstrate that the installed system
2821 will be safe must be carried out at the design stage. Refer to 9.3.7.

2822 Target resistance values should consider all foreseeable running arrangements or network
2823 configurations, especially if the network is automated or remote controlled. Refer to Section
2824 9.9.

2825 **9.3.4 EPR design limit**

2826 A natural EPR design limit is imposed by a) consideration of transfer voltage onto the LV
2827 systems for combined HV/LV systems, and b) insulation withstand (stress voltage) between
2828 the HV and LV systems for segregated systems. See section 9.5 for more detail regarding
2829 separation distances. These considerations may for example, lead to typical design EPR limits
2830 of 3 kV (or higher, depending on equipment withstand voltage) for segregated systems, and
2831 466 V* for combined systems.

2832 **9.3.5 Calculation of EPR**

2833 The EPR for a distribution substation, for faults at that substation, is calculated in the
2834 conventional manner, i.e. by multiplying the ground return current by the overall (combined)
2835 substation earth resistance.

2836 **9.3.5.1 Factors to consider:**

2837 The ground return current value is influenced by the earth fault current 'split' between the soil
2838 return path and the cable sheath. The impedance of the cable sheath(s) is made up of a 'self
2839 impedance' (fixed), and a 'mutual impedance' that is dependent on a number of factors.

2840 The earth fault current is influenced by the resistance of the earthing system and the
2841 impedance of the cable sheath. The source impedance (primary substation), the resistance
2842 of the primary substation earthing system, and in particular the method of neutral earthing will
2843 have an effect.

2844 For most accuracy, some form of iterative calculation or computer model will be required to
2845 explore the relationship between fault current, EPR, and substation resistance. However, in
2846 any such design there are often other factors or unknowns / variables which may be of more
2847 significance. For this reason it may be sufficient for a design to err on the side of caution by
2848 using a 'zero-ohm' earth fault level (the maximum theoretical fault level at the distribution
2849 substation calculated using zero sequence impedances for the circuit). Fault impedance can
2850 then be introduced only if necessary to achieve an economic or practicable solution.

2851 ENA EREC S34 provides a detailed discussion of EPR calculations and includes worked
2852 examples to assist with the calculation of ground return current.

* This value is 2x the 1 second touch voltage limit of 233 volts, and replaces the previous design figure of 430 Volts.

2853 9.3.5.2 Transfer Potential from source

2854 A second contribution to EPR comes from **Transfer Potential** 'exported' from the source
2855 substation, since any EPR at the source will be conveyed along the cable sheath and will
2856 appear (in part) at the new substation.

2857 Transfer potential need not been considered if there is any overhead line in the circuit, or if the
2858 new substation is not the first on the feeder and transfer potential is known to be of no
2859 significance at previous distribution substations.

2860 In determining the acceptable transfer potential from source, the relevant protection clearance
2861 time at the source should be used in touch/step calculations.

2862 **9.3.6 Step/Touch Potentials at the Substation**

2863 Many network operators or connection providers opt for a 'standard' design of distribution
2864 substation, and it is possible to establish, by modelling or calculation, the step and touch
2865 potentials as a % of EPR for each 'standard' layout. These values are influenced to a small
2866 degree by the depth of rods and the proximity of other earthed metalwork, but for design
2867 purposes can be taken as fixed for each layout. Typical values for touch potential within a
2868 3x3m 'unit substation' that has a perimeter 'grading ring' and corner electrodes are 20-40% of
2869 EPR. A substation built on a fine (and bonded) rebar mesh might present a touch voltage in
2870 the region of 10% or less of EPR.

2871 Substations that employ a single rod electrode, or similar 'legacy' design, are unlikely to limit
2872 touch potentials to less than 75% of EPR away from the electrode, and may have unacceptably
2873 high step potentials (gradients) in the vicinity of the electrode, depending on its depth of burial.
2874 Computer modelling using an appropriate package and soil model will normally be necessary
2875 to demonstrate safety unless the system is simple enough to permit 'first principle' calculations
2876 such as those presented in EREC S34 or other relevant standards.

2877 The appropriate design limits for touch and step potential are given in Table 2 and are
2878 dependent on normal (calculated or worst case) protection operation.

2879 **9.3.7 Simplified approach**

2880 In some cases, a safe system can be achieved without detailed design calculations; DNOs
2881 may wish to instead adopt simple rules in certain geographic areas, provided these rules can
2882 be shown to produce a site with acceptable touch, step and transfer voltages. For example, a
2883 'standard' layout (perhaps consisting of a perimeter electrode and corner rods) might be
2884 appropriate if:

- 2885 a) 11 kV fault current is limited by reactor or resistor, and;
- 2886 b) there is a continuous cable connection to the primary substation, and;
- 2887 c) there is interconnection to the wider (HV and LV) network, and;
- 2888 d) the transfer potential from the Primary Substation is below the permissible touch
2889 voltage (taking into consideration clearance times at the primary);
- 2890 e) there is some 'potential grading' to limit step/touch to 50% or less of EPR (this assumes
2891 that site EPR will not exceed 2x permissible touch voltage limits).

2892 This approach is broadly consistent with that outlined in the design flowchart (Section 5.6.1).

2893

2894 Circumstances where the simplified approach is not appropriate:

2895 More detailed assessments might be needed if one or more of the following apply:

- 2896 a) there is any overhead line in circuit, or other break in the earth-return path;
- 2897 b) the substation is not interconnected to the HV or LV network;
- 2898 c) the secondary winding of the main transformer at the primary substation is solidly
2899 earthed.
- 2900 d) dedicated earth fault protection is not installed;
- 2901 e) the primary substation is a site where the EPR is greater than twice the permissible
2902 touch voltage limit for the applicable fault clearance times and there is a cable
2903 connection giving a transfer voltage consideration.

2904 In difficult circumstances a 'HPR*' but 'Safe (step/touch) voltage' design is allowable by
2905 appropriate use of grading electrode/mesh to control step and touch voltages. Alternatively,
2906 the EPR may be reduced by appropriate means (refer to Section 5.6.3 - Methods to improve
2907 design).

2908 * High (earth) Potential Rise

2909 **9.4 Network and other contributions**

2910 Distribution substations are commonly connected to larger metallic systems which can serve
2911 as an electrode. The following sub-sections describe typical contributions which may be
2912 included in design calculations.

2913 **9.4.1 Additional Electrode**

2914 In many cases it will be possible to supplement the substation's electrode system by laying
2915 bare copper, or a long 'rod nest' beneath incoming or outgoing cables (subject to
2916 separation/segregation where required), although when there are several parties involved in a
2917 project it may not be possible for the substation installer to do so without agreement with the
2918 cable installers (and landowners) at the design stage. Test facilities (e.g. an accessible loop)
2919 may be provided so that the integrity of buried horizontal electrode can be tested periodically.

2920 Electrode contribution such as this may be considered in calculations for EPR, touch/step
2921 voltages, and surface current density. It should not be included in design calculations if it is
2922 vulnerable to theft and/or damage. Suitable precautions should be taken to ensure the integrity
2923 of any such connections if they are safety critical.

2924 **9.4.2 Parallel contributions from interconnected HV and LV networks**

2925 If it is not practicable to achieve a 'safe' (compliant) design based on HV electrode (and
2926 additional electrode) contribution alone, then a reasonable 'parallel' contribution from the HV
2927 network may be included in the design (Section 9.4.3 below). However, this '**network
2928 contribution**' must not be the sole means of earthing and it is recommended that the local
2929 (HV) electrode contribution does not exceed **40 Ohms** or value sufficient to ensure reliable
2930 protection operation. In this way, there is some protection against failure of cable
2931 sheath/glands.

2932 The LV network contribution may also be used if it can be shown that it is safe to combine the
2933 HV and LV networks. Consideration should be given to the magnitude of fault current that will
2934 flow into other (parallel) systems, particularly in the case of solidly earthed HV systems, to
2935 ensure that the thermal ratings of any conductor or cable sheath are not exceeded.

2936 The thermal rating and surface current density requirements of sections 5.5.1 and 5.5.2 should
2937 ideally be satisfied where possible without reliance on network contribution, thus allowing the

2938 earthing system to withstand fault current without damage should the cable sheath/gland
2939 connections fail.

2940 **9.4.3 Ascertaining Network Contribution**

2941 The HV network or LV network, (if applicable), can serve as an effective electrode system, and
2942 will provide a reduction in earth resistance when combined with the substation earth.

2943 The 'Network Contribution' element is difficult to establish accurately at the design stage, and
2944 measurements of the LV and HV network may be necessary to inform the design. However,
2945 due to the relatively routine nature of most 11 kV (or HV) connections, a conservative estimate
2946 is often made to expedite the design process.

2947 The contribution from the network is (for older networks) made up of horizontal electrodes (un-
2948 insulated cable sheaths) and 'point' electrodes at distribution substations.

2949 The cable connected distribution substations (whether connected with polymeric HV cables or
2950 otherwise) can be modelled as a 'ladder network', with cable sheath impedances forming the
2951 series elements, and earth electrode resistances forming the parallel parts. This is termed the
2952 'chain impedance', and is akin to the treatment of metal EHV towers in ENA EREC S34. The
2953 'chain impedance' contribution from the HV network substations falls as distance increases
2954 from the new substation. In practice the substations within a 1-2 km radius are those which
2955 need to be considered.

2956 The 'horizontal electrode' contribution from any lead sheathed or hessian served HV cable
2957 sheaths can be treated in the same way as a buried horizontal conductor (EREC S34). In
2958 practice, each conductor will have an effective length, beyond which no additional contribution
2959 can be assumed. A practical HV network will radiate from a substation in more than one
2960 direction, and a contribution can be assumed from each 'leg' provided their areas of influence
2961 do not overlap. In cases of doubt, these systems should be modelled using appropriate
2962 computer software, or measurements carried out (taking care to use a method appropriate to
2963 the size of the network).

2964 Calculated values for network contribution are often pessimistic in dense urban areas, where
2965 numerous parallel contributions (such as water and gas pipes, building foundations, etc.) may
2966 exist. If this is so, the designer may commission a measurement of network contribution (if
2967 possible), or may use an estimated value for network contribution, or may be able to
2968 demonstrate that the area is a Global Earthing System (GES) – see next section.

2969 [Include reference to worked example here – S34?]

2970 **9.4.4 Global Earthing Systems**

2971 A 'Global Earthing System' (GES), is a system where all equipment is bonded together, and
2972 the ground is saturated with metallic 'electrode contributions' in the form of metallic cable
2973 sheaths or bare conductors laid direct in soil. In such a system, the voltage on the surface of
2974 the soil will rise in sympathy with that of bonded HV steelwork under fault conditions, and the
2975 voltage differences (leading to touch voltage risk) are minimal. The term is often used to
2976 describe dense urban networks where measurements or detailed calculation of network
2977 contribution is not practical. Refer to annex O (informative) in BS EN 50522 for more detail.

2978 Network operators may wish to designate certain geographic areas as 'GES', in which case
2979 they will need to carry out measurements or analysis to demonstrate that the designation is
2980 appropriate. In addition they should carry out calculations to assess the 'target resistance'
2981 required in these areas; this is most easily achieved by assuming a low value of network
2982 contribution and designing an electrode system that is sufficient to satisfy protection operation,
2983 current density and thermal ratings in the absence of this network contribution. A standard

2984 design using perimeter electrode/rebar mesh etc. is usually still warranted for these reasons,
2985 using an appropriate resistance value to ensure safety.

2986 GES networks by definition operate with combined HV/LV earthing. It should be noted that
2987 touch potentials in GES networks can arise from transferred sources that may not be locally
2988 bonded, e.g. cable sheaths bonded to remote systems, metallic gas/water pipes with insulated
2989 covering, **pilot**/communications cables, and HV or LV insulated sheathed cables connected to
2990 metallic plant that is not bonded to the local 'global' earthing system. Such arrangements can
2991 cause 'islands' of higher potential inside a 'GES', and thus the benefits of a GES do not apply.

2992 **9.5 Transfer Potential onto LV network**

2993 **9.5.1 General**

2994 ESQC Regulations (2002) require that danger will not arise on the LV system as a
2995 consequence of HV faults. In practice, this means that the HV and LV earthing systems must
2996 be separated if the HV EPR cannot be limited to the applicable limit.

2997 NOTE: Previously, a design limit of 430 V has been applied, i.e. the HV and LV systems could be combined if the
2998 HV EPR was ≤ 430 V; in practice, this EPR would be impressed on the LV neutral/earth (star point). The voltage
2999 ultimately transferred to a consumer's LV earth terminal would be less than this, and the touch voltage appearing
3000 within an installation would be even lower.

3001 **9.5.2 Touch voltage on LV system as a result of HV faults**

3002 BS EN 50522 Section 6.1 Table 2 introduces the concept of 'F' factors. In order to combine
3003 HV and LV earthing systems, the HV EPR must not exceed $F \times U_{Tp}$, where U_{Tp} is the
3004 acceptable touch voltage as a function of HV fault clearance time.

3005 The 'F' factor described above relates to the percentage of EPR that will appear as a touch
3006 voltage on the LV network; it relates to the potential grading that will occur within an installation,
3007 as well as the decay in exported potential along a multiple earthed neutral conductor. The
3008 resultant touch voltage within the consumer's installation is necessarily subject to a number of
3009 factors beyond the control of any network operator.

3010 It is recommended that in the UK, a value of $F = 2$ is used unless:

- 3011 • The LV neutral/earth conductor is earthed at only one point, and:
- 3012 • The LV supplies only a small system that is isolated from the general mass of earth (e.g.
3013 a metal pillar on a concrete plinth without outgoing circuits).

3014 In such circumstances note (d) of BS EN 50522 Table 2 applies, which states: "*If the PEN or*
3015 *neutral conductor of the low voltage system is connected to earth only at the HV earthing*
3016 *system, the value of F shall be 1.*"

3017 In such circumstances a reduced EPR limit is applicable (e.g. 233 volts for a 1 second fault,
3018 see Table 1) because it must be assumed that the full EPR could appear as a touch voltage.

3019 In practice, for typical arrangements in the UK where $F = 2$, the HV EPR must not exceed 466
3020 volts if the systems are to be combined. This assumes a 1 second fault clearance time. Lower
3021 limits will apply for longer fault durations.

3022 **9.5.3 Stress Voltage**

3023 The Stress Voltage is the voltage across any two points in a substation or connected circuits.
3024 The Stress Voltage Limit relates to the insulation withstand requirement of cables and
3025 equipment.

3026 If HV and LV systems are combined then stress voltage limits are unlikely to be exceeded in
3027 the substation.

3028 For segregated HV and LV systems, stress voltage includes the difference in potential between
3029 the HV and LV earths, and may be assumed equal to the EPR of the substation. Typically this
3030 needs to be considered in the insulation withstand of the LV neutral bushing, LV neutral busbar
3031 supports, and LV cable screen where these are in close proximity to HV steelwork (a value of
3032 3 kV or more is often quoted for modern equipment).

3033 Care is needed if bringing (remotely earthed) LV supplies into such sites, particularly if feeding
3034 into metal equipment cabinets that are earthed to HV steelwork. In such circumstances the
3035 insulation withstand within the equipment should be verified to ensure that that breakdown
3036 between LV phase/neutral/earth and HV steelwork cannot occur internally. Isolation
3037 transformers may be required to ensure that HV and LV systems do not flash across under HV
3038 fault conditions.

3039 Where these criteria are met, the requirements of BS EN 50522 (Table 2) will be achieved.

3040 **9.6 Combined HV and LV earthing**

3041 HV and LV earthing systems will generally be combined if the EPR on HV steelwork does not
3042 exceed LV transfer voltage limits described above (Section 9.5).

3043 In general:

- 3044 • combine HV & LV earths if voltage rise due to an HV or EHV earth fault is safe to apply
3045 to the transformer LV earth;
- 3046 • segregate HV & LV earths if voltage rise on LV transformer earth is unacceptable.

3047 A substation with EPR limited to 466V will usually be suitable for combined earthing if supplying
3048 a PME network*. This limit is subject to the caveats described in Section 9.5.2.

3049 **9.7 Segregated HV and LV earthing**

3050 For segregated earth systems, it is necessary to ensure that the LV electrode system is sited
3051 at sufficient distance from the HV electrode so that the voltage rise on the LV network is
3052 acceptable.

3053 **9.7.1 Separation Distance**

3054 Table 11 below provide an approximate minimum separation distance based on the EPR and
3055 acceptable LV transfer limits. The values are not significantly dependent on soil resistivity
3056 once the EPR is known, although a uniform soil model is assumed.

3057 The tables are calculated for 3x3m substations and 5x5m substations, assuming both have a
3058 perimeter electrode. These are calculated values as given by **EREC S34 Equation P3**. They
3059 have been compared with modelled results (for uniform soil) and the most conservative values
3060 are presented in these tables; this represents the voltage contour furthest from the substation,
3061 such that any LV electrode beyond this distance from the substation boundary will be at or
3062 below the stated V_x figure under HV fault conditions.

3063

3064 **Table 11 - Separation distance (m) from 3x3m substation.**

* A factor of 2 can be assumed for PME networks compliant with ENA ER G12/4, i.e. the voltage appearing at the customer's earth terminal is expected to be no more than 50% of the substation EPR. This paragraph also assumes that HV faults will clear within 1 second.

V_x (V) \ EPR(V)	1000	2000	3000	5000
233	3.0	7.6	12.2	21.5
324	1.8	5.0	8.3	15.0
376	1.4	4.2	7.0	12.7
466	0.8	3.0	5.3	9.9

3065

3066

Table 12 – Separation distance (m) from 5x5m substation.

V_x (V) \ EPR(V)	1000	2000	3000	5000
233	5.0	12.7	20.4	35.8
324	3.0	8.4	13.9	25.0
376	2.3	6.9	11.7	21.2
466	1.4	5.1	8.9	16.6

3067

3068 NOTE: The following voltage limits are tabulated. For other values refer to Table 1:

- 3069 233 V = 1 second touch voltage limit on soil (or EPR limit with F=1);
- 3070 324 V = 162 V x 2, EPR limit applicable to 3 second faults with F=2;
- 3071 376 V = 188 V x 2, EPR limit applicable to 1.5 second faults with F=2;
- 3072 466 V = 233 V x 2, EPR limit applicable to 1 second faults with F=1.

3073

3074 These figures relate to the distance of the voltage contour at its furthest point from the
 3075 substation; in some cases (multiple earthed systems) the first LV neutral/earth electrode may
 3076 be sited inside the appropriate contour, refer to Section 9.7.4 and to worked examples in ENA
 3077 **EREC S34**.

3078 **9.7.2 Transfer voltage to third parties**

3079 For substations that are close to third parties, refer to Section 4.3.3. Consideration must be
 3080 given to railways, pipelines, telecommunications, cable TV, etc. if such utilities pass through
 3081 an area of high potential. The formulae **in EREC S34 (ref xxx)** may be used to provide an
 3082 indication of the EPR that may be transferred to nearby objects.

3083 **9.7.3 Further Considerations**

3084 The precise separation distance to be maintained between the HV and LV earthing systems is
 3085 dependent on the EPR, the soil layer structure, and the physical layout of the earth electrodes.
 3086 If necessary, it should be calculated during the design phase using the methods contained in

3087 **EREC S34** or via detailed simulation and must include the effect of electrodes located away
3088 from the substation (See Section 9.7.4).

3089 For existing substations or during commissioning of a new installation the transfer potential
3090 should be determined by measurement where practicable to confirm the calculated value. A
3091 'Separation Factor' of 0.9 or greater should be achieved (as described in Section 7.10).

3092 **9.7.4 Multiple LV electrodes on segregated systems**

3093 The separation distances above are those relating to the potential contour, such that the LV
3094 electrode(s) is/are sited beyond this. In practice, if these distances cannot be maintained, one
3095 or more electrodes on a multiple earthed neutral (e.g. PME system) may be sited within a
3096 higher voltage contour (but no closer than 3m) provided that the majority of the PME LV
3097 electrodes are sited beyond this. An above ground separation of 2m or more must be
3098 maintained to prevent simultaneous (hand-hand) contact between the systems.

3099 This assumes that the remainder of the LV system as a whole will have a resistance lower
3100 than that of the LV neutral electrode. The LV earthing system will have a 'centre of gravity' that
3101 lies outside the relevant contour, i.e. the transfer voltage will be the weighted average of that
3102 appearing at all LV electrodes. Any design based on these assumptions should be backed up
3103 by a measurement of separation factor for the installed arrangement.

3104 Refer also to **EREC S34** for calculations / worked examples.

3105 This relaxation does not apply to SNE systems or PNB systems where the neutral/earth is
3106 earthed at only one point.

3107 Where calculations based on the local LV electrode (closest to the substation) indicate
3108 impractical separation distances or excessive transfer potentials, the design should be
3109 reviewed and further LV electrodes installed at the end of LV feeder cables, connected via the
3110 neutral earth conductor. To maximise this beneficial effect, they should be located as far away
3111 from the HV electrode as possible and have a lower resistance than the LV electrode at the
3112 substation.

3113 **9.8 Situations where HV/LV systems cannot be segregated**

3114 In some situations it is not possible to segregate HV and LV systems safely without additional
3115 measures. One example is where an LV system exists within a HV system, or there are other
3116 similar physical constraints meaning that systems cannot reasonably be kept apart. Refer to
3117 BS EN 50522.

3118 In such circumstances, consideration should be given to combining the HV and LV systems
3119 and augmenting the electrode system(s) such that EPR and HV-LV transfer voltage is
3120 acceptable. If this is not practical, insulated mats/barriers could be considered in relevant
3121 areas.

3122 If necessary, the building or area could operate with a combined HV/LV system, safely yet with
3123 a high EPR provided all sources of transfer potential into/out of the 'high EPR area' can be
3124 excluded, and touch voltages are managed in and around the building. Refer to guidance on
3125 stress voltage given in Section 9.5.3 above.

3126 **9.9 Practical Considerations**

3127 HV networks are usually capable of being manually, or automatically reconfigured. The
3128 change in 'running arrangements' will affect various parameters including fault level, protection
3129 clearance time, and sheath return current/percentage.

3130 This complication means that a bespoke design for a distribution substation may not be valid
3131 if the running arrangement changes, and therefore the value of detailed design calculations on
3132 a 'dynamic' network is questionable. It is recommended that the design considers all
3133 foreseeable running arrangements, or (for simplicity) makes worst case assumptions regarding
3134 fault level, protection clearance time, and ground return current.

3135 A network operator may wish to adopt or provide a target resistance value (tailored to different
3136 geographic areas and different system earthing/protection scenarios), or other simplification of
3137 these design rules, for these reasons.

3138 **9.10 LV installations near High EPR sites**

3139 LV electrodes (segregated systems) as described above must be clear of the relevant voltage
3140 contour. The consideration also applies to any customer's TT electrode. If necessary the
3141 electrode(s) should be relocated or the shape of the high EPR zone altered by careful
3142 positioning of HV electrodes. In addition, where possible, LV electrode locations should place
3143 them clear of any fallen HV or EHV conductors.

3144 The siting of LV earths must consider zones with elevated potential e.g. some properties close
3145 to high EPR substations or EHV towers may themselves be in an area of high EPR, in which
3146 case provision of an LV earth derived from outside that zone may introduce a touch voltage
3147 risk at the installation, due to the LV earth being a remote earth reference. The arrangement
3148 can also pose a risk to other customers on the LV network if it will permit dangerous voltages
3149 to be impressed on the LV neutral/earth.

3150 Detailed modelling of HV/LV networks may demonstrate that voltage differences are not
3151 significant, due to the influence of the network on the shape of the contours; however such
3152 modelling may not be practicable. If any doubt exists, customers should not be offered an earth
3153 terminal, and no LV network earths shall be located in the area of high EPR. Cables passing
3154 through the area should be ducted or otherwise insulated to limit stress voltage to permissible
3155 limits. Typically a customer will use their own TT earth electrode; however if properties are in
3156 an area where EPR exceeds 1200 V, it is possible that they will experience L-E or N-E
3157 insulation failures in HV or EHV fault conditions; isolation transformers (or careful siting of
3158 HV:LV transformers and electrode systems) may be required; refer to Section 9.11 below, and
3159 to risk assessment case studies given in Section 11.

3160 For PME electrode locations, reference should be made to ENA EREC G12.

3161 **9.11 Supplies to/from High EPR (HPR) sites**

3162 Network supplies into HPR sites invariably need care if the network earth is to remain
3163 segregated from the HPR site earth. In remaining separate, this can introduce touch voltage
3164 risk within the site. It is normally necessary to use a careful combination of bonding and
3165 segregation to ensure that danger does not arise within the site, or on the wider network.
3166 Sheath breaks (insulated glands) or unearthed overhead line sections are often convenient
3167 mechanisms to segregate the earthing systems.

3168 Similar considerations are required for LV supplies derived from HPR sites if these are to
3169 'export' to a wider area. Typically the LV neutral will be earthed outside the contours of highest
3170 potential and will be kept separate from all HPR steelwork in accordance with normal best
3171 practice. It may be necessary to apply ducting or additional insulation to prevent insulation
3172 breakdown and resultant fault current diversion from the HPR site into the wider network.

3173 Refer to **EREC S34** for specific examples, and to Section 11 (Case Studies).

3174 **9.11.1 Special Arrangements**

3175 Where a standard substation earthing arrangement is not applicable, other options may
3176 include:

- 3177 • combining HV & LV earths and managing touch and step potentials by installing an earth
3178 grid to enclose the installation supplied, i.e. effectively producing a large 'equipotential' safe
3179 zone, irrespective of EPR. (The design must take into account any metallic services such
3180 as Telecoms entering or leaving the installation, and is most useful in rural areas);
- 3181 • using an isolation transformer with a separate earthing system where an LV supply has to
3182 be taken outside a HPR substation site with a bonded HV/LV earth system;
- 3183 • use of isolation transformers to provide small capacity LV supplies to HPR ground
3184 mounted substations. E.g. LV supplies to tele-control equipment located within
3185 substations with segregated HV/LV earths (as described in 9.5.3). The (alternative) use
3186 of TT supplies (derived outside the High EPR zone) in such circumstance does not
3187 protect against insulation failure/flashover between the LV phase/neutral conductors and
3188 HV steelwork and could lead to the systems becoming inadvertently combined.
- 3189 • For supplies to mobile phone base stations refer to ENA EREC G78.

3190

3191 **See case study XXX**

3192

3193 **10 Pole Mounted Substation and Equipment Earthing**

3194 This section describes earthing associated with HV Distribution Overhead Line Networks
3195 (excluding Tower lines).

3196 **10.1 General Comments & Assumptions**

3197 Extreme care must be taken when replacing pole mounted equipment with ground mounted
3198 equipment, since any existing earthing system is unlikely to be adequate to limit touch voltages
3199 to safe levels on the new installation.

3200 **10.2 Pole Mounted Transformers**

3201 Pole mounted transformers (PMTs) typically operate with a segregated HV and LV earthing
3202 system* (see section 9.6), and (since the metalwork is out of reach), a high EPR can be
3203 tolerated on the HV steelwork, provided that the LV electrode system is suitably separated
3204 from the HV system. Figure 4 below shows a typical arrangement where the main LV electrode
3205 is at the first pole (i.e. one span away) from the HV pole.

3206 The limiting factor for EPR is usually insulation withstand (stress voltage) on the LV cables,
3207 insulators and bushings at the pole-top; often a design value of 2 kV to 5 kV is assumed,
3208 depending on equipment specifications. A high EPR (with a small electrode system) is often
3209 inevitable on systems supplied by unearthed overhead lines as these do not enjoy the 'return
3210 path' offered by a metallic cable sheath/armour.

3211 The HV electrode must be sited and designed so that it will not present a danger in terms of
3212 hazardous step potentials (voltage gradient) around it. In this respect it is no different to that
3213 of ground mounted systems described above, except that PMTs are often in fields, close to
3214 livestock/animals, and with high ground return currents. Refer to Section 10.3.


3215

3216

* In some network areas, combined HV/LV systems were employed, so this cannot be assumed.

3217

Figure 4 – Typical Pole Mounted transformer earthing arrangement



3218

3219

3220 10.3 Electrode Configuration for Pole Mounted Equipment

3221 The following earth electrode designs assume that the overhead network does not have a
3222 return earth conductor. With this type of system the earth potential rise (EPR) of the local earth
3223 electrode typically will exceed tolerable touch, step and transfer potentials under earth fault
3224 conditions.

3225 Due to the possible hazardous touch potentials, earth conductors above ground shall be
3226 suitably insulated and provided with mechanical protection for a minimum height of 3 m or
3227 above the height of the anti-climbing device, whichever is greater. In addition the main earth
3228 conductor shall be suitably insulated for a minimum of 500 mm below ground level. Where the
3229 separation of electrodes is required guidance will be given in the relevant section.

3230 It is not always reasonably practicable to ensure in all situations that step potentials directly
3231 above an installed earth electrode system remain below permissible limits under earth fault
3232 conditions*. It is generally considered that the probability of an earth fault occurring whilst an
3233 individual happens, by chance, to be walking across the earth electrode at the same time, is
3234 extremely small. Therefore, in most circumstances no special precautions are required.
3235 However, at sensitive locations that are often frequented† by people, particularly children, and
3236 concentrations of livestock in stables or pens for example, precautions may be justified to
3237 eliminate or minimise the risk. This can usually be achieved by careful site selection or at the
3238 time of installation by installing the earth electrode in a direction away from the area of concern,

* This is now less of an issue as step voltage limits have been considerably relaxed compared with previous versions of this specification.

† Refer to BS EN 50341-1 clause 6.2.4.2 for definition

3239 burying the electrode as deep as practicable, and/or fencing the electrode off to prevent
3240 access.

3241 A similar situation also applies to personnel carrying out live operations such as HV drop-out
3242 fuse replacement, live-line tapping at earthed locations or ABSD switching using hook stick
3243 (hot-stick or insulated rods) techniques on earthed poles.

3244 **10.4 HV Earth Electrode Value**

3245 The HV electrode is (usually) the only return path for HV fault current (except relatively rare
3246 instances of cable fed PMTs, or cable terminations), and its resistance must generally be low
3247 enough to operate HV protection within design limits for the network (typically 1 to 1.5 seconds
3248 maximum); electrode resistance values between 10 Ohm and 40 Ohm are often quoted for
3249 design purposes, with lower values providing increased resilience to lightning strikes. (Lower
3250 resistance values will limit the voltage rise on HV steelwork, and can prevent 'back flashover'
3251 across LV bushings resulting from lightning surges, which would otherwise destroy the
3252 transformer winding).

3253 In general the lower the earth electrode resistance the more earth fault current will flow,
3254 resulting in more reliable operation of the circuit protection. Where surge arresters are used it
3255 is generally accepted that 10 Ohm is the preferred maximum value of earth electrode
3256 resistance for satisfactory operation of the arrester. This is in line with the preferred 10 Ohm
3257 value in BS EN 62305 for high frequency lightning earth electrodes.

3258 **10.5 Electrode Arrangement Selection Method**

3259 A common arrangement of rods used for earth electrodes associated with overhead line
3260 equipment is a run of parallel rods interconnected with a horizontal conductor.

3261 Resistance values may be calculated using formulae in **EREC S34**. The calculated values are
3262 considered to be conservative and are based on uniform soil resistivity.

3263 Calculated resistance values for the same rod and soil arrangements, using earthing design
3264 software are approximately 30% lower. Where the ground conditions are difficult, i.e. of high
3265 resistivity and/or rocky, the cost of obtaining the required earth electrode resistance value may
3266 warrant carrying out a site specific design.

3267

3268 **10.6 Earthed Operating Mechanisms Accessible From Ground Level**

3269 This section deals with pole mounted auto-reclosers (PMARs), sectionalisers, and air break
3270 switch disconnectors, that are all capable of being manually operated via an earthed metallic
3271 control box or switch mechanism. It is important to note that where a low voltage supply is
3272 required for control circuits, the supply should be derived from a dedicated transformer whose
3273 LV neutral is earthed directly to the installation's main HV earth conductor.

3274 There are several methods of minimising the risk from possibly hazardous touch and step
3275 potentials at such installations. In selecting the most appropriate method due account should
3276 be taken of the nature of the site, the accessibility of the equipment to third parties and the
3277 EPR level under fault conditions.

3278 (1) Use of wireless remote control for a unit mounted on the pole out of reach from ground
3279 level. With this method, an HV earth electrode system may be required where surge
3280 arresters are fitted or where the manufacturer of the equipment specifies. Where
3281 equipment is unearthed its mounting height shall comply with the relevant regulations.

3282 (2) Place the control box out of reach from ground level, access being via an insulated
3283 ladder. Again, with this method an HV earth electrode system may be required where
3284 surge arresters are fitted or where the manufacturer of the equipment specifies.
3285 Where equipment is unearthed its mounting height shall comply with the relevant
3286 regulations.

3287 Install an operator's earth mat and grading conductors to help provide an equipotential
3288 zone for the operator. Figure 5 and Figure 7 show an example of how this may be
3289 achieved. Whilst this minimises the hazards for the operator it requires that the
3290 installation be carried out with great diligence. It is also important that the future
3291 integrity of the earth electrode is ensured. Misplacement of the earth electrode
3292 conductors can result in the operator being exposed to hazardous touch and step
3293 potentials. Consideration needs to be given to the selection of the site prior to
3294 installation to ensure that the required earth electrode configuration can be installed
3295 correctly, and maintained adequately into the future. Use of suitable personal
3296 protective equipment for switching operations may also be considered as an
3297 additional risk control measure; dielectric (insulated) footwear rated at >7 kV is now
3298 commonly used to protect operators against step potentials when stepping on/off the
3299 platform.

3300 (3) Where mechanical damage is likely, for example in farmland, protective measures
3301 need to be considered to ensure the integrity of the earth electrode and the earth mat.
3302 An example would be to install and fix the earth mat on or in a raft of concrete or fence
3303 off the area surrounding the earth mat.

3304 The use of grading conductors to minimise step potentials in the immediate vicinity of the
3305 operator's earth mat may prove impractical in some circumstances, particularly where there is
3306 a danger of them being damaged by ploughing. Burying the grading conductors at a greater
3307 depth will significantly reduce their effectiveness. Keeping step potentials within tolerable limits
3308 can be extremely difficult and in some case impracticable. In such circumstances alternative
3309 mitigation should be considered.

3310 Factors such as, soil structure, operating voltage, type of HV system earthing (solid or
3311 resistance) and system impedance all have an effect on the value of step and touch potentials
3312 created around the earth electrode, whereas protection clearance times will have a bearing in
3313 determining the tolerable touch and step potential limits. At some sites it may be prudent to
3314 restrict access to the control box, for example by use of insulating barriers or fences, so that it


3315 is not possible for third parties to touch the control box and where operators can only touch the
3316 control box when standing on the earth mat.

3317 It should be noted that burying the operator's earth mat will increase the touch potential
3318 between the control box and the surface of the ground above the earth mat; the greater the
3319 depth of the mat, the greater the potential difference between the soil surface above the mat
3320 and the control box. The hazard this presents can be managed by covering the mat with a
3321 high resistivity material which will increase the impedance path between the hands and feet.
3322 Burying the mat will also have the effect of reducing the step potentials for an operator stepping
3323 off the mat. However, the prime concern is to minimise the touch potentials as these are
3324 considered to be more hazardous than step potentials. Where the mat is buried the touch
3325 potential and the hazard it presents will be site specific, being dependent upon the actual EPR
3326 and the protection clearance times for the given site, therefore a site specific design is
3327 recommended. The surface mat shown in Figure 5 results in negligible touch potentials for the
3328 operator standing on the mat, irrespective of the EPR.

3329 In all cases it is an option to use control measures to mitigate risk if a company deems this is
3330 the most appropriate solution in the circumstances.

3331

3332



NOTE: This arrangement does not exclude the use of a portable earth mat.


Figure 5 — Earthing Arrangement for a PMAR with Ground Level Control Box.

3333

3334

3335

3336



3337

Figure 6 — Alternative Earthing Arrangement for a PMAR with Ground Level Control Box.

3338

3339 **10.7 Air Break Switch Disconnect (ABSD) with an isolated operating mechanism**

3340 There are several methods of controlling hazardous touch and step potentials, at pole mounted
3341 ABSDs.

3342 Install an insulated rod operated ABSD at high level that does not require an earth electrode.
3343 Where equipment is unearthed its mounting height shall comply with the relevant regulations.
3344 This option removes the risk of the operator being exposed to the hazard of touch and step
3345 potentials that could occur under certain earth fault conditions when adopting method 2 below.

3346 (1) Install an ABSD that is operated manually from ground level with a separate HV earth
3347 electrode and operator's earth mat. This approach relies on effective separation of
3348 the HV earth electrode that connects the HV steelwork to earth, and the operator's
3349 earth mat connected to the operating handle. This arrangement is typical of existing
3350 earthed ABSD equipment found on rural overhead line distribution networks.

3351 Separation is achieved by placing the HV earth electrode a minimum of 5m away from the
3352 base of the operator's earth mat using insulated earth conductor from the electrode to the HV
3353 steel work, and by insulating the operating handle from the switch mechanism using an
3354 insulating insert in the operating rod. The top of the insert needs to be a minimum of 3m from
3355 ground level when in its lowest position. The operating handle needs to be connected to an
3356 earth mat positioned where the operator will stand to operate the handle. If the earth mat is
3357 installed such that it is visible the operator can verify its existence and its connection to the
3358 handle prior to operating the handle. The continuing effective segregation of the HV earth
3359 electrode and the operator's earth mat is the most important aspect of the way in which this
3360 arrangement seeks to control the touch and step potentials around the operator's earth mat
3361 position. To minimise the possibility of contact between the buried insulated earth conductor
3362 and the surrounding soil, should the earth conductor's insulation fail, the conductor could be
3363 installed in plastic ducting.

3364 Where mechanical damage is possible, for example in farmland, protective measures may
3365 need to be considered to ensure the integrity of the earth electrode and the earth mat. An
3366 example would be to install and fix the earth mat on or in a raft of concrete or fence off the
3367 area surrounding the earth mat using non-conducting fencing.

3368 Under earth fault conditions the HV earth electrode will rise in potential with respect to remote
3369 earth. A potential gradient will be produced around the electrode; the potentials being highest
3370 immediately above the electrode and reducing rapidly with distance. The earth mat will be
3371 located within the potential gradient surrounding the HV earth electrode, but due to the
3372 separation distance of 5m the potential at that point with respect to remote earth will be
3373 relatively small. The surface level earth mat for the operating handle and the handle itself will
3374 rise in potential but there will be effectively no potential difference between the mat and handle.

3375 Under earth fault conditions, assuming the correct separation distance between the HV earth
3376 electrode and the operating handle earth mat, should the operator have one foot on the mat
3377 and one off the mat, touch and step potentials surrounding the earth mat should not exceed
3378 tolerable limits. However, there is a risk of hazardous touch and step potentials arising if the
3379 HV earth electrode short circuits to the operating handle earth mat. The risk of such a short
3380 circuit occurring is extremely small provided that the earth installation is correctly installed,
3381 inspected and maintained.

3382 The actual size and shape of the earth mat shall be such as to ensure that the operator will be
3383 standing towards its centre whilst operating the handle. Notwithstanding this requirement the
3384 minimum size of earth mat should be 1 m by 1 m. Due consideration needs to be taken of the
3385 type of handle, whether it is a two handed or single handed operation and whether the operator
3386 may be left or right handed. A purpose made mat is recommended in preference to a mat

3387 formed on site out of bare conductor, as this eliminates problems of variation in shape and size
3388 that can occur with the latter. Where a buried earth mat is used, the maximum depth of the
3389 mat should be no greater than 300 mm.

3390 Under normal earth fault conditions the touch potential for both buried and surface
3391 mounted scenarios will be negligible. When deciding between the use of a buried
3392 earth mat and a surface mounted mat the following issues shall be considered:

3393 • A surface mounted mat will allow the operator to visually confirm both the
3394 position of the earth mat relative to the handle and also the integrity of the
3395 connection between the earth mat and the handle.

3396 • A surface mounted mat will minimise any touch potentials between the soil
3397 surface on the mat and the handle, both under normal earth fault conditions
3398 and under second fault conditions where the handle and the earth mat become
3399 energised although this scenario should be less likely because effective
3400 segregation can be visually confirmed before operation.

3401 • Conversely a surface mounted mat will maximise the step potential around the
3402 mat although this will only be an issue if the mat and handle become energised
3403 under a second fault scenario.

3404 • A buried earth mat will not allow the operator to visually confirm either its
3405 position relative to the handle, or the integrity of its physical connection to the
3406 handle before operation.


3407 • Burying the earth mat will increase the value of any touch potential between
3408 the handle and the soil above the earth mat, this potential will increase with
3409 depth.

3410 • To maintain the same effective soil surface area with a buried earth mat for
3411 the operator to stand on and minimise any resulting touch potentials requires
3412 a significantly larger mat than for a surface mounted mat.

3413 • Where a second fault occurs that energises the operating handle and earth
3414 mat, with a buried earth mat the touch potential could exceed tolerable levels.

3415 • Conversely burying the mat will have the effect of reducing the step potentials
3416 under such conditions for an operator stepping off the mat.

3417 The use of suitably rated PPE in these situations would assist in minimising the risk of exposure
3418 to possibly hazardous potentials.



3419

3420

Figure 7 - Recommended Earthing Arrangement for an ABSD.

3421 **10.8 Surge Arresters**

3422 The preferred value for the surge arrester earth electrode resistance is 10 Ohm or less. Ideally
 3423 this electrode system should be installed as close to the base of the pole as possible. However,
 3424 for some locations where it may be necessary for an operator to carry out switching operations
 3425 on the HV networks at that pole this may create unacceptable step potential hazards. In such
 3426 cases the HV earth electrode should be installed away from the pole at a location where the
 3427 step potential is calculated to be safe (typically 5m) for the operator to stand when carrying out
 3428 any switching operations, see section 15.8. It is preferable to have a small number of deep
 3429 earth rods rather than many shallow rods or plain horizontal conductor. The earth conductor
 3430 connecting the base of the surge arresters to the earth electrode system should be as straight
 3431 as possible, having as few bends in as is practicable. Refer to Section 6.14 for further details.

3432 Where other HV equipment is situated on the same pole and requires an earth electrode, only
 3433 one HV earth electrode needs to be installed*. The preference is to install an earth conductor
 3434 directly from the surge arresters to the buried HV earth electrode, and then connect the earths
 3435 of the other items of HV equipment to it on the pole. At sites where switching may take place
 3436 the earth lead should be insulated to the first earth rod which should be a minimum of 5m from
 3437 the operating mat for an ABSD or 5m from the operating position for equipment that requires
 3438 the use of hot-sticks or insulated rods. Additional protection may be achieved by placing the
 3439 earth lead in ducting to that point.

3440 * Note: This practice differs for that in substations as described in Section 6.14, where separate power frequency
 3441 and high frequency earths are required.

3442 **10.9 Cable Terminations**

3443 Typically, cable terminations on poles are associated with surge arresters or other HV
 3444 equipment, in which case the cable sheath or screen is connected directly to the surge arrester

3445 or HV equipment main earth conductor. In the absence of surge arresters or other earthed HV
3446 equipment the cable will require the installation of an earth electrode.

3447 **10.10 Operations at Earthed Equipment Locations**

3448 At earthed installations fed via overhead line systems, it is essential to have robust operational
3449 procedures to minimise the risk from the possible hazards associated with the high rise of earth
3450 potential under earth fault conditions. It should be noted that the risk increases during live fault
3451 switching operations. It is beyond the scope of this document to detail such procedures but
3452 consideration should be given to the following points.

3453 Earth systems are usually designed to minimise hazards under main protection operation.
3454 They are not designed, unless specifically required, to minimise hazards under secondary or
3455 backup protection conditions. This is an important point to note when developing fault switching
3456 operational procedures. Temporarily disabling parts of the protection system, reconfiguring the
3457 network, or raising protection settings to aid in fault location during fault switching can give rise
3458 to touch, step and transfer potentials of a duration that the associated earth systems have not
3459 been designed to take account of.

3460 Precautions shall be taken, by virtue of the equipment design and earthing arrangements to
3461 minimise any touch and step potential hazards. For example, where rod operated (insulated
3462 hot sticks) equipment is used, the simplest way of minimising hazards from touch and step
3463 potentials is by, where practicable, placing the earthing electrode, not serving as grading
3464 conductors, away from the position where the operator will be standing. Where several people
3465 are present during operations, any person not actively carrying out operations should stand
3466 well clear of the installed earth electrode.

3467 **10.11 Installation**

3468 The following points should be considered when installing an earth electrode system for
3469 overhead line equipment:

- 3470 (1) Materials and jointing methods shall comply with the requirements of BS 7430.
- 3471 (2) Installation teams should have a basic understanding of the functions of an earth system,
3472 and should carry out installations to a detailed specification.
- 3473 (3) Typically, installing a horizontal earth electrode system at a greater depth than 500mm
3474 will not have any significant effect on reducing the earth electrode's resistance value.
3475 However, it is recommended that the electrode is buried as deep as is practically possible
3476 to minimise surface potentials and the possibility of mechanical damage. Where
3477 ploughing is a concern the electrode should be buried at a minimum depth of 1m.
- 3478 (4) Ensure maximum separation is achieved on the pole between HV earth conductors and
3479 ABSD handle earth mat conductors.
- 3480 (5) It is recommended that a test point is made available for future connection of an earth
3481 tester above ground so that the earth electrode resistance can be measured. This test
3482 point should be installed and constructed so as to prevent unauthorised access, and on
3483 ABSD's prevent possible flashover to the operator's handle and associated earth mat.
- 3484 (6) Welded, brazed or compression connections are preferable to bolted connections for
3485 underground joints.
- 3486 (7) Corrosive materials and high resistivity materials such as sand should not be used as a
3487 backfill immediately around the electrode.
- 3488 (8) The earth resistance of the installed electrode should be measured and recorded.

3489 (9) Where a buried operator's earth mat has been installed, the mat should have two
3490 connections made to the operating handle.

3491 **10.12 Inspection & Maintenance of Earth Installations**

3492 **10.12.1 Items to Inspect**

3493 During routine line inspections it is recommended that the following items are visually
3494 inspected and their condition recorded, with any defects being rectified in a timely manner:

- 3495 (1) ABSD earth mat and connection to operating handle.
- 3496 (2) Separation of HV and operator's handle earth on an ABSD.
- 3497 (3) Separation of HV and LV earth conductors on the pole.
- 3498 (4) Check that the anti-climbing device does not compromise the separation between the
3499 HV earth conductor and the operating handle.
- 3500 (5) Insulation of HV and LV earth conductors.
- 3501 (6) Mechanical protection of HV and LV earth conductors.
- 3502 (7) Bonding of plant and equipment.
- 3503 (8) State of connections, including any test point.
- 3504 (9) Signs of possible mechanical damage to earth electrode and buried earth mats.

3505 **10.12.2 Items to Examine**

3506 Periodically examine a random sample of buried earth electrodes and buried ABSD handle
3507 earth mats, and rectify any defects found. The examination should check for the following:

- 3508 (1) position of earth mat and electrode locations relative to ABSD handle and operator's
3509 position;
- 3510 (2) insulating insert in the ABSD operating rod;
- 3511 (3) state of underground connections;
- 3512 (4) state of earth electrode components, particularly galvanised steel rods;
- 3513 (5) state of insulation on underground earth conductors where separation of electrodes is
3514 required.

3515 NOTE: When carrying out this work protective measures shall be taken to ensure the safety of personnel during
3516 fault conditions.

3517 The results of the examinations can then be used to assist in developing ongoing inspection
3518 and maintenance policy, and procedures.

3519 **10.12.3 Items to Test**

- 3520 (1) Periodically test the earth electrode resistance. For the relatively small earth systems
3521 typically associated with overhead line equipment, a small 3 terminal earth tester is
3522 adequate. The test should be carried out in accordance with the manufacturer's
3523 instructions.
- 3524 (2) Regularly test the continuity between operating handle and the operator's earth mat.

3525 (3) Regularly test the continuity of buried earth mats.

3526 (4) Periodically test a random sample of insulating inserts used in ABSD operating
3527 mechanisms.

3528 Important: When carrying out these measurements the equipment should be made dead or
3529 where this is not practicable a risk assessment should be carried out and suitable test
3530 procedures should be adopted which safeguard the operator from any rise of earth potential.
3531 Such procedures may for example include the use of insulating gloves and boots, mats and /
3532 or fully insulated test equipment.

3533

3534

3535


3536

3537 11 Case studies / examples

3538 11.1 Risk assessment – house near substation

3539

3540 This case study concerns a house that has been built close to a primary substation. The EPR
3541 at the substation in this case is 3kV, and historical data suggests that significant EPR events
3542 may occur up to 8 times per year on average (due to a combination of local and remote faults).
3543 Computer modelling / calculations show that the ground potential rise at the property is 1596
3544 volts.



3545

3546 The house LV earth is assumed to be derived from a remote source (e.g. segregated earthing
3547 at the distribution substation, located some distance from the primary substation). The worst
3548 case assumption is that the house earthing system is connected to a remote (zero volt)
3549 reference.

3550 Under HV/EHV fault conditions the voltage on the soil around the house will rise, leading to
3551 touch potential risk in and around the dwelling. Various scenarios should be considered; this
3552 case study looks at the risk outside the property when an occupant is using an outside tap
3553 (bonded to the LV earth). This is one of the most significant risks because the occupant may
3554 be standing on soil, and may be barefoot, meaning that the resistance of the 'accidental circuit'
3555 will be low. The maximum touch voltage that will occur is 1596 V and this will remain for the
3556 duration of each fault (1.5 seconds).

3557 For barefoot conditions, the maximum permissible touch voltage (1.5 seconds) is 68 volts. This
3558 'deterministic limit' is based on the C2 curve from IEC 60479-1 and the body impedance model
3559 for 95% of the population, i.e. the same criteria used in the examples in BS EN 50522.

3560 If the faults clear in 0.5 seconds, the deterministic limit (U_{TP}) would be 166 volts.

3561 In either case, the touch potential (tap-to-soil) is therefore above the C2 curve, and places the
3562 fibrillation risk between 50% and 100%. For initial analysis therefore, **P_{FB} may be assumed
3563 to be 1** (more detailed analysis shows the body current to be around 2745 mA, which is well
3564 into the AC-4 region of IEC 60479-1 Figure 20, i.e. "Probability of ventricular fibrillation above
3565 50%".

3566 P_F relates to the probability of fault. For the purposes of this analysis it may be taken as equal
3567 to F , where F is the number of significant earth faults in a year.

3568 The probability of exposure (P_E) relates to the time that an individual may be exposed to risk.
3569 The most significant, and obvious risk relates to contact with the outside tap. It is assumed

3570 that the tap is used twice per week, and that each use produces two contacts for 4 seconds
 3571 as the tap is turned on and off. The exposure is calculated as:

3572 $P_E = 52 * 2 * 4 \text{ (seconds)} / (365 * 24 * 60 * 60 \text{ seconds/year})$

3573 $P_E = 1.32 \times 10^{-5} \text{ y}^{-1}$

3574 The individual risk (IR) is calculated using the formula:

3575
$$IR = f_n * P_E * P_{FB}$$

3576 where

3577 f_n = frequency of significant EPR events, on average per year

3578 P_{FB} = probability of heart fibrillation

3579 P_E = probability of exposure

3580 Thus:

Defect	P_F	P_{FB}	P_E	Risk	Remedial action
Close proximity to substation with High EPR	8	1	1.32×10^{-5}	1.06×10^{-4} per person per year	Required (IR > 1 in 1 million per person per year)

3581
 3582 The risk assessment process should consider all risk scenarios, and the overall risk is the sum
 3583 of these. At this particular property it is possible to demonstrate that (due to a combination of
 3584 equipotential bonding and dry floor coverings) a significant touch voltage will not appear in the
 3585 property, so internal risk may be taken as 0.

3586 In conclusion, in this example the risk to an individual exceeds the broadly acceptable
 3587 threshold of 1×10^{-6} pppy, and falls into the ALARP region. This simplified analysis would
 3588 suggest therefore that mitigation is required.

3589 The justifiable spend is calculated according to the loss of life that could occur during the
 3590 lifetime of the installation. The latest 'value for the prevention of a fatality' figure should be used
 3591 based on HSE guidelines [R2P2], and is currently £1M:

3592 Expected lifetime of installation: 100 years

3593 Fatalities in 100 years: $1.06 \times 10^{-4} \times 100 = 0.0106$

3594 Number of individuals (e.g. other properties) exposed to same risk: 10

3595 Justifiable spend = $\text{£}1,000,000 \times 0.0106 \times 10 = \text{£}106,000$

3596 Therefore if the cost of reducing risk to broadly acceptable levels is less than this, mitigation
 3597 of the hazard should be carried out. If only 10 properties are affected, and if only the outside
 3598 tap is an issue, mitigation could include installation of insulated inserts in pipework, installation
 3599 of a local electrode/earthing system for the tap, or alterations to the LV supply arrangements.
 3600 More conventional alterations to the substation earthing system, EPR, or fault rates should
 3601 also be considered. Modifications to customer property must also consider the likelihood that

3602 they may become altered or compromised as they are beyond the control of the network
3603 operator.

3604 Before calculating the justifiable spend, any 'worst case' assumptions should be revisited.
3605 Fault rates and EPRs will have a 'distribution function' typically a poisson distribution, but it is
3606 unlikely that sufficient data will be available to allow a full probabilistic assessment. Instead, it
3607 may be necessary to more accurately determine the number of significant EPR events,
3608 perhaps by measurements / logging over a prolonged period.

3609 Another significant assumption in the analysis above is that the full voltage (1596 V) appears
3610 as a touch voltage. In reality, the LV neutral/earth, and pipework may be in contact with soil
3611 close to the individual and may therefore rise in potential in sympathy with the substation
3612 earthing system. The result could be a much reduced voltage difference (touch voltage)
3613 between tap and soil.

3614 As an example, if measurements show that in fact the significant fault rate is 1 per year, and
3615 each produces a lower (measured) touch voltage at the property than modelled (such that
3616 maximum $P_{FB} = 0.5$, say), the resultant individual risk would be:

3617 $IR = 1 \times 0.5 \times 1.06 \times 10^{-4} = 5.3 \times 10^{-5}$.

3618 If there is robust data to justify it, a further reduction factor can be applied by looking at the
3619 relationship between exposure and fault. If for example, the tap is only used barefoot on dry
3620 sunny days, it may be that the fault rate is lower on those days. A 'correlation factor' may be
3621 applied to account for this. In the example above, if the fault rate on dry days is 1/10th that for
3622 the rest of the year, a factor of 0.1 may be applied to $P_E * P_{FB}$, giving an overall risk of $5.3 \times$
3623 10^{-6} . This is still not 'acceptable' but the justifiable spend comes down to £5,300. If the risk
3624 cannot be significantly reduced for this amount, the network operator may be able to justify the
3625 decision to do nothing.

3626 This case study considers only one aspect of overall risk. All similar scenarios should be
3627 considered (e.g. risk inside the property, if any) and an overall risk calculated by summing the
3628 individual risks from each scenario. In this case, studies inside the property (considering
3629 flooring resistance) show that there is no likelihood of fibrillation for typical domestic floor
3630 coverings (carpet, wood, dry tiles, etc.), but some risk may exist in bare concrete or wet areas.

3631 This study considers only fibrillation risk. Injuries from minor shocks (e.g. falls etc.) have not
3632 been considered. A tailored approach may be required for different circumstances, e.g.
3633 nurseries, nursing homes, hospitals, etc.

3634 [11] HSE, Reducing Risk Protecting People, 2001

3635

3636 11.2 LV Supply into HOT (HPR) site

3637

3638 This case study considers the provision of an LV supply into a transmission substation with
3639 an EPR which cannot safely be carried outside the substation boundary (i.e.the EPR
3640 exceeds 2 x safe step and touch voltage thresholds, and/or the substation is declared 'HOT').

3641

3642 The following parameters apply:

3643

EPR	3 kV
-----	------


Protection clearance time	0.2 seconds
---------------------------	-------------

3644
 3645 The substation is in a suburban location with a local underground LV network and mixed
 3646 overhead / underground 11kV cable system. The LV network supplies nearby properties and
 3647 remains outside the 'HOT' zone (650V) which is calculated to extend 150m from the site.
 3648
 3649 A 100A (3 phase) LV supply has been requested by the substation operator, this is to serve
 3650 as a backup to local site supply transformers.

3651 The EPR exceeds that which can safely be imposed on the LV network under fault conditions.
 3652 Therefore, taking an ordinary LV supply into the site from the nearby network is not an option.
 3653 (The LV neutral/earth would invariably become combined with the substation earthing).

3654 The options available to the DNO include those listed below. The merits/disadvantages of each
 3655 approach are discussed:

Option	Merits / Disadvantages
11kV cable taken to local transformer / RMU located on transmission site	<p>The 11kV system can be assumed to be remotely earthed and may therefore adopt a close-to-zero voltage rise under transmission EPR events. If the cable is taken onto the site, its sheath insulation could puncture and a high EPR could be exported to the 11kV system.</p> <p>To avoid this, the cable must be ducted within the highest voltage contours (dependent on its sheath withstand voltage). Extending ducting to the 2kV contour is a relatively common practice to avoid this.</p> <p>Any such cable connection into a 'HOT' site requires extreme care with the earthing of the RMU/Transformer or unit substation, as the earthing systems for the 11kV cable must not be combined with site earths. It is often most practical to earth the transformer HV and LV earths to the site earth, but to introduce an insulated gland (sheath break) in the 11kV cable(s) where they enter the plant. This can cause problems a) touch voltages between cable sheath and local steelwork, b) no metallic return for 11kV faults beyond the break, requiring the substation earth to be able to limit 11kV EPR and of sufficiently low resistance to operate 11kV protection, and c) operational issues if RMU earth is applied, since the 11kV cable cores will become connected to the local site earth. This could create a hazard for staff working on the cable or elsewhere on the 11kV network unless specific operational practices are adopted.</p>


Option	Merits / Disadvantages
<p>11kV overhead line supply to site, with pole mounted or ground mounted transformer</p> 	<p>An 11kV supply to site, if via 3-wire (unearthed) overhead construction is a simple and effective solution to the issues described above. The OHL can effectively be carried direct into the site, where it can supply a ground mounted transformer or pole mounted transformer. For both arrangements, the transformer HV and LV earths can be combined and connected to the site earth. A 3kV EPR on the site earth is unlikely to initiate flashover between the 11kV phases and steelwork, or between any short 11kV cable sheath-to-cores, although this possibility should be considered in extreme EPR situations. (Similar insulation breakdown could occur internal to the transformer if the casing is elevated above phase voltages). Care should be taken with operational earth positions and procedures.</p> <p>The disadvantage of this method is that the supply may be more vulnerable than underground supplies and consequently might be unacceptable where a resilient supply is necessary.</p>
<p>LV supply from network</p>	<p>The DNO considered making an LV supply available direct from the network, but withholding the earth terminal. (e.g. TT arrangement). It should be borne in mind that the LV neutral / earth will remain tied close-to-zero volts under transmission EPR events, and therefore the possibility of insulation breakdown / flashover to the LV system is very real. Whilst it may be possible to duct the LV cable, there will be little or no control of the LV circuit routing arrangements etc, (e.g. some may pass close to, or in contact with site steelwork) and for this reason the unisolated LV supply should not be used when EPR can exceed e.g. 440V, (or nominal withstand voltage of LV cable or equipment insulation). Isolation transformers are an option, though care is required with the siting and protection of the isolation unit itself.</p>
<p>Dedicated off-site transformer and LV supply into site</p>	<p>Offers little or no benefit, and introduces the risk of exporting transmission EPR to the transformer. The LV arrangements could be PNB, i.e. the neutral could be earthed at the transmission site (only), whilst the HV could be earthed to the local network. The LV neutral to HV steelwork insulation withstand voltage must be sufficient to withstand the full EPR as a stress-voltage, and the LV cable must be ducted outside the transmission substation.</p>

Option	Merits / Disadvantages

3656


3657 In this case, the pole-mounted transformer and overhead 11kV line solution has been adopted.
 3658 This is the minimum cost solution and (because it is a 'back up' supply) the reliability is
 3659 acceptable to the transmission network operator. For operational reasons an ABSD is best
 3660 located outside the site boundary and will serve as a point of isolation and earthing point for
 3661 the 11kV network beyond that point.

3662




3663

3664 **Figure 8 – Overhead supply into High EPR site**



3665

3666



- 3667
- 3668
- 3669
- 3670
- 3671
- 3672
- 3673
- 3674
- 3675
- 3676
- 3677
- 3678
- 3679
- 3680
- 3681
- 3682
- 3683
- 3684
- 3685
- 3686
- 3687
- 3688
- 3689
- 3690
- 3691
- 3692

3693

3694

3695

3696

3697 This page deliberately left blank.

3698

3699