

GC0079 WG

Actions from 31/10/17 Meeting

Item	Action	By whom	When
1	There is need to update the workgroup circulation list as it has some people on the list have either left or retired from the organisation.	?	ASAP
2	There is need to formalise interactions with inverter manufacturers and to see how they can collaborate /engage with Strathclyde in to enable the workgroup to reach a conclusion on immunity test	MK/GS	?
3	Supply revised numbers for generators below 5MW taking into account the latest Week 24 submissions and submit them to MK	PS	Nov 17
4	Finalise the Benefit analysis for increasing RoCoF setting	WR/NG	Nov 17
5	A draft consultation report to be circulated to the meeting by end of November and should include a) A case for retrofitting existing plant b) Proposals for immunity on Type tested plant,	PS	Nov 17
6	Agreed that existing G59 O/F settings should be used for retrospective compliance, and that there was no issue in using 52.0Hz for new installations – as the stage two timing of the present O/F setting at 90s does not figure in the risk analysis as the cut off for risk is 3s. Needs to be explained in the report and codified in legal text	XZ/MK	Dec 17
7	National Grid to contact DFIG manufactures to get their experience on LoM protection under islanding condition. This could be used to support the above conclusion.	GRS	Dec 17
8	Next meeting	ALL	28 November

Commented [NG1]: Mike This was in last month's action. Am I write that the action here is to do nothing. Hence can be deleted